


# Area Type Averages

Building type: College/University. Building size: 25K to less than 50K. Shifts: 2

| Area Type Averages |     |       |      | Normalized Weekly Lights On |         |         |       |        | Normalized Weekly Occupied |         |         |       |       |        |
|--------------------|-----|-------|------|-----------------------------|---------|---------|-------|--------|----------------------------|---------|---------|-------|-------|--------|
| Area Type          | Qty | Watts | Peak | Off                         | Shldr 1 | Shldr 2 | Total | Peak   | Off                        | Shldr 1 | Shldr 2 | Total | % sav |        |
| Auditorium         | AU  | 1     | 250  | 89.33                       | 0.00    | 0.00    | 0.00  | 89.33  | 50.25                      | 0.00    | 0.00    | 0.00  | 50.25 | 43.75% |
| Office             | O   | 26    | 100  | 130.43                      | 0.00    | 0.00    | 0.00  | 130.43 | 43.16                      | 0.00    | 0.00    | 0.00  | 43.16 | 66.91% |
| Building Average   |     |       | 2850 | 126.82                      |         |         | 0.00  | 126.82 | 43.78                      |         |         | 0.00  | 43.78 | 65.48% |



**Hours per Week for each Area Type**

Data Logger Detail Building type:College/University. Building size:25K to less than 50K. Shifts:2 Page 1 of 1

| All Loggers Listed |            |    | Hours Installed |        |      |         |         |                  |                  | Lights On |      |         |         |        | Occupied |      |         |         |        |
|--------------------|------------|----|-----------------|--------|------|---------|---------|------------------|------------------|-----------|------|---------|---------|--------|----------|------|---------|---------|--------|
| Logger             | Area Type  | Ty | Total           | Peak   | Off  | Shldr 1 | Shldr 2 | Installed        | Removed          | Peak      | Off  | Shldr 1 | Shldr 2 | Total  | Peak     | Off  | Shldr 1 | Shldr 2 | Total  |
| 20420              | Auditorium | AU | 825.43          | 825.43 | 0.00 | 0.00    | 0.00    | 6/09/05 2:35 PM  | 7/14/05 12:00 AM | 438.88    | 0.00 | 0.00    | 0.00    | 438.88 | 246.92   | 0.00 | 0.00    | 0.00    | 246.92 |
| 20015              | Office     | O  | 824.22          | 824.22 | 0.00 | 0.00    | 0.00    | 6/09/05 3:48 PM  | 7/14/05 12:00 AM | 762.15    | 0.00 | 0.00    | 0.00    | 762.15 | 63.07    | 0.00 | 0.00    | 0.00    | 63.07  |
| 20469              | Office     | O  | 641.43          | 641.43 | 0.00 | 0.00    | 0.00    | 6/09/05 2:41 PM  | 7/06/05 8:06 AM  | 641.35    | 0.00 | 0.00    | 0.00    | 641.35 | 231.20   | 0.00 | 0.00    | 0.00    | 231.20 |
| 20478              | Office     | O  | 723.87          | 723.87 | 0.00 | 0.00    | 0.00    | 6/09/05 4:04 PM  | 7/09/05 7:55 PM  | 723.85    | 0.00 | 0.00    | 0.00    | 723.85 | 245.97   | 0.00 | 0.00    | 0.00    | 245.97 |
| 20338              | Office     | O  | 505.77          | 505.77 | 0.00 | 0.00    | 0.00    | 6/09/05 3:58 PM  | 6/30/05 5:43 PM  | 505.75    | 0.00 | 0.00    | 0.00    | 505.75 | 237.65   | 0.00 | 0.00    | 0.00    | 237.65 |
| 20473              | Office     | O  | 824.18          | 824.18 | 0.00 | 0.00    | 0.00    | 6/09/05 3:50 PM  | 7/14/05 12:00 AM | 478.35    | 0.00 | 0.00    | 0.00    | 478.35 | 269.60   | 0.00 | 0.00    | 0.00    | 269.60 |
| 20288              | Office     | O  | 767.35          | 767.35 | 0.00 | 0.00    | 0.00    | 6/10/05 10:48 AM | 7/12/05 10:08 AM | 149.23    | 0.00 | 0.00    | 0.00    | 149.23 | 81.20    | 0.00 | 0.00    | 0.00    | 81.20  |
| 20259              | Office     | O  | 824.95          | 824.95 | 0.00 | 0.00    | 0.00    | 6/09/05 3:04 PM  | 7/14/05 12:00 AM | 788.53    | 0.00 | 0.00    | 0.00    | 788.53 | 56.97    | 0.00 | 0.00    | 0.00    | 56.97  |
| 20017              | Office     | O  | 695.67          | 695.67 | 0.00 | 0.00    | 0.00    | 6/09/05 3:53 PM  | 7/08/05 3:32 PM  | 450.05    | 0.00 | 0.00    | 0.00    | 450.05 | 247.75   | 0.00 | 0.00    | 0.00    | 247.75 |
| 20256              | Office     | O  | 823.92          | 823.92 | 0.00 | 0.00    | 0.00    | 6/09/05 4:06 PM  | 7/14/05 12:00 AM | 786.42    | 0.00 | 0.00    | 0.00    | 786.42 | 348.47   | 0.00 | 0.00    | 0.00    | 348.47 |
| 20141              | Office     | O  | 824.07          | 824.07 | 0.00 | 0.00    | 0.00    | 6/09/05 3:57 PM  | 7/14/05 12:00 AM | 519.63    | 0.00 | 0.00    | 0.00    | 519.63 | 35.17    | 0.00 | 0.00    | 0.00    | 35.17  |
| 20394              | Office     | O  | 824.17          | 824.17 | 0.00 | 0.00    | 0.00    | 6/09/05 3:51 PM  | 7/14/05 12:00 AM | 400.93    | 0.00 | 0.00    | 0.00    | 400.93 | 205.40   | 0.00 | 0.00    | 0.00    | 205.40 |
| 20207              | Office     | O  | 825.40          | 825.40 | 0.00 | 0.00    | 0.00    | 6/09/05 2:37 PM  | 7/14/05 12:00 AM | 439.53    | 0.00 | 0.00    | 0.00    | 439.53 | 345.87   | 0.00 | 0.00    | 0.00    | 345.87 |
| 20095              | Office     | O  | 522.10          | 522.10 | 0.00 | 0.00    | 0.00    | 6/09/05 2:58 PM  | 7/01/05 9:03 AM  | 522.08    | 0.00 | 0.00    | 0.00    | 522.08 | 195.80   | 0.00 | 0.00    | 0.00    | 195.80 |
| 20089              | Office     | O  | 672.55          | 672.55 | 0.00 | 0.00    | 0.00    | 6/09/05 2:46 PM  | 7/07/05 3:18 PM  | 378.50    | 0.00 | 0.00    | 0.00    | 378.50 | 233.03   | 0.00 | 0.00    | 0.00    | 233.03 |
| 20312              | Office     | O  | 788.65          | 788.65 | 0.00 | 0.00    | 0.00    | 6/09/05 2:55 PM  | 7/12/05 11:33 AM | 782.37    | 0.00 | 0.00    | 0.00    | 782.37 | 137.10   | 0.00 | 0.00    | 0.00    | 137.10 |
| 20365              | Office     | O  | 825.30          | 825.30 | 0.00 | 0.00    | 0.00    | 6/09/05 2:43 PM  | 7/14/05 12:00 AM | 233.87    | 0.00 | 0.00    | 0.00    | 233.87 | 153.80   | 0.00 | 0.00    | 0.00    | 153.80 |
| 20461              | Office     | O  | 825.28          | 825.28 | 0.00 | 0.00    | 0.00    | 6/09/05 2:44 PM  | 7/14/05 12:00 AM | 439.22    | 0.00 | 0.00    | 0.00    | 439.22 | 254.70   | 0.00 | 0.00    | 0.00    | 254.70 |
| 20258              | Office     | O  | 449.92          | 449.92 | 0.00 | 0.00    | 0.00    | 6/09/05 3:04 PM  | 6/28/05 8:58 AM  | 449.87    | 0.00 | 0.00    | 0.00    | 449.87 | 25.00    | 0.00 | 0.00    | 0.00    | 25.00  |
| 20046              | Office     | O  | 824.15          | 824.15 | 0.00 | 0.00    | 0.00    | 6/09/05 3:52 PM  | 7/14/05 12:00 AM | 472.75    | 0.00 | 0.00    | 0.00    | 472.75 | 202.40   | 0.00 | 0.00    | 0.00    | 202.40 |
| 20465              | Office     | O  | 823.87          | 823.87 | 0.00 | 0.00    | 0.00    | 6/09/05 4:09 PM  | 7/14/05 12:00 AM | 786.33    | 0.00 | 0.00    | 0.00    | 786.33 | 152.87   | 0.00 | 0.00    | 0.00    | 152.87 |
| 20239              | Office     | O  | 824.13          | 824.13 | 0.00 | 0.00    | 0.00    | 6/09/05 3:53 PM  | 7/14/05 12:00 AM | 503.90    | 0.00 | 0.00    | 0.00    | 503.90 | 14.07    | 0.00 | 0.00    | 0.00    | 14.07  |
| 20244              | Office     | O  | 823.98          | 823.98 | 0.00 | 0.00    | 0.00    | 6/09/05 4:02 PM  | 7/14/05 12:00 AM | 786.55    | 0.00 | 0.00    | 0.00    | 786.55 | 160.30   | 0.00 | 0.00    | 0.00    | 160.30 |
| 20056              | Office     | O  | 715.65          | 715.65 | 0.00 | 0.00    | 0.00    | 6/09/05 2:54 PM  | 7/09/05 10:32 AM | 715.60    | 0.00 | 0.00    | 0.00    | 715.60 | 294.23   | 0.00 | 0.00    | 0.00    | 294.23 |
| 20050              | Office     | O  | 647.75          | 647.75 | 0.00 | 0.00    | 0.00    | 6/09/05 2:44 PM  | 7/06/05 2:28 PM  | 557.18    | 0.00 | 0.00    | 0.00    | 557.18 | 241.18   | 0.00 | 0.00    | 0.00    | 241.18 |
| 20159              | Office     | O  | 825.37          | 825.37 | 0.00 | 0.00    | 0.00    | 6/09/05 2:39 PM  | 7/14/05 12:00 AM | 787.73    | 0.00 | 0.00    | 0.00    | 787.73 | 135.67   | 0.00 | 0.00    | 0.00    | 135.67 |
| 20013              | Office     | O  | 624.83          | 624.83 | 0.00 | 0.00    | 0.00    | 6/09/05 4:01 PM  | 7/05/05 4:50 PM  | 624.78    | 0.00 | 0.00    | 0.00    | 624.78 | 252.93   | 0.00 | 0.00    | 0.00    | 252.93 |

| All Loggers Listed |            |    | Load  | Normalized Weekly Hours of Use |      |         |         |        | Normalized Weekly Hours of Occupancy |      |         |         |       |        |
|--------------------|------------|----|-------|--------------------------------|------|---------|---------|--------|--------------------------------------|------|---------|---------|-------|--------|
| Logger             | Area Type  | Ty | Watts | Peak                           | Off  | Shldr 1 | Shldr 2 | Total  | Peak                                 | Off  | Shldr 1 | Shldr 2 | Total | % sav  |
| 20420              | Auditorium | AU | 250   | 89.33                          | 0.00 | 0.00    | 0.00    | 89.33  | 50.25                                | 0.00 | 0.00    | 0.00    | 50.25 | 43.75% |
| 20015              | Office     | O  | 100   | 155.35                         | 0.00 | 0.00    | 0.00    | 155.35 | 12.85                                | 0.00 | 0.00    | 0.00    | 12.85 | 91.73% |
| 20469              | Office     | O  | 100   | 167.98                         | 0.00 | 0.00    | 0.00    | 167.98 | 60.55                                | 0.00 | 0.00    | 0.00    | 60.55 | 63.95% |
| 20478              | Office     | O  | 100   | 168.00                         | 0.00 | 0.00    | 0.00    | 168.00 | 57.09                                | 0.00 | 0.00    | 0.00    | 57.09 | 66.02% |
| 20338              | Office     | O  | 100   | 167.99                         | 0.00 | 0.00    | 0.00    | 167.99 | 78.94                                | 0.00 | 0.00    | 0.00    | 78.94 | 53.01% |
| 20473              | Office     | O  | 100   | 97.51                          | 0.00 | 0.00    | 0.00    | 97.51  | 54.95                                | 0.00 | 0.00    | 0.00    | 54.95 | 43.65% |
| 20288              | Office     | O  | 100   | 32.67                          | 0.00 | 0.00    | 0.00    | 32.67  | 17.78                                | 0.00 | 0.00    | 0.00    | 17.78 | 45.58% |
| 20259              | Office     | O  | 100   | 160.58                         | 0.00 | 0.00    | 0.00    | 160.58 | 11.60                                | 0.00 | 0.00    | 0.00    | 11.60 | 92.78% |
| 20017              | Office     | O  | 100   | 108.68                         | 0.00 | 0.00    | 0.00    | 108.68 | 59.83                                | 0.00 | 0.00    | 0.00    | 59.83 | 44.95% |
| 20256              | Office     | O  | 100   | 160.35                         | 0.00 | 0.00    | 0.00    | 160.35 | 71.05                                | 0.00 | 0.00    | 0.00    | 71.05 | 55.69% |
| 20141              | Office     | O  | 100   | 105.94                         | 0.00 | 0.00    | 0.00    | 105.94 | 7.17                                 | 0.00 | 0.00    | 0.00    | 7.17  | 93.23% |
| 20394              | Office     | O  | 100   | 81.73                          | 0.00 | 0.00    | 0.00    | 81.73  | 41.87                                | 0.00 | 0.00    | 0.00    | 41.87 | 48.77% |
| 20207              | Office     | O  | 100   | 89.46                          | 0.00 | 0.00    | 0.00    | 89.46  | 70.40                                | 0.00 | 0.00    | 0.00    | 70.40 | 21.31% |
| 20095              | Office     | O  | 100   | 167.99                         | 0.00 | 0.00    | 0.00    | 167.99 | 63.00                                | 0.00 | 0.00    | 0.00    | 63.00 | 62.50% |
| 20089              | Office     | O  | 100   | 94.55                          | 0.00 | 0.00    | 0.00    | 94.55  | 58.21                                | 0.00 | 0.00    | 0.00    | 58.21 | 38.43% |
| 20312              | Office     | O  | 100   | 166.66                         | 0.00 | 0.00    | 0.00    | 166.66 | 29.21                                | 0.00 | 0.00    | 0.00    | 29.21 | 82.47% |
| 20365              | Office     | O  | 100   | 47.61                          | 0.00 | 0.00    | 0.00    | 47.61  | 31.31                                | 0.00 | 0.00    | 0.00    | 31.31 | 34.24% |
| 20461              | Office     | O  | 100   | 89.41                          | 0.00 | 0.00    | 0.00    | 89.41  | 51.85                                | 0.00 | 0.00    | 0.00    | 51.85 | 42.01% |
| 20258              | Office     | O  | 100   | 167.98                         | 0.00 | 0.00    | 0.00    | 167.98 | 9.34                                 | 0.00 | 0.00    | 0.00    | 9.34  | 94.44% |
| 20046              | Office     | O  | 100   | 96.37                          | 0.00 | 0.00    | 0.00    | 96.37  | 41.26                                | 0.00 | 0.00    | 0.00    | 41.26 | 57.19% |
| 20465              | Office     | O  | 100   | 160.35                         | 0.00 | 0.00    | 0.00    | 160.35 | 31.17                                | 0.00 | 0.00    | 0.00    | 31.17 | 80.56% |
| 20239              | Office     | O  | 100   | 102.72                         | 0.00 | 0.00    | 0.00    | 102.72 | 2.87                                 | 0.00 | 0.00    | 0.00    | 2.87  | 97.21% |
| 20244              | Office     | O  | 100   | 160.37                         | 0.00 | 0.00    | 0.00    | 160.37 | 32.68                                | 0.00 | 0.00    | 0.00    | 32.68 | 79.62% |
| 20056              | Office     | O  | 100   | 167.99                         | 0.00 | 0.00    | 0.00    | 167.99 | 69.07                                | 0.00 | 0.00    | 0.00    | 69.07 | 58.88% |
| 20050              | Office     | O  | 100   | 144.51                         | 0.00 | 0.00    | 0.00    | 144.51 | 62.55                                | 0.00 | 0.00    | 0.00    | 62.55 | 56.72% |
| 20159              | Office     | O  | 100   | 160.34                         | 0.00 | 0.00    | 0.00    | 160.34 | 27.61                                | 0.00 | 0.00    | 0.00    | 27.61 | 82.78% |
| 20013              | Office     | O  | 100   | 167.99                         | 0.00 | 0.00    | 0.00    | 167.99 | 68.01                                | 0.00 | 0.00    | 0.00    | 68.01 | 59.52% |

Building Summary Totals Building type:College/University. Building size:25K to less than 50K. Shifts:2 Page 1 of 1

| Building Summary Totals |    |     |       | Lights On KWHR |     |         |         |       | Occupied KWHR |     |         |         |       |
|-------------------------|----|-----|-------|----------------|-----|---------|---------|-------|---------------|-----|---------|---------|-------|
| Area Type               |    | Qty | Watts | Peak           | Off | Shldr 1 | Shldr 2 | Total | Peak          | Off | Shldr 1 | Shldr 2 | Total |
| Auditorium              | AU | 1   | 250   | 22             | 0   | 0       | 0       | 22    | 13            | 0   | 0       | 0       | 13    |
| Office                  | O  | 26  | 2600  | 339            | 0   | 0       | 0       | 339   | 112           | 0   | 0       | 0       | 112   |
| Building Totals         |    |     | 2850  | 361            |     |         | 0       | 361   | 125           |     |         | 0       | 125   |