


Area Type Averages

Building type: College/University. Building size: 25K to less than 50K. Shifts: 2

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Meeting Rooms	M	2	112	132.75	0.00	0.00	0.00	132.75	62.01	0.00	0.00	0.00	62.01	53.29%
Restroom	R	5	103	164.67	0.00	0.00	0.00	164.67	31.88	0.00	0.00	0.00	31.88	80.64%
Storage	S	4	88	115.46	0.00	0.00	0.00	115.46	33.11	0.00	0.00	0.00	33.11	71.32%
Hallway	H	1	100	167.99	0.00	0.00	0.00	167.99	78.94	0.00	0.00	0.00	78.94	53.01%
Mechanical Room /	MR	1	114	47.61	0.00	0.00	0.00	47.61	31.31	0.00	0.00	0.00	31.31	34.24%
Fitting Room	FR	6	114	127.01	0.00	0.00	0.00	127.01	56.36	0.00	0.00	0.00	56.36	55.63%
Stock Room	ST	1	110	89.41	0.00	0.00	0.00	89.41	51.85	0.00	0.00	0.00	51.85	42.01%
Office	O	6	104	127.72	0.00	0.00	0.00	127.72	35.85	0.00	0.00	0.00	35.85	71.93%
Computer Room	CP	1	114	96.37	0.00	0.00	0.00	96.37	41.26	0.00	0.00	0.00	41.26	57.19%
Building Average			2837	128.59				128.59	43.97				43.97	65.81%



Hours per Week for each Area Type

Data Logger Detail Building type:College/University. Building size:25K to less than 50K. Shifts:2 Page 1 of 1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20394	Office	O	824.17	824.17	0.00	0.00	0.00	6/09/05 12:51 PM	7/13/05 9:00 PM	400.93	0.00	0.00	0.00	400.93	205.40	0.00	0.00	0.00	205.40
20461	Stock Room	ST	825.28	825.28	0.00	0.00	0.00	6/09/05 11:44 AM	7/13/05 9:00 PM	439.22	0.00	0.00	0.00	439.22	254.70	0.00	0.00	0.00	254.70
20465	Fitting Room	FR	823.87	823.87	0.00	0.00	0.00	6/09/05 1:09 PM	7/13/05 9:00 PM	786.33	0.00	0.00	0.00	786.33	152.87	0.00	0.00	0.00	152.87
20420	Fitting Room	FR	825.43	825.43	0.00	0.00	0.00	6/09/05 11:35 AM	7/13/05 9:00 PM	438.88	0.00	0.00	0.00	438.88	246.92	0.00	0.00	0.00	246.92
20056	Meeting Rooms	M	715.65	715.65	0.00	0.00	0.00	6/09/05 11:54 AM	7/09/05 7:32 AM	715.60	0.00	0.00	0.00	715.60	294.23	0.00	0.00	0.00	294.23
20473	Meeting Rooms	M	824.18	824.18	0.00	0.00	0.00	6/09/05 12:50 PM	7/13/05 9:00 PM	478.35	0.00	0.00	0.00	478.35	269.60	0.00	0.00	0.00	269.60
20046	Computer Room	CP	824.15	824.15	0.00	0.00	0.00	6/09/05 12:52 PM	7/13/05 9:00 PM	472.75	0.00	0.00	0.00	472.75	202.40	0.00	0.00	0.00	202.40
20256	Fitting Room	FR	823.92	823.92	0.00	0.00	0.00	6/09/05 1:06 PM	7/13/05 9:00 PM	786.42	0.00	0.00	0.00	786.42	348.47	0.00	0.00	0.00	348.47
20207	Fitting Room	FR	825.40	825.40	0.00	0.00	0.00	6/09/05 11:37 AM	7/13/05 9:00 PM	439.53	0.00	0.00	0.00	439.53	345.87	0.00	0.00	0.00	345.87
20312	Restroom	R	788.65	788.65	0.00	0.00	0.00	6/09/05 11:55 AM	7/12/05 8:33 AM	782.37	0.00	0.00	0.00	782.37	137.10	0.00	0.00	0.00	137.10
20469	Restroom	R	641.43	641.43	0.00	0.00	0.00	6/09/05 11:41 AM	7/06/05 5:06 AM	641.35	0.00	0.00	0.00	641.35	231.20	0.00	0.00	0.00	231.20
20013	Office	O	624.83	624.83	0.00	0.00	0.00	6/09/05 1:01 PM	7/05/05 1:50 PM	624.78	0.00	0.00	0.00	624.78	252.93	0.00	0.00	0.00	252.93
20478	Fitting Room	FR	723.87	723.87	0.00	0.00	0.00	6/09/05 1:04 PM	7/09/05 4:55 PM	723.85	0.00	0.00	0.00	723.85	245.97	0.00	0.00	0.00	245.97
20089	Fitting Room	FR	672.55	672.55	0.00	0.00	0.00	6/09/05 11:46 AM	7/07/05 12:18 PM	378.50	0.00	0.00	0.00	378.50	233.03	0.00	0.00	0.00	233.03
20258	Restroom	R	449.92	449.92	0.00	0.00	0.00	6/09/05 12:04 PM	6/28/05 5:58 AM	449.87	0.00	0.00	0.00	449.87	25.00	0.00	0.00	0.00	25.00
20244	Restroom	R	823.98	823.98	0.00	0.00	0.00	6/09/05 1:02 PM	7/13/05 9:00 PM	786.55	0.00	0.00	0.00	786.55	160.30	0.00	0.00	0.00	160.30
20159	Restroom	R	825.37	825.37	0.00	0.00	0.00	6/09/05 11:39 AM	7/13/05 9:00 PM	787.73	0.00	0.00	0.00	787.73	135.67	0.00	0.00	0.00	135.67
20288	Office	O	767.35	767.35	0.00	0.00	0.00	6/10/05 7:48 AM	7/12/05 7:08 AM	149.23	0.00	0.00	0.00	149.23	81.20	0.00	0.00	0.00	81.20
20015	Office	O	824.22	824.22	0.00	0.00	0.00	6/09/05 12:48 PM	7/13/05 9:00 PM	762.15	0.00	0.00	0.00	762.15	63.07	0.00	0.00	0.00	63.07
20050	Storage	S	647.75	647.75	0.00	0.00	0.00	6/09/05 11:44 AM	7/06/05 11:28 AM	557.18	0.00	0.00	0.00	557.18	241.18	0.00	0.00	0.00	241.18
20141	Storage	S	824.07	824.07	0.00	0.00	0.00	6/09/05 12:57 PM	7/13/05 9:00 PM	519.63	0.00	0.00	0.00	519.63	35.17	0.00	0.00	0.00	35.17
20239	Storage	S	824.13	824.13	0.00	0.00	0.00	6/09/05 12:53 PM	7/13/05 9:00 PM	503.90	0.00	0.00	0.00	503.90	14.07	0.00	0.00	0.00	14.07
20017	Storage	S	695.67	695.67	0.00	0.00	0.00	6/09/05 12:53 PM	7/08/05 12:32 PM	450.05	0.00	0.00	0.00	450.05	247.75	0.00	0.00	0.00	247.75
20365	Mechanical Room / Storage	MR	825.30	825.30	0.00	0.00	0.00	6/09/05 11:43 AM	7/13/05 9:00 PM	233.87	0.00	0.00	0.00	233.87	153.80	0.00	0.00	0.00	153.80
20338	Hallway	H	505.77	505.77	0.00	0.00	0.00	6/09/05 12:58 PM	6/30/05 2:43 PM	505.75	0.00	0.00	0.00	505.75	237.65	0.00	0.00	0.00	237.65
20259	Office	O	824.95	824.95	0.00	0.00	0.00	6/09/05 12:04 PM	7/13/05 9:00 PM	788.53	0.00	0.00	0.00	788.53	56.97	0.00	0.00	0.00	56.97
20095	Office	O	522.10	522.10	0.00	0.00	0.00	6/09/05 11:58 AM	7/01/05 6:03 AM	522.08	0.00	0.00	0.00	522.08	195.80	0.00	0.00	0.00	195.80

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20394	Office	O	114	81.73	0.00	0.00	0.00	81.73	41.87	0.00	0.00	0.00	41.87	48.77%
20461	Stock Room	ST	110	89.41	0.00	0.00	0.00	89.41	51.85	0.00	0.00	0.00	51.85	42.01%
20465	Fitting Room	FR	114	160.35	0.00	0.00	0.00	160.35	31.17	0.00	0.00	0.00	31.17	80.56%
20420	Fitting Room	FR	114	89.33	0.00	0.00	0.00	89.33	50.25	0.00	0.00	0.00	50.25	43.75%
20056	Meeting Rooms	M	110	167.99	0.00	0.00	0.00	167.99	69.07	0.00	0.00	0.00	69.07	58.88%
20473	Meeting Rooms	M	114	97.51	0.00	0.00	0.00	97.51	54.95	0.00	0.00	0.00	54.95	43.65%
20046	Computer	CP	114	96.37	0.00	0.00	0.00	96.37	41.26	0.00	0.00	0.00	41.26	57.19%
20256	Fitting Room	FR	114	160.35	0.00	0.00	0.00	160.35	71.05	0.00	0.00	0.00	71.05	55.69%
20207	Fitting Room	FR	114	89.46	0.00	0.00	0.00	89.46	70.40	0.00	0.00	0.00	70.40	21.31%
20312	Restroom	R	60	166.66	0.00	0.00	0.00	166.66	29.21	0.00	0.00	0.00	29.21	82.47%
20469	Restroom	R	114	167.98	0.00	0.00	0.00	167.98	60.55	0.00	0.00	0.00	60.55	63.95%
20013	Office	O	114	167.99	0.00	0.00	0.00	167.99	68.01	0.00	0.00	0.00	68.01	59.52%
20478	Fitting Room	FR	114	168.00	0.00	0.00	0.00	168.00	57.09	0.00	0.00	0.00	57.09	66.02%
20089	Fitting Room	FR	114	94.55	0.00	0.00	0.00	94.55	58.21	0.00	0.00	0.00	58.21	38.43%
20258	Restroom	R	114	167.98	0.00	0.00	0.00	167.98	9.34	0.00	0.00	0.00	9.34	94.44%
20244	Restroom	R	114	160.37	0.00	0.00	0.00	160.37	32.68	0.00	0.00	0.00	32.68	79.62%
20159	Restroom	R	114	160.34	0.00	0.00	0.00	160.34	27.61	0.00	0.00	0.00	27.61	82.78%
20288	Office	O	110	32.67	0.00	0.00	0.00	32.67	17.78	0.00	0.00	0.00	17.78	45.58%
20015	Office	O	114	155.35	0.00	0.00	0.00	155.35	12.85	0.00	0.00	0.00	12.85	91.73%
20050	Storage	S	30	144.51	0.00	0.00	0.00	144.51	62.55	0.00	0.00	0.00	62.55	56.72%
20141	Storage	S	100	105.94	0.00	0.00	0.00	105.94	7.17	0.00	0.00	0.00	7.17	93.23%
20239	Storage	S	110	102.72	0.00	0.00	0.00	102.72	2.87	0.00	0.00	0.00	2.87	97.21%
20017	Storage	S	110	108.68	0.00	0.00	0.00	108.68	59.83	0.00	0.00	0.00	59.83	44.95%
20365	Mechanical	MR	114	47.61	0.00	0.00	0.00	47.61	31.31	0.00	0.00	0.00	31.31	34.24%
20338	Hallway	H	100	167.99	0.00	0.00	0.00	167.99	78.94	0.00	0.00	0.00	78.94	53.01%
20259	Office	O	110	160.58	0.00	0.00	0.00	160.58	11.60	0.00	0.00	0.00	11.60	92.78%
20095	Office	O	59	167.99	0.00	0.00	0.00	167.99	63.00	0.00	0.00	0.00	63.00	62.50%

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Meeting Rooms	M	2	224	30	0	0	0	30	14	0	0	0	14
Restroom	R	5	515	85	0	0	0	85	16	0	0	0	16
Storage	S	4	352	41	0	0	0	41	12	0	0	0	12
Hallway	H	1	100	17	0	0	0	17	8	0	0	0	8
Mechanical Room /	MR	1	114	5	0	0	0	5	4	0	0	0	4
Fitting Room	FR	6	684	87	0	0	0	87	39	0	0	0	39
Stock Room	ST	1	110	10	0	0	0	10	6	0	0	0	6
Office	O	6	624	80	0	0	0	80	22	0	0	0	22
Computer Room	CP	1	114	11	0	0	0	11	5	0	0	0	5
Building Totals			2837	365			0	365	125			0	125