


Area Type Averages

Building type:Elementary School. Building size:100K to less than 250K. Shifts:1

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Meeting Rooms	M	2	383	49.38	0.00	0.00	0.00	49.38	34.83	0.00	0.00	0.00	34.83	29.47%
Restroom	R	8	170	153.31	0.00	0.00	0.00	153.31	33.07	0.00	0.00	0.00	33.07	78.43%
Storage	S	1	255	90.84	0.00	0.00	0.00	90.84	8.94	0.00	0.00	0.00	8.94	90.16%
Classroom	CR	20	717	49.41	0.00	0.00	0.00	49.41	39.68	0.00	0.00	0.00	39.68	19.69%
Cafeteria	CF	3	4086	63.39	0.00	0.00	0.00	63.39	42.39	0.00	0.00	0.00	42.39	33.13%
Library	LI	6	992	58.28	0.00	0.00	0.00	58.28	27.68	0.00	0.00	0.00	27.68	52.51%
Office	O	5	306	56.68	0.00	0.00	0.00	56.68	42.77	0.00	0.00	0.00	42.77	24.54%
Building Average			36461	60.03			0.00	60.03	38.20			0.00	38.20	36.37%



Hours per Week for each Area Type

Data Logger Detail Building type:Elementary School. Building size:100K to less than 250K. Shifts:1 Page 1 of 1

All Loggers Listed			Hours Installed						Lights On						Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
22223	Office	O	408.02	408.02	0.00	0.00	0.00	8/30/05 9:22 AM	9/16/05 9:22 AM	122.82	0.00	0.00	0.00	122.82	109.55	0.00	0.00	0.00	109.55
22161	Restroom	R	408.02	408.02	0.00	0.00	0.00	8/30/05 10:17 AM	8/30/05 12:47 PM	122.82	0.00	0.00	0.00	122.82	109.55	0.00	0.00	0.00	109.55
20925	Restroom	R	407.72	407.72	0.00	0.00	0.00	8/30/05 10:19 AM	9/16/05 10:01 AM	407.70	0.00	0.00	0.00	407.70	84.02	0.00	0.00	0.00	84.02
21708	Classroom	CR	407.63	407.63	0.00	0.00	0.00	8/30/05 10:21 AM	9/16/05 9:58 AM	103.08	0.00	0.00	0.00	103.08	95.15	0.00	0.00	0.00	95.15
21385	Cafeteria	CF	420.80	420.80	0.00	0.00	0.00	8/30/05 10:13 AM	9/16/05 11:00 PM	155.47	0.00	0.00	0.00	155.47	102.93	0.00	0.00	0.00	102.93
22975	Cafeteria	CF	407.70	407.70	0.00	0.00	0.00	8/30/05 10:14 AM	9/16/05 9:55 AM	155.38	0.00	0.00	0.00	155.38	105.68	0.00	0.00	0.00	105.68
21101	Cafeteria	CF	407.70	407.70	0.00	0.00	0.00	8/30/05 10:13 AM	9/16/05 9:54 AM	155.47	0.00	0.00	0.00	155.47	103.17	0.00	0.00	0.00	103.17
21570	Classroom	CR	407.80	407.80	0.00	0.00	0.00	8/30/05 9:52 AM	9/16/05 9:39 AM	101.08	0.00	0.00	0.00	101.08	94.75	0.00	0.00	0.00	94.75
23044	Classroom	CR	408.00	408.00	0.00	0.00	0.00	8/30/05 9:25 AM	9/16/05 9:24 AM	113.72	0.00	0.00	0.00	113.72	98.45	0.00	0.00	0.00	98.45
20746	Classroom	CR	420.98	420.98	0.00	0.00	0.00	8/30/05 10:02 AM	9/16/05 11:00 PM	136.47	0.00	0.00	0.00	136.47	104.23	0.00	0.00	0.00	104.23
23490	Classroom	CR	407.57	407.57	0.00	0.00	0.00	8/30/05 10:12 AM	9/16/05 9:45 AM	126.63	0.00	0.00	0.00	126.63	115.17	0.00	0.00	0.00	115.17
21089	Classroom	CR	407.83	407.83	0.00	0.00	0.00	8/30/05 9:46 AM	9/16/05 9:35 AM	115.88	0.00	0.00	0.00	115.88	99.48	0.00	0.00	0.00	99.48
22145	Classroom	CR	407.62	407.62	0.00	0.00	0.00	8/30/05 10:21 AM	9/16/05 9:57 AM	110.67	0.00	0.00	0.00	110.67	92.30	0.00	0.00	0.00	92.30
20962	Classroom	CR	407.92	407.92	0.00	0.00	0.00	8/30/05 9:33 AM	9/16/05 9:27 AM	116.40	0.00	0.00	0.00	116.40	106.00	0.00	0.00	0.00	106.00
21412	Classroom	CR	407.72	407.72	0.00	0.00	0.00	8/30/05 9:55 AM	9/16/05 9:37 AM	113.23	0.00	0.00	0.00	113.23	105.90	0.00	0.00	0.00	105.90
21592	Classroom	CR	407.80	407.80	0.00	0.00	0.00	8/30/05 9:53 AM	9/16/05 9:40 AM	89.60	0.00	0.00	0.00	89.60	78.90	0.00	0.00	0.00	78.90
21720	Classroom	CR	407.77	407.77	0.00	0.00	0.00	8/30/05 9:59 AM	9/16/05 9:44 AM	101.42	0.00	0.00	0.00	101.42	89.50	0.00	0.00	0.00	89.50
23069	Restroom	R	407.80	407.80	0.00	0.00	0.00	8/30/05 9:48 AM	9/16/05 9:35 AM	407.78	0.00	0.00	0.00	407.78	82.35	0.00	0.00	0.00	82.35
24612	Restroom	R	407.82	407.82	0.00	0.00	0.00	8/30/05 9:49 AM	9/16/05 9:37 AM	407.80	0.00	0.00	0.00	407.80	78.78	0.00	0.00	0.00	78.78
21505	Classroom	CR	407.98	407.98	0.00	0.00	0.00	8/30/05 9:28 AM	9/16/05 9:26 AM	125.32	0.00	0.00	0.00	125.32	104.68	0.00	0.00	0.00	104.68
24588	Storage	S	407.98	407.98	0.00	0.00	0.00	8/30/05 9:28 AM	9/16/05 9:26 AM	220.60	0.00	0.00	0.00	220.60	21.70	0.00	0.00	0.00	21.70
20955	Library	LI	421.42	421.42	0.00	0.00	0.00	8/30/05 9:36 AM	9/16/05 11:00 PM	170.22	0.00	0.00	0.00	170.22	86.48	0.00	0.00	0.00	86.48
21564	Library	LI	407.92	407.92	0.00	0.00	0.00	8/30/05 9:36 AM	9/16/05 9:30 AM	170.30	0.00	0.00	0.00	170.30	79.75	0.00	0.00	0.00	79.75
22886	Library	LI	407.92	407.92	0.00	0.00	0.00	8/30/05 9:39 AM	9/16/05 9:33 AM	159.47	0.00	0.00	0.00	159.47	90.40	0.00	0.00	0.00	90.40
22749	Library	LI	407.95	407.95	0.00	0.00	0.00	8/30/05 9:38 AM	9/16/05 9:34 AM	159.57	0.00	0.00	0.00	159.57	93.40	0.00	0.00	0.00	93.40
22097	Library	LI	407.85	407.85	0.00	0.00	0.00	8/30/05 9:42 AM	9/16/05 9:32 AM	81.15	0.00	0.00	0.00	81.15	23.82	0.00	0.00	0.00	23.82
22309	Library	LI	407.87	407.87	0.00	0.00	0.00	8/30/05 9:41 AM	9/16/05 9:32 AM	113.73	0.00	0.00	0.00	113.73	32.12	0.00	0.00	0.00	32.12
22348	Classroom	CR	407.77	407.77	0.00	0.00	0.00	8/30/05 9:54 AM	9/16/05 9:39 AM	89.45	0.00	0.00	0.00	89.45	83.95	0.00	0.00	0.00	83.95
21036	Classroom	CR	407.78	407.78	0.00	0.00	0.00	8/30/05 10:00 AM	9/16/05 9:46 AM	120.28	0.00	0.00	0.00	120.28	102.62	0.00	0.00	0.00	102.62
22867	Classroom	CR	407.75	407.75	0.00	0.00	0.00	8/30/05 10:00 AM	9/16/05 9:44 AM	126.03	0.00	0.00	0.00	126.03	111.00	0.00	0.00	0.00	111.00
22149	Classroom	CR	407.97	407.97	0.00	0.00	0.00	8/30/05 9:30 AM	9/16/05 9:27 AM	119.97	0.00	0.00	0.00	119.97	105.17	0.00	0.00	0.00	105.17
23043	Classroom	CR	407.93	407.93	0.00	0.00	0.00	8/30/05 9:33 AM	9/16/05 9:28 AM	129.18	0.00	0.00	0.00	129.18	112.35	0.00	0.00	0.00	112.35
22656	Classroom	CR	407.93	407.93	0.00	0.00	0.00	8/30/05 9:32 AM	9/16/05 9:27 AM	269.58	0.00	0.00	0.00	269.58	56.27	0.00	0.00	0.00	56.27
22139	Classroom	CR	407.77	407.77	0.00	0.00	0.00	8/30/05 9:50 AM	9/16/05 9:35 AM	90.25	0.00	0.00	0.00	90.25	83.62	0.00	0.00	0.00	83.62
20971	Office	O	407.67	407.67	0.00	0.00	0.00	8/30/05 10:24 AM	9/16/05 10:03 AM	197.27	0.00	0.00	0.00	197.27	106.17	0.00	0.00	0.00	106.17
20634	Office	O	407.83	407.83	0.00	0.00	0.00	8/30/05 9:46 AM	9/16/05 9:35 AM	99.93	0.00	0.00	0.00	99.93	87.77	0.00	0.00	0.00	87.77
20995	Office	O	407.83	407.83	0.00	0.00	0.00	8/30/05 9:44 AM	9/16/05 9:33 AM	93.27	0.00	0.00	0.00	93.27	72.53	0.00	0.00	0.00	72.53
20675	Restroom	R	407.72	407.72	0.00	0.00	0.00	8/30/05 10:07 AM	9/16/05 9:49 AM	407.70	0.00	0.00	0.00	407.70	21.67	0.00	0.00	0.00	21.67
23240	Restroom	R	407.70	407.70	0.00	0.00	0.00	8/30/05 10:09 AM	9/16/05 9:50 AM	407.68	0.00	0.00	0.00	407.68	102.82	0.00	0.00	0.00	102.82
22232	Meeting Rooms	M	407.73	407.73	0.00	0.00	0.00	8/30/05 10:05 AM	9/16/05 9:48 AM	169.75	0.00	0.00	0.00	169.75	105.38	0.00	0.00	0.00	105.38
21929	Classroom	CR	407.63	407.63	0.00	0.00	0.00	8/30/05 10:19 AM	9/16/05 9:56 AM	104.90	0.00	0.00	0.00	104.90	90.10	0.00	0.00	0.00	90.10
21573	Meeting Rooms	M	407.80	407.80	0.00	0.00	0.00	8/30/05 10:07 AM	9/16/05 9:54 AM	69.93	0.00	0.00	0.00	69.93	63.70	0.00	0.00	0.00	63.70
20899	Office	O	407.67	407.67	0.00	0.00	0.00	8/30/05 10:25 AM	9/16/05 10:04 AM	174.63	0.00	0.00	0.00	174.63	143.07	0.00	0.00	0.00	143.07
20702	Restroom	R	407.75	407.75	0.00	0.00	0.00	8/30/05 9:58 AM	9/16/05 9:42 AM	407.73	0.00	0.00	0.00	407.73	77.83	0.00	0.00	0.00	77.83
24671	Restroom	R	407.77	407.77	0.00	0.00	0.00	8/30/05 9:58 AM	9/16/05 9:43 AM	407.75	0.00	0.00	0.00	407.75	85.05	0.00	0.00	0.00	85.05

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
22223	Office	O	340	50.57	0.00	0.00	0.00	50.57	45.11	0.00	0.00	0.00	45.11	10.80%
22161	Restroom	R	170	50.57	0.00	0.00	0.00	50.57	45.11	0.00	0.00	0.00	45.11	10.80%
20925	Restroom	R	170	167.99	0.00	0.00	0.00	167.99	34.62	0.00	0.00	0.00	34.62	79.39%
21708	Classroom	CR	765	42.48	0.00	0.00	0.00	42.48	39.21	0.00	0.00	0.00	39.21	7.70%
21385	Cafeteria	CF	4086	62.07	0.00	0.00	0.00	62.07	41.10	0.00	0.00	0.00	41.10	33.78%
22975	Cafeteria	CF	4086	64.03	0.00	0.00	0.00	64.03	43.55	0.00	0.00	0.00	43.55	31.99%
21101	Cafeteria	CF	4086	64.06	0.00	0.00	0.00	64.06	42.51	0.00	0.00	0.00	42.51	33.64%
21570	Classroom	CR	765	41.64	0.00	0.00	0.00	41.64	39.03	0.00	0.00	0.00	39.03	6.27%
23044	Classroom	CR	765	46.82	0.00	0.00	0.00	46.82	40.54	0.00	0.00	0.00	40.54	13.41%
20746	Classroom	CR	765	54.46	0.00	0.00	0.00	54.46	41.60	0.00	0.00	0.00	41.60	23.61%
23490	Classroom	CR	765	52.20	0.00	0.00	0.00	52.20	47.47	0.00	0.00	0.00	47.47	9.06%
21089	Classroom	CR	510	47.74	0.00	0.00	0.00	47.74	40.98	0.00	0.00	0.00	40.98	14.16%
22145	Classroom	CR	765	45.61	0.00	0.00	0.00	45.61	38.04	0.00	0.00	0.00	38.04	16.60%
20962	Classroom	CR	765	47.94	0.00	0.00	0.00	47.94	43.66	0.00	0.00	0.00	43.66	8.93%
21412	Classroom	CR	765	46.66	0.00	0.00	0.00	46.66	43.64	0.00	0.00	0.00	43.64	6.47%
21592	Classroom	CR	765	36.91	0.00	0.00	0.00	36.91	32.50	0.00	0.00	0.00	32.50	11.95%
21720	Classroom	CR	765	41.78	0.00	0.00	0.00	41.78	36.87	0.00	0.00	0.00	36.87	11.75%
23069	Restroom	R	170	167.99	0.00	0.00	0.00	167.99	33.93	0.00	0.00	0.00	33.93	79.80%
24612	Restroom	R	170	167.99	0.00	0.00	0.00	167.99	32.45	0.00	0.00	0.00	32.45	80.68%
21505	Classroom	CR	765	51.60	0.00	0.00	0.00	51.60	43.11	0.00	0.00	0.00	43.11	16.45%
24588	Storage	S	255	90.84	0.00	0.00	0.00	90.84	8.94	0.00	0.00	0.00	8.94	90.16%
20955	Library	LI	1275	67.86	0.00	0.00	0.00	67.86	34.48	0.00	0.00	0.00	34.48	49.19%
21564	Library	LI	1275	70.14	0.00	0.00	0.00	70.14	32.84	0.00	0.00	0.00	32.84	53.18%
22886	Library	LI	1445	65.68	0.00	0.00	0.00	65.68	37.23	0.00	0.00	0.00	37.23	43.32%
22749	Library	LI	1445	65.71	0.00	0.00	0.00	65.71	38.46	0.00	0.00	0.00	38.46	41.47%
22097	Library	LI	170	33.43	0.00	0.00	0.00	33.43	9.81	0.00	0.00	0.00	9.81	70.66%
22309	Library	LI	340	46.85	0.00	0.00	0.00	46.85	13.23	0.00	0.00	0.00	13.23	71.76%
22348	Classroom	CR	765	36.85	0.00	0.00	0.00	36.85	34.59	0.00	0.00	0.00	34.59	6.13%
21036	Classroom	CR	765	49.55	0.00	0.00	0.00	49.55	42.28	0.00	0.00	0.00	42.28	14.67%
22867	Classroom	CR	765	51.93	0.00	0.00	0.00	51.93	45.73	0.00	0.00	0.00	45.73	11.94%
22149	Classroom	CR	765	49.40	0.00	0.00	0.00	49.40	43.31	0.00	0.00	0.00	43.31	12.33%
23043	Classroom	CR	765	53.20	0.00	0.00	0.00	53.20	46.27	0.00	0.00	0.00	46.27	13.03%
22656	Classroom	CR	58	111.02	0.00	0.00	0.00	111.02	23.17	0.00	0.00	0.00	23.17	79.13%
22139	Classroom	CR	765	37.18	0.00	0.00	0.00	37.18	34.45	0.00	0.00	0.00	34.45	7.34%
20971	Office	O	170	81.29	0.00	0.00	0.00	81.29	43.75	0.00	0.00	0.00	43.75	46.18%
20634	Office	O	255	41.17	0.00	0.00	0.00	41.17	36.15	0.00	0.00	0.00	36.15	12.19%
20995	Office	O	255	38.42	0.00	0.00	0.00	38.42	29.88	0.00	0.00	0.00	29.88	22.23%
20675	Restroom	R	170	167.99	0.00	0.00	0.00	167.99	8.93	0.00	0.00	0.00	8.93	94.68%
23240	Restroom	R	170	167.99	0.00	0.00	0.00	167.99	42.37	0.00	0.00	0.00	42.37	74.78%
22232	Meeting Rooms	M	510	69.94	0.00	0.00	0.00	69.94	43.42	0.00	0.00	0.00	43.42	37.92%
21929	Classroom	CR	765	43.23	0.00	0.00	0.00	43.23	37.13	0.00	0.00	0.00	37.13	14.11%
21573	Meeting Rooms	M	255	28.81	0.00	0.00	0.00	28.81	26.24	0.00	0.00	0.00	26.24	8.92%
20899	Office	O	510	71.97	0.00	0.00	0.00	71.97	58.96	0.00	0.00	0.00	58.96	18.08%
20702	Restroom	R	170	167.99	0.00	0.00	0.00	167.99	32.07	0.00	0.00	0.00	32.07	80.91%
24671	Restroom	R	170	167.99	0.00	0.00	0.00	167.99	35.04	0.00	0.00	0.00	35.04	79.14%

Building Summary Totals Building type:Elementary School. Building size:100K to less than 250K. Shifts:1 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Meeting Rooms	M	2	766	38	0	0	0	38	27	0	0	0	27
Restroom	R	8	1360	209	0	0	0	209	45	0	0	0	45
Storage	S	1	255	23	0	0	0	23	2	0	0	0	2
Classroom	CR	20	14340	709	0	0	0	709	569	0	0	0	569
Cafeteria	CF	3	12258	777	0	0	0	777	520	0	0	0	520
Library	LI	6	5952	347	0	0	0	347	165	0	0	0	165
Office	O	5	1530	87	0	0	0	87	65	0	0	0	65
Building Totals			36461	2189			0	2189	1393			0	1393