


Area Type Averages

Building type:Elementary School. Building size:25K to less than 50K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Restroom	R	1	400	61.87	0.00	0.00	61.87	35.50	0.00	0.00	0.00	35.50	42.62%
Classroom	CR	6	1440	42.33	0.00	0.00	42.33	30.76	0.00	0.00	0.00	30.76	27.33%
Gym	G	1	6000	80.38	0.00	0.00	80.38	51.77	0.00	0.00	0.00	51.77	35.59%
Locker Room	LR	1	480	62.06	0.00	0.00	62.06	21.49	0.00	0.00	0.00	21.49	65.37%
Cafeteria	CF	1	3600	32.89	0.00	0.00	32.89	31.92	0.00	0.00	0.00	31.92	2.95%
Building Average			19120	53.40		0.00	53.40	37.44		0.00	0.00	37.44	29.89%



Hours per Week for each Area Type

Data Logger Detail Building type:Elementary School. Building size:25K to less than 50K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23627	Cafeteria	CF	495.28	495.28	0.00	0.00	0.00	10/07/05 6:44 AM	10/27/05 10:00	96.97	0.00	0.00	0.00	96.97	94.10	0.00	0.00	0.00	94.10
21855	Classroom	CR	506.10	506.10	0.00	0.00	0.00	10/06/05 7:55 PM	10/27/05 10:00	121.00	0.00	0.00	0.00	121.00	105.37	0.00	0.00	0.00	105.37
23269	Classroom	CR	503.00	503.00	0.00	0.00	0.00	10/06/05 11:01	10/27/05 10:00	112.58	0.00	0.00	0.00	112.58	106.65	0.00	0.00	0.00	106.65
20591	Classroom	CR	506.25	506.25	0.00	0.00	0.00	10/06/05 7:46 PM	10/27/05 10:00	108.03	0.00	0.00	0.00	108.03	101.30	0.00	0.00	0.00	101.30
23683	Restroom	R	505.98	505.98	0.00	0.00	0.00	10/06/05 8:02 PM	10/27/05 10:00	186.35	0.00	0.00	0.00	186.35	106.93	0.00	0.00	0.00	106.93
22430	Gym	G	505.82	505.82	0.00	0.00	0.00	10/06/05 8:12 PM	10/27/05 10:00	242.00	0.00	0.00	0.00	242.00	155.87	0.00	0.00	0.00	155.87
23708	Locker Room	LR	504.40	504.40	0.00	0.00	0.00	10/06/05 9:37 PM	10/27/05 10:00	186.33	0.00	0.00	0.00	186.33	64.53	0.00	0.00	0.00	64.53
24013	Classroom	CR	506.02	506.02	0.00	0.00	0.00	10/06/05 8:00 PM	10/27/05 10:00	184.42	0.00	0.00	0.00	184.42	101.07	0.00	0.00	0.00	101.07
23731	Classroom	CR	504.87	504.87	0.00	0.00	0.00	10/06/05 9:09 PM	10/27/05 10:00	169.95	0.00	0.00	0.00	169.95	124.08	0.00	0.00	0.00	124.08
22247	Classroom	CR	501.83	501.83	0.00	0.00	0.00	10/07/05 12:11	10/27/05 10:00	67.43	0.00	0.00	0.00	67.43	16.50	0.00	0.00	0.00	16.50

Normalized Data Logger Detail Building type:Elementary School. Building size:25K to less than 50K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23627	Cafeteria	CF	3600	32.89	0.00	0.00	0.00	32.89	31.92	0.00	0.00	0.00	31.92	2.95%
21855	Classroom	CR	1920	40.17	0.00	0.00	0.00	40.17	34.98	0.00	0.00	0.00	34.98	12.92%
23269	Classroom	CR	960	37.60	0.00	0.00	0.00	37.60	35.62	0.00	0.00	0.00	35.62	5.27%
20591	Classroom	CR	1920	35.85	0.00	0.00	0.00	35.85	33.62	0.00	0.00	0.00	33.62	6.22%
23683	Restroom	R	400	61.87	0.00	0.00	0.00	61.87	35.50	0.00	0.00	0.00	35.50	42.62%
22430	Gym	G	6000	80.38	0.00	0.00	0.00	80.38	51.77	0.00	0.00	0.00	51.77	35.59%
23708	Locker Room	LR	480	62.06	0.00	0.00	0.00	62.06	21.49	0.00	0.00	0.00	21.49	65.37%
24013	Classroom	CR	1920	61.23	0.00	0.00	0.00	61.23	33.55	0.00	0.00	0.00	33.55	45.21%
23731	Classroom	CR	960	56.55	0.00	0.00	0.00	56.55	41.29	0.00	0.00	0.00	41.29	26.98%
22247	Classroom	CR	960	22.57	0.00	0.00	0.00	22.57	5.52	0.00	0.00	0.00	5.52	75.54%

Building Summary Totals Building type:Elementary School. Building size:25K to less than 50K. Shifts:1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	1	400	25	0	0	0	25	14	0	0	0	14
Classroom	CR	6	8640	366	0	0	0	366	266	0	0	0	266
Gym	G	1	6000	482	0	0	0	482	311	0	0	0	311
Locker Room	LR	1	480	30	0	0	0	30	10	0	0	0	10
Cafeteria	CF	1	3600	118	0	0	0	118	115	0	0	0	115
Building Totals			19120	1021			0	1021	716			0	716