


Area Type Averages

Building type:High School. Building size:50K to less than 100K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Classroom	CR	4	3910	67.84	0.00	0.00	0.00	67.84	37.28	0.00	0.00	0.00	37.28	45.05%
Building Average		15640	67.84			0.00	67.84	37.28			0.00	37.28	45.05%	



Hours per Week for each Area Type

Data Logger Detail Building type:High School. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
24311	Classroom	CR	257.28	257.28	0.00	0.00	0.00	9/26/05 11:00 PM	10/07/05 4:16 PM	100.92	0.00	0.00	0.00	100.92	54.48	0.00	0.00	0.00	54.48
21595	Classroom	CR	257.27	257.27	0.00	0.00	0.00	9/26/05 11:00 PM	10/07/05 4:15 PM	102.30	0.00	0.00	0.00	102.30	60.57	0.00	0.00	0.00	60.57
24383	Classroom	CR	257.33	257.33	0.00	0.00	0.00	9/26/05 11:00 PM	10/07/05 4:19 PM	107.35	0.00	0.00	0.00	107.35	56.08	0.00	0.00	0.00	56.08
22237	Classroom	CR	264.02	264.02	0.00	0.00	0.00	9/26/05 11:00 PM	10/07/05 11:00	107.77	0.00	0.00	0.00	107.77	58.77	0.00	0.00	0.00	58.77

Normalized Data Logger Detail Building type:High School. Building size:50K to less than 100K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
24311	Classroom	CR	3910	65.90	0.00	0.00	0.00	65.90	35.58	0.00	0.00	0.00	35.58	46.01%
21595	Classroom	CR	3910	66.80	0.00	0.00	0.00	66.80	39.55	0.00	0.00	0.00	39.55	40.79%
24383	Classroom	CR	3910	70.08	0.00	0.00	0.00	70.08	36.61	0.00	0.00	0.00	36.61	47.76%
22237	Classroom	CR	3910	68.57	0.00	0.00	0.00	68.57	37.39	0.00	0.00	0.00	37.39	45.47%

Building Summary Totals Building type:High School. Building size:50K to less than 100K. Shifts:2

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Classroom	CR	4	15640	1061	0	0	0	1061	583	0	0	0	583
Building Totals			15640	1061	0		0	1061	583	0			583