


Area Type Averages

Building type:Hospital. Building size:100K to less than 250K. Shifts:3

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Restroom	R	4	200	130.80	0.00	0.00	0.00	130.80	38.65	0.00	0.00	0.00	38.65	70.45%
Hallway	H	12	200	121.99	0.00	0.00	0.00	121.99	76.14	0.00	0.00	0.00	76.14	37.59%
Classroom	CR	1	200	18.58	0.00	0.00	0.00	18.58	15.09	0.00	0.00	0.00	15.09	18.78%
Cafeteria	CF	2	200	121.11	0.00	0.00	0.00	121.11	95.63	0.00	0.00	0.00	95.63	21.04%
Patient Room	P	4	200	23.89	0.00	0.00	0.00	23.89	18.31	0.00	0.00	0.00	18.31	23.36%
Waiting Room	WF	2	200	132.03	0.00	0.00	0.00	132.03	120.19	0.00	0.00	0.00	120.19	8.97%
Office	O	3	200	44.10	0.00	0.00	0.00	44.10	38.12	0.00	0.00	0.00	38.12	13.56%
Stairwell	ST	3	200	61.01	0.00	0.00	0.00	61.01	11.79	0.00	0.00	0.00	11.79	80.68%
Whse/Storage	WS	2	200	62.32	0.00	0.00	0.00	62.32	53.01	0.00	0.00	0.00	53.01	14.94%
Operating Rooms	OR	1	200	92.66	0.00	0.00	0.00	92.66	35.83	0.00	0.00	0.00	35.83	61.33%
General Office	GO	2	200	74.65	0.00	0.00	0.00	74.65	72.06	0.00	0.00	0.00	72.06	3.47%
MultiPurpose Rm	MP	1	200	167.99	0.00	0.00	0.00	167.99	81.01	0.00	0.00	0.00	81.01	51.78%
Building Average			7400	93.44			0.00	93.44	56.89			0.00	56.89	39.12%



Data Logger Detail Building type:Hospital. Building size:100K to less than 250K. Shifts:3 Page 1 of 1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
21901	Cafeteria	CF	529.02	529.02	0.00	0.00	0.00	11/09/05 3:57 PM	12/01/05 4:57 PM	363.33	0.00	0.00	0.00	363.33	273.87	0.00	0.00	0.00	273.87
21307	Restroom	R	528.98	528.98	0.00	0.00	0.00	11/09/05 4:02 PM	12/01/05 5:00 PM	432.88	0.00	0.00	0.00	432.88	138.07	0.00	0.00	0.00	138.07
20548	Waiting Room	WF	529.05	529.05	0.00	0.00	0.00	11/09/05 3:50 PM	12/01/05 4:52 PM	529.03	0.00	0.00	0.00	529.03	460.78	0.00	0.00	0.00	460.78
21862	Hallway	H	529.33	529.33	0.00	0.00	0.00	11/09/05 3:30 PM	12/01/05 4:49 PM	290.58	0.00	0.00	0.00	290.58	258.00	0.00	0.00	0.00	258.00
22760	Hallway	H	528.98	528.98	0.00	0.00	0.00	11/09/05 3:47 PM	12/01/05 4:45 PM	528.97	0.00	0.00	0.00	528.97	244.15	0.00	0.00	0.00	244.15
20749	Restroom	R	529.22	529.22	0.00	0.00	0.00	11/09/05 3:34 PM	12/01/05 4:46 PM	529.20	0.00	0.00	0.00	529.20	135.90	0.00	0.00	0.00	135.90
20682	Stock Room	ST	528.95	528.95	0.00	0.00	0.00	11/09/05 3:46 PM	12/01/05 4:42 PM	528.77	0.00	0.00	0.00	528.77	88.10	0.00	0.00	0.00	88.10
23620	Hallway	H	531.13	531.13	0.00	0.00	0.00	11/09/05 3:21 PM	12/01/05 6:28 PM	506.32	0.00	0.00	0.00	506.32	377.52	0.00	0.00	0.00	377.52
20810	Hallway	H	531.52	531.52	0.00	0.00	0.00	11/09/05 3:02 PM	12/01/05 6:32 PM	334.02	0.00	0.00	0.00	334.02	194.93	0.00	0.00	0.00	194.93
23734	General Office	GO	531.40	531.40	0.00	0.00	0.00	11/09/05 2:56 PM	12/01/05 6:19 PM	416.12	0.00	0.00	0.00	416.12	400.45	0.00	0.00	0.00	400.45
20902	Hallway	H	531.52	531.52	0.00	0.00	0.00	11/09/05 2:37 PM	12/01/05 6:07 PM	118.33	0.00	0.00	0.00	118.33	100.87	0.00	0.00	0.00	100.87
24066	Workshop	WS	531.52	531.52	0.00	0.00	0.00	11/09/05 2:43 PM	12/01/05 6:13 PM	121.10	0.00	0.00	0.00	121.10	112.33	0.00	0.00	0.00	112.33
22857	Hallway	H	531.67	531.67	0.00	0.00	0.00	11/09/05 2:19 PM	12/01/05 5:58 PM	531.65	0.00	0.00	0.00	531.65	199.58	0.00	0.00	0.00	199.58
24061	Office	O	531.88	531.88	0.00	0.00	0.00	11/09/05 2:12 PM	12/01/05 6:04 PM	6.47	0.00	0.00	0.00	6.47	5.47	0.00	0.00	0.00	5.47
23536	Hallway	H	531.67	531.67	0.00	0.00	0.00	11/09/05 2:08 PM	12/01/05 5:47 PM	13.50	0.00	0.00	0.00	13.50	12.67	0.00	0.00	0.00	12.67
23386	General Office	GO	531.67	531.67	0.00	0.00	0.00	11/09/05 2:10 PM	12/01/05 5:49 PM	56.17	0.00	0.00	0.00	56.17	55.40	0.00	0.00	0.00	55.40
24053	Hallway	H	531.63	531.63	0.00	0.00	0.00	11/09/05 2:13 PM	12/01/05 5:50 PM	364.33	0.00	0.00	0.00	364.33	339.70	0.00	0.00	0.00	339.70
23866	Office	O	533.63	533.63	0.00	0.00	0.00	11/09/05 3:23 PM	12/01/05 9:00 PM	194.07	0.00	0.00	0.00	194.07	145.37	0.00	0.00	0.00	145.37
21341	Classroom	CR	531.50	531.50	0.00	0.00	0.00	11/09/05 3:05 PM	12/01/05 6:34 PM	58.78	0.00	0.00	0.00	58.78	47.73	0.00	0.00	0.00	47.73
21992	Waiting Room	WF	528.88	528.88	0.00	0.00	0.00	11/09/05 3:45 PM	12/01/05 4:37 PM	302.40	0.00	0.00	0.00	302.40	296.07	0.00	0.00	0.00	296.07
22290	Hallway	H	530.02	530.02	0.00	0.00	0.00	11/09/05 3:55 PM	12/01/05 5:55 PM	530.00	0.00	0.00	0.00	530.00	491.57	0.00	0.00	0.00	491.57
24035	Hallway	H	531.53	531.53	0.00	0.00	0.00	11/09/05 2:25 PM	12/01/05 5:56 PM	345.32	0.00	0.00	0.00	345.32	313.52	0.00	0.00	0.00	313.52
24060	Hallway	H	529.12	529.12	0.00	0.00	0.00	11/09/05 4:09 PM	12/01/05 5:15 PM	529.10	0.00	0.00	0.00	529.10	351.77	0.00	0.00	0.00	351.77
21292	Hallway	H	529.17	529.17	0.00	0.00	0.00	11/09/05 3:59 PM	12/01/05 5:08 PM	529.15	0.00	0.00	0.00	529.15	1.03	0.00	0.00	0.00	1.03
20882	Cafeteria	CF	533.70	533.70	0.00	0.00	0.00	11/09/05 3:19 PM	12/01/05 9:00 PM	402.92	0.00	0.00	0.00	402.92	331.27	0.00	0.00	0.00	331.27
22613	Restroom	R	529.03	529.03	0.00	0.00	0.00	11/09/05 4:04 PM	12/01/05 5:05 PM	498.60	0.00	0.00	0.00	498.60	137.00	0.00	0.00	0.00	137.00
20844	Restroom	R	531.52	531.52	0.00	0.00	0.00	11/09/05 3:04 PM	12/01/05 6:34 PM	187.90	0.00	0.00	0.00	187.90	76.23	0.00	0.00	0.00	76.23
23910	MultiPurpose Rm	MP	529.18	529.18	0.00	0.00	0.00	11/09/05 4:06 PM	12/01/05 5:16 PM	529.17	0.00	0.00	0.00	529.17	255.18	0.00	0.00	0.00	255.18
23758	Patient Room	P	531.52	531.52	0.00	0.00	0.00	11/09/05 2:41 PM	12/01/05 6:11 PM	163.55	0.00	0.00	0.00	163.55	142.68	0.00	0.00	0.00	142.68
23864	Patient Room	P	531.47	531.47	0.00	0.00	0.00	11/09/05 2:47 PM	12/01/05 6:14 PM	12.27	0.00	0.00	0.00	12.27	9.93	0.00	0.00	0.00	9.93
23238	Patient Room	P	531.63	531.63	0.00	0.00	0.00	11/09/05 2:16 PM	12/01/05 5:53 PM	60.30	0.00	0.00	0.00	60.30	45.93	0.00	0.00	0.00	45.93
23697	Patient Room	P	533.15	533.15	0.00	0.00	0.00	11/09/05 3:52 PM	12/01/05 9:00 PM	66.37	0.00	0.00	0.00	66.37	33.27	0.00	0.00	0.00	33.27
20592	Operating Rooms	OR	529.32	529.32	0.00	0.00	0.00	11/09/05 3:31 PM	12/01/05 4:49 PM	291.93	0.00	0.00	0.00	291.93	112.90	0.00	0.00	0.00	112.90
20825	Stock Room	ST	529.08	529.08	0.00	0.00	0.00	11/09/05 3:53 PM	12/01/05 4:57 PM	23.37	0.00	0.00	0.00	23.37	14.53	0.00	0.00	0.00	14.53
23581	Stock Room	ST	531.63	531.63	0.00	0.00	0.00	11/09/05 2:21 PM	12/01/05 5:58 PM	24.30	0.00	0.00	0.00	24.30	8.77	0.00	0.00	0.00	8.77
22548	Workshop	WS	531.48	531.48	0.00	0.00	0.00	11/09/05 2:59 PM	12/01/05 6:27 PM	273.20	0.00	0.00	0.00	273.20	223.03	0.00	0.00	0.00	223.03
23944	Office	O	531.20	531.20	0.00	0.00	0.00	11/09/05 3:25 PM	12/01/05 6:36 PM	218.63	0.00	0.00	0.00	218.63	211.47	0.00	0.00	0.00	211.47

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
21901	Cafeteria	CF	200	115.38	0.00	0.00	0.00	115.38	86.97	0.00	0.00	0.00	86.97	24.62%
21307	Restroom	R	200	137.48	0.00	0.00	0.00	137.48	43.85	0.00	0.00	0.00	43.85	68.10%
20548	Waiting Room	WF	200	167.99	0.00	0.00	0.00	167.99	146.32	0.00	0.00	0.00	146.32	12.90%
21862	Hallway	H	200	92.23	0.00	0.00	0.00	92.23	81.88	0.00	0.00	0.00	81.88	11.22%
22760	Hallway	H	200	167.99	0.00	0.00	0.00	167.99	77.54	0.00	0.00	0.00	77.54	53.84%
20749	Restroom	R	200	167.99	0.00	0.00	0.00	167.99	43.14	0.00	0.00	0.00	43.14	74.32%
20682	Stock Room	ST	200	167.94	0.00	0.00	0.00	167.94	27.98	0.00	0.00	0.00	27.98	83.34%
23620	Hallway	H	200	160.15	0.00	0.00	0.00	160.15	119.41	0.00	0.00	0.00	119.41	25.44%
20810	Hallway	H	200	105.57	0.00	0.00	0.00	105.57	61.61	0.00	0.00	0.00	61.61	41.64%
23734	General Office	GO	200	131.55	0.00	0.00	0.00	131.55	126.60	0.00	0.00	0.00	126.60	3.76%
20902	Hallway	H	200	37.40	0.00	0.00	0.00	37.40	31.88	0.00	0.00	0.00	31.88	14.76%
24066	Workshop	WS	200	38.28	0.00	0.00	0.00	38.28	35.51	0.00	0.00	0.00	35.51	7.24%
22857	Hallway	H	200	167.99	0.00	0.00	0.00	167.99	63.07	0.00	0.00	0.00	63.07	62.46%
24061	Office	O	200	2.04	0.00	0.00	0.00	2.04	1.73	0.00	0.00	0.00	1.73	15.20%
23536	Hallway	H	200	4.27	0.00	0.00	0.00	4.27	4.00	0.00	0.00	0.00	4.00	6.32%
23386	General Office	GO	200	17.75	0.00	0.00	0.00	17.75	17.51	0.00	0.00	0.00	17.51	1.35%
24053	Hallway	H	200	115.13	0.00	0.00	0.00	115.13	107.35	0.00	0.00	0.00	107.35	6.76%
23866	Office	O	200	61.10	0.00	0.00	0.00	61.10	45.76	0.00	0.00	0.00	45.76	25.11%
21341	Classroom	CR	200	18.58	0.00	0.00	0.00	18.58	15.09	0.00	0.00	0.00	15.09	18.78%
21992	Waiting Room	WF	200	96.06	0.00	0.00	0.00	96.06	94.05	0.00	0.00	0.00	94.05	2.09%
22290	Hallway	H	200	167.99	0.00	0.00	0.00	167.99	155.81	0.00	0.00	0.00	155.81	7.25%
24035	Hallway	H	200	109.14	0.00	0.00	0.00	109.14	99.09	0.00	0.00	0.00	99.09	9.21%
24060	Hallway	H	200	167.99	0.00	0.00	0.00	167.99	111.69	0.00	0.00	0.00	111.69	33.51%
21292	Hallway	H	200	167.99	0.00	0.00	0.00	167.99	0.33	0.00	0.00	0.00	0.33	99.80%
20882	Cafeteria	CF	200	126.83	0.00	0.00	0.00	126.83	104.28	0.00	0.00	0.00	104.28	17.78%
22613	Restroom	R	200	158.34	0.00	0.00	0.00	158.34	43.51	0.00	0.00	0.00	43.51	72.52%
20844	Restroom	R	200	59.39	0.00	0.00	0.00	59.39	24.10	0.00	0.00	0.00	24.10	59.42%
23910	MultiPurpose	MP	200	167.99	0.00	0.00	0.00	167.99	81.01	0.00	0.00	0.00	81.01	51.78%
23758	Patient Room	P	200	51.69	0.00	0.00	0.00	51.69	45.10	0.00	0.00	0.00	45.10	12.75%
23864	Patient Room	P	200	3.88	0.00	0.00	0.00	3.88	3.14	0.00	0.00	0.00	3.14	19.07%
23238	Patient Room	P	200	19.06	0.00	0.00	0.00	19.06	14.52	0.00	0.00	0.00	14.52	23.82%
23697	Patient Room	P	200	20.91	0.00	0.00	0.00	20.91	10.48	0.00	0.00	0.00	10.48	49.88%
20592	Operating	OR	200	92.66	0.00	0.00	0.00	92.66	35.83	0.00	0.00	0.00	35.83	61.33%
20825	Stock Room	ST	200	7.42	0.00	0.00	0.00	7.42	4.61	0.00	0.00	0.00	4.61	37.87%
23581	Stock Room	ST	200	7.68	0.00	0.00	0.00	7.68	2.77	0.00	0.00	0.00	2.77	63.93%
22548	Workshop	WS	200	86.36	0.00	0.00	0.00	86.36	70.50	0.00	0.00	0.00	70.50	18.36%
23944	Office	O	200	69.15	0.00	0.00	0.00	69.15	66.88	0.00	0.00	0.00	66.88	3.28%

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	4	800	105	0	0	0	105	31	0	0	0	31
Hallway	H	12	2400	293	0	0	0	293	183	0	0	0	183
Classroom	CR	1	200	4	0	0	0	4	3	0	0	0	3
Cafeteria	CF	2	400	48	0	0	0	48	38	0	0	0	38
Patient Room	P	4	800	19	0	0	0	19	15	0	0	0	15
Waiting Room	WF	2	400	53	0	0	0	53	48	0	0	0	48
Office	O	3	600	26	0	0	0	26	23	0	0	0	23
Stairwell	ST	3	600	37	0	0	0	37	7	0	0	0	7
Whse/Storage	WS	2	400	25	0	0	0	25	21	0	0	0	21
Operating Rooms	OR	1	200	19	0	0	0	19	7	0	0	0	7
General Office	GO	2	400	30	0	0	0	30	29	0	0	0	29
MultiPurpose Rm	MP	1	200	34	0	0	0	34	16	0	0	0	16
Building Totals			7400	691	0			691	421	0			421