


# Area Type Averages

Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Storage	S	2	100	19.50	0.00	0.00	0.00	19.50	4.58	0.00	0.00	0.00	4.58	76.51%
Hallway	H	1	100	168.00	0.00	0.00	0.00	168.00	52.48	0.00	0.00	0.00	52.48	68.76%
Exam Room	EX	2	100	30.63	0.00	0.00	0.00	30.63	22.32	0.00	0.00	0.00	22.32	27.13%
Office	O	2	100	19.90	0.00	0.00	0.00	19.90	17.88	0.00	0.00	0.00	17.88	10.15%
Conference	CN	1	100	0.04	0.00	0.00	0.00	0.04	0.04	0.00	0.00	0.00	0.04	0.00%
MultiPurpose Rm	MP	1	100	44.33	0.00	0.00	0.00	44.33	35.79	0.00	0.00	0.00	35.79	19.26%
Building Average			900	39.16			0.00	39.16	19.76			0.00	19.76	49.54%



Hours per Week for each Area Type

## Data Logger Detail Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20111	MultiPurpose Rm	MP	1248.47	1248.47	0.00	0.00	0.00	8/19/05 2:36 PM	10/10/05 3:03 PM	329.42	0.00	0.00	0.00	329.42	265.98	0.00	0.00	0.00	265.98
20201	Conference	CN	2146.88	2146.88	0.00	0.00	0.00	8/25/05 1:08 PM	11/23/05 12:00	0.57	0.00	0.00	0.00	0.57	0.57	0.00	0.00	0.00	0.57
20304	Office	O	2289.03	2289.03	0.00	0.00	0.00	8/19/05 2:59 PM	11/23/05 12:00	182.68	0.00	0.00	0.00	182.68	167.42	0.00	0.00	0.00	167.42
20209	Exam Room	EX	2288.82	2288.82	0.00	0.00	0.00	8/19/05 3:12 PM	11/23/05 12:00	512.83	0.00	0.00	0.00	512.83	372.13	0.00	0.00	0.00	372.13
20441	Exam Room	EX	2288.72	2288.72	0.00	0.00	0.00	8/19/05 3:18 PM	11/23/05 12:00	321.73	0.00	0.00	0.00	321.73	235.97	0.00	0.00	0.00	235.97
20451	Storage	S	2288.32	2288.32	0.00	0.00	0.00	8/19/05 3:42 PM	11/23/05 12:00	419.62	0.00	0.00	0.00	419.62	113.17	0.00	0.00	0.00	113.17
20171	Hallway	H	1677.35	1677.35	0.00	0.00	0.00	8/19/05 2:28 PM	10/28/05 11:48	1677.33	0.00	0.00	0.00	1677.33	524.00	0.00	0.00	0.00	524.00
23788	Office	O	2288.75	2288.75	0.00	0.00	0.00	8/19/05 3:16 PM	11/23/05 12:00	359.57	0.00	0.00	0.00	359.57	319.63	0.00	0.00	0.00	319.63
20466	Storage	S	2289.40	2289.40	0.00	0.00	0.00	8/19/05 2:37 PM	11/23/05 12:00	111.53	0.00	0.00	0.00	111.53	11.40	0.00	0.00	0.00	11.40

## Normalized Data Logger Detail Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20111	MultiPurpose	MP	100	44.33	0.00	0.00	0.00	44.33	35.79	0.00	0.00	0.00	35.79	19.26%
20201	Conference	CN	100	0.04	0.00	0.00	0.00	0.04	0.04	0.00	0.00	0.00	0.04	0.00%
20304	Office	O	100	13.41	0.00	0.00	0.00	13.41	12.29	0.00	0.00	0.00	12.29	8.35%
20209	Exam Room	EX	100	37.64	0.00	0.00	0.00	37.64	27.31	0.00	0.00	0.00	27.31	27.44%
20441	Exam Room	EX	100	23.62	0.00	0.00	0.00	23.62	17.32	0.00	0.00	0.00	17.32	26.67%
20451	Storage	S	100	30.81	0.00	0.00	0.00	30.81	8.31	0.00	0.00	0.00	8.31	73.03%
20171	Hallway	H	100	168.00	0.00	0.00	0.00	168.00	52.48	0.00	0.00	0.00	52.48	68.76%
23788	Office	O	100	26.39	0.00	0.00	0.00	26.39	23.46	0.00	0.00	0.00	23.46	11.10%
20466	Storage	S	100	8.18	0.00	0.00	0.00	8.18	0.84	0.00	0.00	0.00	0.84	89.73%

## Building Summary Totals Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type	Qty	Watts		Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Storage	S	2	200	4	0	0	0	4	1	0	0	0	1
Hallway	H	1	100	17	0	0	0	17	5	0	0	0	5
Exam Room	EX	2	200	6	0	0	0	6	4	0	0	0	4
Office	O	2	200	4	0	0	0	4	4	0	0	0	4
Conference	CN	1	100	0	0	0	0	0	0	0	0	0	0
MultiPurpose Rm	MP	1	100	4	0	0	0	4	4	0	0	0	4
Building Totals			900	35			0	35	18			0	18