


Area Type Averages

Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Restroom	R	1	100	168.00	0.00	0.00	0.00	168.00	41.75	0.00	0.00	0.00	41.75	75.15%
Hallway	H	1	100	95.79	0.00	0.00	0.00	95.79	67.88	0.00	0.00	0.00	67.88	29.14%
Classroom	CR	1	100	34.35	0.00	0.00	0.00	34.35	24.42	0.00	0.00	0.00	24.42	28.91%
Office	O	2	100	34.27	0.00	0.00	0.00	34.27	20.53	0.00	0.00	0.00	20.53	40.09%
Conference	CN	1	100	23.93	0.00	0.00	0.00	23.93	15.04	0.00	0.00	0.00	15.04	37.15%
MultiPurpose Rm	MP	1	100	35.66	0.00	0.00	0.00	35.66	19.91	0.00	0.00	0.00	19.91	44.17%
Building Average			700	60.90			0.00	60.90	30.01			0.00	30.01	50.72%



Hours per Week for each Area Type

Data Logger Detail Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20570	Conference	CN	2292.95	2292.95	0.00	0.00	0.00	8/19/05 11:04 AM	11/23/05 12:00	326.57	0.00	0.00	0.00	326.57	205.30	0.00	0.00	0.00	205.30
23913	Hallway	H	2293.98	2293.98	0.00	0.00	0.00	8/19/05 10:02 AM	11/23/05 12:00	1308.03	0.00	0.00	0.00	1308.03	926.93	0.00	0.00	0.00	926.93
24161	Office	O	2292.98	2292.98	0.00	0.00	0.00	8/19/05 11:02 AM	11/23/05 12:00	456.47	0.00	0.00	0.00	456.47	305.73	0.00	0.00	0.00	305.73
23243	Office	O	2293.00	2293.00	0.00	0.00	0.00	8/19/05 11:01 AM	11/23/05 12:00	478.88	0.00	0.00	0.00	478.88	254.72	0.00	0.00	0.00	254.72
23130	Classroom	CR	2294.02	2294.02	0.00	0.00	0.00	8/19/05 10:00 AM	11/23/05 12:00	469.07	0.00	0.00	0.00	469.07	333.50	0.00	0.00	0.00	333.50
21729	MultiPurpose Rm	MP	2293.52	2293.52	0.00	0.00	0.00	8/19/05 10:30 AM	11/23/05 12:00	486.82	0.00	0.00	0.00	486.82	271.77	0.00	0.00	0.00	271.77
24054	Restroom	R	2293.25	2293.25	0.00	0.00	0.00	8/19/05 10:46 AM	11/23/05 12:00	2293.25	0.00	0.00	0.00	2293.25	563.83	0.00	0.00	0.00	563.83

Normalized Data Logger Detail Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20570	Conference	CN	100	23.93	0.00	0.00	0.00	23.93	15.04	0.00	0.00	0.00	15.04	37.15%
23913	Hallway	H	100	95.79	0.00	0.00	0.00	95.79	67.88	0.00	0.00	0.00	67.88	29.14%
24161	Office	O	100	33.44	0.00	0.00	0.00	33.44	22.40	0.00	0.00	0.00	22.40	33.01%
23243	Office	O	100	35.09	0.00	0.00	0.00	35.09	18.66	0.00	0.00	0.00	18.66	46.82%
23130	Classroom	CR	100	34.35	0.00	0.00	0.00	34.35	24.42	0.00	0.00	0.00	24.42	28.91%
21729	MultiPurpose	MP	100	35.66	0.00	0.00	0.00	35.66	19.91	0.00	0.00	0.00	19.91	44.17%
24054	Restroom	R	100	168.00	0.00	0.00	0.00	168.00	41.75	0.00	0.00	0.00	41.75	75.15%

Building Summary Totals Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

Building Summary Totals				Lights On KWHR					Occupied KWHR					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Restroom		R	1	100	17	0	0	0	17	4	0	0	0	4
Hallway		H	1	100	10	0	0	0	10	7	0	0	0	7
Classroom		CR	1	100	3	0	0	0	3	2	0	0	0	2
Office		O	2	200	7	0	0	0	7	4	0	0	0	4
Conference		CN	1	100	2	0	0	0	2	2	0	0	0	2
MultiPurpose Rm		MP	1	100	4	0	0	0	4	2	0	0	0	2
Building Totals				700	43			0	43	21			0	21