


# Area Type Averages

Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav		
Storage	S	1	100	56.25	0.00	0.00	0.00	56.25	40.39	0.00	0.00	0.00	40.39	28.20%	
Office	O	5	100	67.77	0.00	0.00	0.00	67.77	32.94	0.00	0.00	0.00	32.94	51.39%	
Conference	CN	1	100	39.19	0.00	0.00	0.00	39.19	19.12	0.00	0.00	0.00	19.12	51.21%	
Building Average		700	62.04				0.00	62.04	32.03				0.00	32.03	48.37%



**Hours per Week for each Area Type**

## Data Logger Detail Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20193	Office	O	2289.27	2289.27	0.00	0.00	0.00	8/19/05 2:45 PM	11/23/05 12:00	534.15	0.00	0.00	0.00	534.15	171.27	0.00	0.00	0.00	171.27
20399	Conference	CN	2289.25	2289.25	0.00	0.00	0.00	8/19/05 2:46 PM	11/23/05 12:00	534.05	0.00	0.00	0.00	534.05	260.50	0.00	0.00	0.00	260.50
20145	Office	O	2288.52	2288.52	0.00	0.00	0.00	8/19/05 3:30 PM	11/23/05 12:00	620.17	0.00	0.00	0.00	620.17	492.47	0.00	0.00	0.00	492.47
20084	Office	O	1992.28	1992.28	0.00	0.00	0.00	8/19/05 2:47 PM	11/10/05 3:03 PM	579.73	0.00	0.00	0.00	579.73	476.13	0.00	0.00	0.00	476.13
20270	Office	O	2289.55	2289.55	0.00	0.00	0.00	8/19/05 2:28 PM	11/23/05 12:00	514.33	0.00	0.00	0.00	514.33	236.83	0.00	0.00	0.00	236.83
20281	Storage	S	980.23	980.23	0.00	0.00	0.00	8/19/05 3:08 PM	9/29/05 11:21 AM	328.20	0.00	0.00	0.00	328.20	235.67	0.00	0.00	0.00	235.67
20036	Office	O	5.75	5.75	0.00	0.00	0.00	8/19/05 3:07 PM	8/19/05 8:51 PM	5.73	0.00	0.00	0.00	5.73	2.00	0.00	0.00	0.00	2.00

## Normalized Data Logger Detail Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20193	Office	O	100	39.20	0.00	0.00	0.00	39.20	12.57	0.00	0.00	0.00	12.57	67.93%
20399	Conference	CN	100	39.19	0.00	0.00	0.00	39.19	19.12	0.00	0.00	0.00	19.12	51.21%
20145	Office	O	100	45.53	0.00	0.00	0.00	45.53	36.15	0.00	0.00	0.00	36.15	20.60%
20084	Office	O	100	48.89	0.00	0.00	0.00	48.89	40.15	0.00	0.00	0.00	40.15	17.88%
20270	Office	O	100	37.74	0.00	0.00	0.00	37.74	17.38	0.00	0.00	0.00	17.38	53.95%
20281	Storage	S	100	56.25	0.00	0.00	0.00	56.25	40.39	0.00	0.00	0.00	40.39	28.20%
20036	Office	O	100	167.51	0.00	0.00	0.00	167.51	58.43	0.00	0.00	0.00	58.43	65.12%

## Building Summary Totals Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Storage		S	1	100	6	0	0	6	4	0	0	0	4
Office		O	5	500	34	0	0	34	16	0	0	0	16
Conference		CN	1	100	4	0	0	4	2	0	0	0	2
Building Totals				700	43		0	43	22			0	22