


Area Type Averages

Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts		Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Meeting Rooms	M	2	100	124.00	0.00	0.00	0.00	124.00	59.11	0.00	0.00	0.00	59.11	52.33%
Restroom	R	1	100	166.70	0.00	0.00	0.00	166.70	59.31	0.00	0.00	0.00	59.31	64.42%
Storage	S	4	100	100.18	0.00	0.00	0.00	100.18	23.73	0.00	0.00	0.00	23.73	76.31%
Hallway	H	1	100	168.00	0.00	0.00	0.00	168.00	40.99	0.00	0.00	0.00	40.99	75.60%
Locker Room	LR	2	100	168.00	0.00	0.00	0.00	168.00	75.48	0.00	0.00	0.00	75.48	55.07%
Copy Rm	C	1	100	168.00	0.00	0.00	0.00	168.00	73.61	0.00	0.00	0.00	73.61	56.18%
Cafeteria	CF	1	100	67.99	0.00	0.00	0.00	67.99	22.71	0.00	0.00	0.00	22.71	66.60%
Office	O	4	100	83.00	0.00	0.00	0.00	83.00	61.18	0.00	0.00	0.00	61.18	26.29%
Conference	CN	1	100	26.45	0.00	0.00	0.00	26.45	13.82	0.00	0.00	0.00	13.82	47.75%
Building Average			1700	112.58			0.00	112.58	48.19			0.00	48.19	57.19%



Hours per Week for each Area Type

Data Logger Detail Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3 Page 1 of 1

All Loggers Listed			Hours Installed							Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23787	Locker Room	LR	2342.85	2342.85	0.00	0.00	0.00	8/17/05 9:10 AM	11/23/05 12:00	2342.85	0.00	0.00	0.00	2342.85	813.57	0.00	0.00	0.00	813.57
22089	Storage	S	2290.70	2290.70	0.00	0.00	0.00	8/19/05 1:19 PM	11/23/05 12:00	2185.40	0.00	0.00	0.00	2185.40	591.60	0.00	0.00	0.00	591.60
24150	Hallway	H	2338.18	2338.18	0.00	0.00	0.00	8/17/05 1:50 PM	11/23/05 12:00	2338.18	0.00	0.00	0.00	2338.18	570.47	0.00	0.00	0.00	570.47
24087	Storage	S	2338.33	2338.33	0.00	0.00	0.00	8/17/05 1:41 PM	11/23/05 12:00	465.83	0.00	0.00	0.00	465.83	142.83	0.00	0.00	0.00	142.83
23978	Office	O	2337.13	2337.13	0.00	0.00	0.00	8/17/05 2:53 PM	11/23/05 12:00	645.98	0.00	0.00	0.00	645.98	542.72	0.00	0.00	0.00	542.72
24063	Conference	CN	2335.92	2335.92	0.00	0.00	0.00	8/17/05 4:06 PM	11/23/05 12:00	367.83	0.00	0.00	0.00	367.83	192.20	0.00	0.00	0.00	192.20
23955	Cafeteria	CF	2341.73	2341.73	0.00	0.00	0.00	8/17/05 10:17 AM	11/23/05 12:00	947.68	0.00	0.00	0.00	947.68	316.52	0.00	0.00	0.00	316.52
22952	Copy Rm	C	2141.20	2141.20	0.00	0.00	0.00	8/19/05 9:46 AM	11/16/05 2:57 PM	2141.18	0.00	0.00	0.00	2141.18	938.12	0.00	0.00	0.00	938.12
24323	Restroom	R	2342.70	2342.70	0.00	0.00	0.00	8/17/05 9:19 AM	11/23/05 12:00	2324.57	0.00	0.00	0.00	2324.57	827.12	0.00	0.00	0.00	827.12
23934	Locker Room	LR	1822.22	1822.22	0.00	0.00	0.00	8/17/05 12:05 PM	11/01/05 10:17	1822.20	0.00	0.00	0.00	1822.20	1004.47	0.00	0.00	0.00	1004.47
23960	Office	O	1206.23	1206.23	0.00	0.00	0.00	8/19/05 12:30 PM	10/08/05 6:43 PM	1206.18	0.00	0.00	0.00	1206.18	934.53	0.00	0.00	0.00	934.53
24285	Office	O	2341.93	2341.93	0.00	0.00	0.00	8/17/05 10:05 AM	11/23/05 12:00	745.60	0.00	0.00	0.00	745.60	745.60	0.00	0.00	0.00	745.60
22608	Meeting Rooms	M	1995.82	1995.82	0.00	0.00	0.00	8/18/05 9:49 AM	11/09/05 1:37 PM	1870.70	0.00	0.00	0.00	1870.70	796.83	0.00	0.00	0.00	796.83
23983	Office	O	2317.85	2317.85	0.00	0.00	0.00	8/18/05 10:10 AM	11/23/05 12:00	883.95	0.00	0.00	0.00	883.95	304.43	0.00	0.00	0.00	304.43
24695	Storage	S	2290.68	2290.68	0.00	0.00	0.00	8/19/05 1:20 PM	11/23/05 12:00	2019.37	0.00	0.00	0.00	2019.37	490.97	0.00	0.00	0.00	490.97
24160	Meeting Rooms	M	2307.65	2307.65	0.00	0.00	0.00	8/18/05 8:22 PM	11/23/05 12:00	1243.40	0.00	0.00	0.00	1243.40	702.60	0.00	0.00	0.00	702.60
23869	Storage	S	2291.47	2291.47	0.00	0.00	0.00	8/19/05 12:33 PM	11/23/05 12:00	802.85	0.00	0.00	0.00	802.85	71.62	0.00	0.00	0.00	71.62

Normalized Data Logger Detail Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3 Page 1 of 1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23787	Locker Room	LR	100	168.00	0.00	0.00	0.00	168.00	58.34	0.00	0.00	0.00	58.34	65.27%
22089	Storage	S	100	160.28	0.00	0.00	0.00	160.28	43.39	0.00	0.00	0.00	43.39	72.93%
24150	Hallway	H	100	168.00	0.00	0.00	0.00	168.00	40.99	0.00	0.00	0.00	40.99	75.60%
24087	Storage	S	100	33.47	0.00	0.00	0.00	33.47	10.26	0.00	0.00	0.00	10.26	69.35%
23978	Office	O	100	46.44	0.00	0.00	0.00	46.44	39.01	0.00	0.00	0.00	39.01	16.00%
24063	Conference	CN	100	26.45	0.00	0.00	0.00	26.45	13.82	0.00	0.00	0.00	13.82	47.75%
23955	Cafeteria	CF	100	67.99	0.00	0.00	0.00	67.99	22.71	0.00	0.00	0.00	22.71	66.60%
22952	Copy Rm	C	100	168.00	0.00	0.00	0.00	168.00	73.61	0.00	0.00	0.00	73.61	56.18%
24323	Restroom	R	100	166.70	0.00	0.00	0.00	166.70	59.31	0.00	0.00	0.00	59.31	64.42%
23934	Locker Room	LR	100	168.00	0.00	0.00	0.00	168.00	92.61	0.00	0.00	0.00	92.61	44.88%
23960	Office	O	100	167.99	0.00	0.00	0.00	167.99	130.16	0.00	0.00	0.00	130.16	22.52%
24285	Office	O	100	53.49	0.00	0.00	0.00	53.49	53.49	0.00	0.00	0.00	53.49	0.00%
22608	Meeting Rooms	M	100	157.47	0.00	0.00	0.00	157.47	67.07	0.00	0.00	0.00	67.07	57.41%
23983	Office	O	100	64.07	0.00	0.00	0.00	64.07	22.07	0.00	0.00	0.00	22.07	65.55%
24695	Storage	S	100	148.10	0.00	0.00	0.00	148.10	36.01	0.00	0.00	0.00	36.01	75.69%
24160	Meeting Rooms	M	100	90.52	0.00	0.00	0.00	90.52	51.15	0.00	0.00	0.00	51.15	43.49%
23869	Storage	S	100	58.86	0.00	0.00	0.00	58.86	5.25	0.00	0.00	0.00	5.25	91.08%

Building Summary Totals Building type:Hospital. Building size:500K to less than 1,000K. Shifts:3 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Meeting Rooms	M	2	200	25	0	0	0	25	12	0	0	0	12
Restroom	R	1	100	17	0	0	0	17	6	0	0	0	6
Storage	S	4	400	40	0	0	0	40	9	0	0	0	9
Hallway	H	1	100	17	0	0	0	17	4	0	0	0	4
Locker Room	LR	2	200	34	0	0	0	34	15	0	0	0	15
Copy Rm	C	1	100	17	0	0	0	17	7	0	0	0	7
Cafeteria	CF	1	100	7	0	0	0	7	2	0	0	0	2
Office	O	4	400	33	0	0	0	33	24	0	0	0	24
Conference	CN	1	100	3	0	0	0	3	1	0	0	0	1
Building Totals			1700	191			0	191	82			0	82