


# Area Type Averages

Building type:Hospital. Building size:50K to less than 100K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts		Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Restroom	R	4	141	63.56	0.00	0.00	0.00	63.56	27.34	0.00	0.00	0.00	27.34	56.99%
Storage	S	4	87	41.75	0.00	0.00	0.00	41.75	21.89	0.00	0.00	0.00	21.89	47.57%
Hallway	H	3	928	42.88	0.00	0.00	0.00	42.88	36.58	0.00	0.00	0.00	36.58	14.69%
Mechanical Room /	MR	3	297	43.30	0.00	0.00	0.00	43.30	3.32	0.00	0.00	0.00	3.32	92.33%
Classroom	CR	2	944	41.87	0.00	0.00	0.00	41.87	24.24	0.00	0.00	0.00	24.24	42.11%
Kitchen	K	6	618	43.33	0.00	0.00	0.00	43.33	32.08	0.00	0.00	0.00	32.08	25.96%
Cafeteria	CF	1	464	168.00	0.00	0.00	0.00	168.00	112.28	0.00	0.00	0.00	112.28	33.17%
Dorm Room	DR	1	64	0.99	0.00	0.00	0.00	0.99	0.92	0.00	0.00	0.00	0.92	7.07%
Open Bay	OB	3	2475	13.92	0.00	0.00	0.00	13.92	10.80	0.00	0.00	0.00	10.80	22.41%
Office	O	4	248	58.38	0.00	0.00	0.00	58.38	25.39	0.00	0.00	0.00	25.39	56.51%
Conference	CN	6	653	15.40	0.00	0.00	0.00	15.40	12.12	0.00	0.00	0.00	12.12	21.30%
Machine Shop	MS	2	2368	16.15	0.00	0.00	0.00	16.15	8.61	0.00	0.00	0.00	8.61	46.69%
MultiPurpose Rm	MP	1	1024	43.79	0.00	0.00	0.00	43.79	38.51	0.00	0.00	0.00	38.51	12.06%
Building Average			28806	30.17			0.00	30.17	20.06			0.00	20.06	33.51%



Hours per Week for each Area Type

Data Logger Detail Building type:Hospital. Building size:50K to less than 100K. Shifts:3 Page 1 of 1

All Loggers Listed			Hours Installed					Installed		Removed		Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total		
24199	Mechanical Room / Storage	MR	312.37	312.37	0.00	0.00	0.00	9/29/05 3:27 PM	10/12/05 3:48 PM	108.57	0.00	0.00	0.00	108.57	3.70	0.00	0.00	0.00	3.70		
23495	Conference	CN	291.00	291.00	0.00	0.00	0.00	9/30/05 12:20 PM	10/12/05 3:19 PM	0.30	0.00	0.00	0.00	0.30	0.30	0.00	0.00	0.00	0.30		
22742	Restroom	R	317.87	317.87	0.00	0.00	0.00	9/29/05 9:27 AM	10/12/05 3:18 PM	9.50	0.00	0.00	0.00	9.50	8.13	0.00	0.00	0.00	8.13		
22214	Office	O	317.95	317.95	0.00	0.00	0.00	9/29/05 9:22 AM	10/12/05 3:18 PM	20.92	0.00	0.00	0.00	20.92	18.72	0.00	0.00	0.00	18.72		
22142	Office	O	319.28	319.28	0.00	0.00	0.00	9/29/05 7:51 AM	10/12/05 3:07 PM	319.23	0.00	0.00	0.00	319.23	96.08	0.00	0.00	0.00	96.08		
22583	Hallway	H	319.05	319.05	0.00	0.00	0.00	9/29/05 8:10 AM	10/12/05 3:12 PM	47.58	0.00	0.00	0.00	47.58	41.93	0.00	0.00	0.00	41.93		
20637	Conference	CN	319.07	319.07	0.00	0.00	0.00	9/29/05 8:08 AM	10/12/05 3:11 PM	9.65	0.00	0.00	0.00	9.65	7.05	0.00	0.00	0.00	7.05		
20651	Office	O	319.25	319.25	0.00	0.00	0.00	9/29/05 7:55 AM	10/12/05 3:09 PM	38.77	0.00	0.00	0.00	38.77	24.37	0.00	0.00	0.00	24.37		
21562	Restroom	R	319.10	319.10	0.00	0.00	0.00	9/29/05 8:06 AM	10/12/05 3:11 PM	129.03	0.00	0.00	0.00	129.03	29.13	0.00	0.00	0.00	29.13		
21336	Kitchen	K	303.83	303.83	0.00	0.00	0.00	9/30/05 6:11 AM	10/12/05 10:00	0.33	0.00	0.00	0.00	0.33	0.33	0.00	0.00	0.00	0.33		
23605	Classroom	CR	323.93	323.93	0.00	0.00	0.00	9/29/05 10:05 AM	10/12/05 10:00	116.97	0.00	0.00	0.00	116.97	80.73	0.00	0.00	0.00	80.73		
21122	Classroom	CR	323.85	323.85	0.00	0.00	0.00	9/29/05 10:10 AM	10/12/05 10:00	44.48	0.00	0.00	0.00	44.48	12.75	0.00	0.00	0.00	12.75		
24196	Storage	S	312.32	312.32	0.00	0.00	0.00	9/29/05 3:43 PM	10/12/05 4:01 PM	35.63	0.00	0.00	0.00	35.63	0.83	0.00	0.00	0.00	0.83		
24136	Kitchen	K	258.65	258.65	0.00	0.00	0.00	10/01/05 9:45 PM	10/12/05 4:23 PM	0.53	0.00	0.00	0.00	0.53	0.53	0.00	0.00	0.00	0.53		
24332	Hallway	H	205.90	205.90	0.00	0.00	0.00	10/04/05 2:47 AM	10/12/05 4:40 PM	0.40	0.00	0.00	0.00	0.40	0.27	0.00	0.00	0.00	0.27		
24135	Conference	CN	315.02	315.02	0.00	0.00	0.00	9/29/05 1:43 PM	10/12/05 4:43 PM	59.30	0.00	0.00	0.00	59.30	44.10	0.00	0.00	0.00	44.10		
23931	Conference	CN	315.00	315.00	0.00	0.00	0.00	9/29/05 1:46 PM	10/12/05 4:45 PM	58.80	0.00	0.00	0.00	58.80	54.13	0.00	0.00	0.00	54.13		
23760	Office	O	315.08	315.08	0.00	0.00	0.00	9/29/05 1:38 PM	10/12/05 4:42 PM	63.97	0.00	0.00	0.00	63.97	53.03	0.00	0.00	0.00	53.03		
24678	Conference	CN	314.50	314.50	0.00	0.00	0.00	9/29/05 1:18 PM	10/12/05 3:47 PM	21.40	0.00	0.00	0.00	21.40	18.67	0.00	0.00	0.00	18.67		
24223	Mechanical Room / Storage	MR	312.48	312.48	0.00	0.00	0.00	9/29/05 3:37 PM	10/12/05 4:05 PM	6.60	0.00	0.00	0.00	6.60	2.50	0.00	0.00	0.00	2.50		
24261	Storage	S	312.40	312.40	0.00	0.00	0.00	9/29/05 3:41 PM	10/12/05 4:04 PM	42.77	0.00	0.00	0.00	42.77	6.07	0.00	0.00	0.00	6.07		
21872	MultiPurpose Rm	MP	317.92	317.92	0.00	0.00	0.00	9/29/05 9:43 AM	10/12/05 3:37 PM	82.87	0.00	0.00	0.00	82.87	72.87	0.00	0.00	0.00	72.87		
23017	Open Bay	OB	218.87	218.87	0.00	0.00	0.00	10/03/05 12:46	10/12/05 3:37 PM	6.37	0.00	0.00	0.00	6.37	3.87	0.00	0.00	0.00	3.87		
21087	Open Bay	OB	318.02	318.02	0.00	0.00	0.00	9/29/05 9:34 AM	10/12/05 3:34 PM	64.37	0.00	0.00	0.00	64.37	50.37	0.00	0.00	0.00	50.37		
21286	Open Bay	OB	298.45	298.45	0.00	0.00	0.00	9/30/05 5:09 AM	10/12/05 3:35 PM	5.10	0.00	0.00	0.00	5.10	5.00	0.00	0.00	0.00	5.00		
23066	Conference	CN	319.07	319.07	0.00	0.00	0.00	9/29/05 8:18 AM	10/12/05 3:21 PM	24.13	0.00	0.00	0.00	24.13	12.30	0.00	0.00	0.00	12.30		
21126	Machine Shop	MS	318.78	318.78	0.00	0.00	0.00	9/29/05 8:38 AM	10/12/05 3:24 PM	61.15	0.00	0.00	0.00	61.15	32.68	0.00	0.00	0.00	32.68		
21844	Machine Shop	MS	176.10	176.10	0.00	0.00	0.00	10/05/05 7:19 AM	10/12/05 3:24 PM	0.07	0.00	0.00	0.00	0.07	0.00	0.00	0.00	0.00			
20912	Kitchen	K	318.75	318.75	0.00	0.00	0.00	9/29/05 3:16 PM	10/12/05 10:00	0.33	0.00	0.00	0.00	0.33	0.33	0.00	0.00	0.00	0.33		
21038	Restroom	R	323.68	323.68	0.00	0.00	0.00	9/29/05 10:20 AM	10/12/05 10:00	41.37	0.00	0.00	0.00	41.37	18.70	0.00	0.00	0.00	18.70		
20694	Dorm Room	DR	321.62	321.62	0.00	0.00	0.00	9/29/05 12:24 PM	10/12/05 10:00	1.90	0.00	0.00	0.00	1.90	1.77	0.00	0.00	0.00	1.77		
23755	Cafeteria	CF	323.62	323.62	0.00	0.00	0.00	9/29/05 10:24 AM	10/12/05 10:00	323.62	0.00	0.00	0.00	323.62	216.28	0.00	0.00	0.00	216.28		
23280	Hallway	H	86.52	86.52	0.00	0.00	0.00	10/09/05 7:30 AM	10/12/05 10:00	53.17	0.00	0.00	0.00	53.17	45.03	0.00	0.00	0.00	45.03		
23579	Storage	S	323.65	323.65	0.00	0.00	0.00	9/29/05 10:22 AM	10/12/05 10:00	211.55	0.00	0.00	0.00	211.55	158.85	0.00	0.00	0.00	158.85		
22550	Storage	S	312.38	312.38	0.00	0.00	0.00	9/29/05 3:29 PM	10/12/05 3:51 PM	27.93	0.00	0.00	0.00	27.93	2.57	0.00	0.00	0.00	2.57		
23778	Kitchen	K	321.98	321.98	0.00	0.00	0.00	9/29/05 12:02 PM	10/12/05 10:00	5.87	0.00	0.00	0.00	5.87	5.80	0.00	0.00	0.00	5.80		
22357	Restroom	R	323.02	323.02	0.00	0.00	0.00	9/29/05 11:00 AM	10/12/05 10:00	307.25	0.00	0.00	0.00	307.25	153.80	0.00	0.00	0.00	153.80		
21542	Kitchen	K	24.75	24.75	0.00	0.00	0.00	9/29/05 10:53 AM	9/30/05 11:37 AM	16.63	0.00	0.00	0.00	16.63	13.03	0.00	0.00	0.00	13.03		
21304	Mechanical Room / Storage	MR	312.37	312.37	0.00	0.00	0.00	9/29/05 3:48 PM	10/12/05 4:09 PM	126.38	0.00	0.00	0.00	126.38	12.33	0.00	0.00	0.00	12.33		
22039	Kitchen	K	324.98	324.98	0.00	0.00	0.00	9/29/05 9:02 AM	10/12/05 10:00	277.25	0.00	0.00	0.00	277.25	193.90	0.00	0.00	0.00	193.90		

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
24199	Mechanical	MR	312	58.39	0.00	0.00	0.00	58.39	1.99	0.00	0.00	0.00	1.99	96.59%
23495	Conference	CN	512	0.17	0.00	0.00	0.00	0.17	0.17	0.00	0.00	0.00	0.17	0.00%
22742	Restroom	R	64	5.02	0.00	0.00	0.00	5.02	4.30	0.00	0.00	0.00	4.30	14.34%
22214	Office	O	256	11.05	0.00	0.00	0.00	11.05	9.89	0.00	0.00	0.00	9.89	10.50%
22142	Office	O	64	167.97	0.00	0.00	0.00	167.97	50.56	0.00	0.00	0.00	50.56	69.90%
22583	Hallway	H	512	25.06	0.00	0.00	0.00	25.06	22.08	0.00	0.00	0.00	22.08	11.89%
20637	Conference	CN	384	5.08	0.00	0.00	0.00	5.08	3.71	0.00	0.00	0.00	3.71	26.97%
20651	Office	O	192	20.40	0.00	0.00	0.00	20.40	12.82	0.00	0.00	0.00	12.82	37.16%
21562	Restroom	R	128	67.93	0.00	0.00	0.00	67.93	15.34	0.00	0.00	0.00	15.34	77.42%
21336	Kitchen	K	2432	0.18	0.00	0.00	0.00	0.18	0.18	0.00	0.00	0.00	0.18	0.00%
23605	Classroom	CR	1632	60.66	0.00	0.00	0.00	60.66	41.87	0.00	0.00	0.00	41.87	30.98%
21122	Classroom	CR	256	23.08	0.00	0.00	0.00	23.08	6.61	0.00	0.00	0.00	6.61	71.36%
24196	Storage	S	128	19.17	0.00	0.00	0.00	19.17	0.45	0.00	0.00	0.00	0.45	97.65%
24136	Kitchen	K	128	0.35	0.00	0.00	0.00	0.35	0.35	0.00	0.00	0.00	0.35	0.00%
24332	Hallway	H	1120	0.33	0.00	0.00	0.00	0.33	0.22	0.00	0.00	0.00	0.22	33.33%
24135	Conference	CN	480	31.62	0.00	0.00	0.00	31.62	23.52	0.00	0.00	0.00	23.52	25.62%
23931	Conference	CN	1440	31.36	0.00	0.00	0.00	31.36	28.87	0.00	0.00	0.00	28.87	7.94%
23760	Office	O	480	34.11	0.00	0.00	0.00	34.11	28.28	0.00	0.00	0.00	28.28	17.09%
24678	Conference	CN	720	11.43	0.00	0.00	0.00	11.43	9.97	0.00	0.00	0.00	9.97	12.77%
24223	Mechanical	MR	128	3.55	0.00	0.00	0.00	3.55	1.34	0.00	0.00	0.00	1.34	62.25%
24261	Storage	S	52	23.00	0.00	0.00	0.00	23.00	3.26	0.00	0.00	0.00	3.26	85.83%
21872	MultiPurpose	MP	1024	43.79	0.00	0.00	0.00	43.79	38.51	0.00	0.00	0.00	38.51	12.06%
23017	Open Bay	OB	768	4.89	0.00	0.00	0.00	4.89	2.97	0.00	0.00	0.00	2.97	39.26%
21087	Open Bay	OB	4992	34.00	0.00	0.00	0.00	34.00	26.61	0.00	0.00	0.00	26.61	21.74%
21286	Open Bay	OB	1664	2.87	0.00	0.00	0.00	2.87	2.81	0.00	0.00	0.00	2.81	2.09%
23066	Conference	CN	384	12.71	0.00	0.00	0.00	12.71	6.48	0.00	0.00	0.00	6.48	49.02%
21126	Machine Shop	MS	2368	32.23	0.00	0.00	0.00	32.23	17.22	0.00	0.00	0.00	17.22	46.57%
21844	Machine Shop	MS	2368	0.06	0.00	0.00	0.00	0.06	0.00	0.00	0.00	0.00	0.00	00.00%
20912	Kitchen	K	192	0.18	0.00	0.00	0.00	0.18	0.18	0.00	0.00	0.00	0.18	0.00%
21038	Restroom	R	52	21.47	0.00	0.00	0.00	21.47	9.71	0.00	0.00	0.00	9.71	54.77%
20694	Dorm Room	DR	64	0.99	0.00	0.00	0.00	0.99	0.92	0.00	0.00	0.00	0.92	7.07%
23755	Cafeteria	CF	464	168.00	0.00	0.00	0.00	168.00	112.28	0.00	0.00	0.00	112.28	33.17%
23280	Hallway	H	1152	103.24	0.00	0.00	0.00	103.24	87.45	0.00	0.00	0.00	87.45	15.29%
23579	Storage	S	64	109.81	0.00	0.00	0.00	109.81	82.46	0.00	0.00	0.00	82.46	24.91%
22550	Storage	S	104	15.02	0.00	0.00	0.00	15.02	1.38	0.00	0.00	0.00	1.38	90.81%
23778	Kitchen	K	320	3.06	0.00	0.00	0.00	3.06	3.03	0.00	0.00	0.00	3.03	0.98%
22357	Restroom	R	320	159.80	0.00	0.00	0.00	159.80	79.99	0.00	0.00	0.00	79.99	49.94%
21542	Kitchen	K	448	112.91	0.00	0.00	0.00	112.91	88.47	0.00	0.00	0.00	88.47	21.65%
21304	Mechanical	MR	450	67.97	0.00	0.00	0.00	67.97	6.63	0.00	0.00	0.00	6.63	90.25%
22039	Kitchen	K	186	143.32	0.00	0.00	0.00	143.32	100.24	0.00	0.00	0.00	100.24	30.06%

Building Summary Totals Building type:Hospital. Building size:50K to less than 100K. Shifts:3 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	4	564	36	0	0	0	36	15	0	0	0	15
Storage	S	4	348	15	0	0	0	15	8	0	0	0	8
Hallway	H	3	2784	119	0	0	0	119	102	0	0	0	102
Mechanical Room /	MR	3	891	39	0	0	0	39	3	0	0	0	3
Classroom	CR	2	1888	79	0	0	0	79	46	0	0	0	46
Kitchen	K	6	3708	161	0	0	0	161	119	0	0	0	119
Cafeteria	CF	1	464	78	0	0	0	78	52	0	0	0	52
Dorm Room	DR	1	64	0	0	0	0	0	0	0	0	0	0
Open Bay	OB	3	7425	103	0	0	0	103	80	0	0	0	80
Office	O	4	992	58	0	0	0	58	25	0	0	0	25
Conference	CN	6	3918	60	0	0	0	60	47	0	0	0	47
Machine Shop	MS	2	4736	76	0	0	0	76	41	0	0	0	41
MultiPurpose Rm	MP	1	1024	45	0	0	0	45	39	0	0	0	39
Building Totals			28806	869			0	869	578			0	578