


# Area Type Averages

Building type:Hotel/Casino. Building size:100K to less than 250K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	2	90	113.14	0.00	0.00	0.00	113.14	67.46	0.00	0.00	0.00	67.46	40.37%
Meeting Rooms	M	10	130	32.33	0.00	0.00	0.00	32.33	17.53	0.00	0.00	0.00	17.53	45.78%
Restroom	R	8	236	35.52	0.00	0.00	0.00	35.52	20.69	0.00	0.00	0.00	20.69	41.75%
Storage	S	8	23	20.72	0.00	0.00	0.00	20.72	9.00	0.00	0.00	0.00	9.00	56.56%
Hallway	H	1	307	168.00	0.00	0.00	0.00	168.00	104.85	0.00	0.00	0.00	104.85	37.59%
Janitor Closet	J	4	50	47.19	0.00	0.00	0.00	47.19	20.22	0.00	0.00	0.00	20.22	57.15%
Kitchen	K	1	227	139.11	0.00	0.00	0.00	139.11	101.53	0.00	0.00	0.00	101.53	27.01%
Office	O	1	80	106.87	0.00	0.00	0.00	106.87	91.30	0.00	0.00	0.00	91.30	14.57%
MultiPurpose Rm	MP	4	520	103.58	0.00	0.00	0.00	103.58	73.99	0.00	0.00	0.00	73.99	28.57%
Building Average			6446	69.79			0.00	69.79	45.94			0.00	45.94	34.17%



**Hours per Week for each Area Type**

Data Logger Detail Building type:Hotel/Casino. Building size:100K to less than 250K. Shifts:3 Page 1 of 1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
21408	Meeting Rooms	M	215.87	215.87	0.00	0.00	0.00	8/27/05 9:09 PM	9/05/05 9:00 PM	52.87	0.00	0.00	0.00	52.87	31.60	0.00	0.00	0.00	31.60
21707	Storage	S	197.97	197.97	0.00	0.00	0.00	8/28/05 3:03 PM	9/05/05 9:00 PM	3.13	0.00	0.00	0.00	3.13	1.97	0.00	0.00	0.00	1.97
21244	Restroom	R	215.85	215.85	0.00	0.00	0.00	8/27/05 9:10 PM	9/05/05 9:00 PM	48.65	0.00	0.00	0.00	48.65	32.65	0.00	0.00	0.00	32.65
20798	Meeting Rooms	M	221.78	221.78	0.00	0.00	0.00	8/27/05 3:14 PM	9/05/05 9:00 PM	38.73	0.00	0.00	0.00	38.73	25.60	0.00	0.00	0.00	25.60
21885	Storage	S	221.78	221.78	0.00	0.00	0.00	8/27/05 3:14 PM	9/05/05 9:00 PM	0.27	0.00	0.00	0.00	0.27	0.27	0.00	0.00	0.00	0.27
21659	Restroom	R	221.80	221.80	0.00	0.00	0.00	8/27/05 3:13 PM	9/05/05 9:00 PM	66.75	0.00	0.00	0.00	66.75	32.25	0.00	0.00	0.00	32.25
22395	Meeting Rooms	M	217.33	217.33	0.00	0.00	0.00	8/27/05 7:41 PM	9/05/05 9:00 PM	32.03	0.00	0.00	0.00	32.03	24.17	0.00	0.00	0.00	24.17
21780	Storage	S	222.40	222.40	0.00	0.00	0.00	8/27/05 2:37 PM	9/05/05 9:00 PM	18.03	0.00	0.00	0.00	18.03	12.37	0.00	0.00	0.00	12.37
21281	Restroom	R	222.43	222.43	0.00	0.00	0.00	8/27/05 2:35 PM	9/05/05 9:00 PM	88.37	0.00	0.00	0.00	88.37	46.47	0.00	0.00	0.00	46.47
22063	Meeting Rooms	M	222.52	222.52	0.00	0.00	0.00	8/27/05 2:30 PM	9/05/05 9:00 PM	56.63	0.00	0.00	0.00	56.63	35.27	0.00	0.00	0.00	35.27
22665	Storage	S	222.48	222.48	0.00	0.00	0.00	8/27/05 2:32 PM	9/05/05 9:00 PM	43.37	0.00	0.00	0.00	43.37	19.10	0.00	0.00	0.00	19.10
21626	Restroom	R	222.53	222.53	0.00	0.00	0.00	8/27/05 2:29 PM	9/05/05 9:00 PM	67.33	0.00	0.00	0.00	67.33	39.90	0.00	0.00	0.00	39.90
22977	Janitor Closet	J	222.33	222.33	0.00	0.00	0.00	8/27/05 2:41 PM	9/05/05 9:00 PM	53.67	0.00	0.00	0.00	53.67	17.60	0.00	0.00	0.00	17.60
22589	Meeting Rooms	M	222.62	222.62	0.00	0.00	0.00	8/27/05 2:24 PM	9/05/05 9:00 PM	63.17	0.00	0.00	0.00	63.17	34.23	0.00	0.00	0.00	34.23
21620	Storage	S	193.48	193.48	0.00	0.00	0.00	8/28/05 7:32 PM	9/05/05 9:00 PM	34.33	0.00	0.00	0.00	34.33	8.73	0.00	0.00	0.00	8.73
21289	Meeting Rooms	M	217.58	217.58	0.00	0.00	0.00	8/27/05 7:26 PM	9/05/05 9:00 PM	66.55	0.00	0.00	0.00	66.55	30.83	0.00	0.00	0.00	30.83
20851	Storage	S	222.68	222.68	0.00	0.00	0.00	8/27/05 2:20 PM	9/05/05 9:00 PM	38.68	0.00	0.00	0.00	38.68	17.07	0.00	0.00	0.00	17.07
22365	Restroom	R	222.70	222.70	0.00	0.00	0.00	8/27/05 2:19 PM	9/05/05 9:00 PM	48.10	0.00	0.00	0.00	48.10	34.37	0.00	0.00	0.00	34.37
22431	Janitor Closet	J	222.75	222.75	0.00	0.00	0.00	8/27/05 2:16 PM	9/05/05 9:00 PM	116.93	0.00	0.00	0.00	116.93	47.03	0.00	0.00	0.00	47.03
20745	Meeting Rooms	M	206.08	206.08	0.00	0.00	0.00	8/28/05 6:56 AM	9/05/05 9:00 PM	0.43	0.00	0.00	0.00	0.43	0.40	0.00	0.00	0.00	0.40
20856	Storage	S	222.87	222.87	0.00	0.00	0.00	8/27/05 2:09 PM	9/05/05 9:00 PM	25.27	0.00	0.00	0.00	25.27	12.13	0.00	0.00	0.00	12.13
22200	Restroom	R	218.33	218.33	0.00	0.00	0.00	8/27/05 6:41 PM	9/05/05 9:00 PM	1.20	0.00	0.00	0.00	1.20	1.20	0.00	0.00	0.00	1.20
21000	Janitor Closet	J	222.98	222.98	0.00	0.00	0.00	8/27/05 2:02 PM	9/05/05 9:00 PM	59.50	0.00	0.00	0.00	59.50	37.60	0.00	0.00	0.00	37.60
22374	Janitor Closet	J	222.90	222.90	0.00	0.00	0.00	8/27/05 2:07 PM	9/05/05 9:00 PM	20.13	0.00	0.00	0.00	20.13	5.03	0.00	0.00	0.00	5.03
22301	Meeting Rooms	M	221.30	221.30	0.00	0.00	0.00	8/27/05 3:43 PM	9/05/05 9:00 PM	53.80	0.00	0.00	0.00	53.80	20.80	0.00	0.00	0.00	20.80
22258	Restroom	R	221.33	221.33	0.00	0.00	0.00	8/27/05 3:41 PM	9/05/05 9:00 PM	39.60	0.00	0.00	0.00	39.60	16.97	0.00	0.00	0.00	16.97
22141	Meeting Rooms	M	221.35	221.35	0.00	0.00	0.00	8/27/05 3:40 PM	9/05/05 9:00 PM	53.58	0.00	0.00	0.00	53.58	22.20	0.00	0.00	0.00	22.20
21369	Storage	S	221.28	221.28	0.00	0.00	0.00	8/27/05 3:44 PM	9/05/05 9:00 PM	50.68	0.00	0.00	0.00	50.68	22.13	0.00	0.00	0.00	22.13
20550	MultiPurpose Rm	MP	219.67	219.67	0.00	0.00	0.00	8/27/05 5:21 PM	9/05/05 9:00 PM	55.20	0.00	0.00	0.00	55.20	27.00	0.00	0.00	0.00	27.00
21629	Meeting Rooms	M	221.45	221.45	0.00	0.00	0.00	8/27/05 3:34 PM	9/05/05 9:00 PM	5.73	0.00	0.00	0.00	5.73	4.43	0.00	0.00	0.00	4.43
21003	Restroom	R	221.45	221.45	0.00	0.00	0.00	8/27/05 3:34 PM	9/05/05 9:00 PM	14.37	0.00	0.00	0.00	14.37	14.13	0.00	0.00	0.00	14.13
22697	MultiPurpose Rm	MP	221.42	221.42	0.00	0.00	0.00	8/27/05 3:36 PM	9/05/05 9:00 PM	47.57	0.00	0.00	0.00	47.57	27.73	0.00	0.00	0.00	27.73
22302	Kitchen	K	221.58	221.58	0.00	0.00	0.00	8/27/05 3:26 PM	9/05/05 9:00 PM	183.48	0.00	0.00	0.00	183.48	133.92	0.00	0.00	0.00	133.92
20737	Hallway	H	221.60	221.60	0.00	0.00	0.00	8/27/05 3:25 PM	9/05/05 9:00 PM	221.60	0.00	0.00	0.00	221.60	138.30	0.00	0.00	0.00	138.30
21728	Private Office	PO	221.55	221.55	0.00	0.00	0.00	8/27/05 3:28 PM	9/05/05 9:00 PM	201.42	0.00	0.00	0.00	201.42	106.67	0.00	0.00	0.00	106.67
22750	Private Office	PO	221.65	221.65	0.00	0.00	0.00	8/27/05 3:22 PM	9/05/05 9:00 PM	97.03	0.00	0.00	0.00	97.03	71.30	0.00	0.00	0.00	71.30
21171	Office	O	222.20	222.20	0.00	0.00	0.00	8/27/05 2:49 PM	9/05/05 9:00 PM	141.35	0.00	0.00	0.00	141.35	120.75	0.00	0.00	0.00	120.75
22292	MultiPurpose Rm	MP	222.23	222.23	0.00	0.00	0.00	8/27/05 2:47 PM	9/05/05 9:00 PM	222.23	0.00	0.00	0.00	222.23	168.30	0.00	0.00	0.00	168.30
21176	MultiPurpose Rm	MP	222.23	222.23	0.00	0.00	0.00	8/27/05 2:47 PM	9/05/05 9:00 PM	222.23	0.00	0.00	0.00	222.23	168.07	0.00	0.00	0.00	168.07

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
21408	Meeting Rooms	M	125	41.14	0.00	0.00	0.00	41.14	24.59	0.00	0.00	0.00	24.59	40.23%
21707	Storage	S	17	2.66	0.00	0.00	0.00	2.66	1.67	0.00	0.00	0.00	1.67	37.22%
21244	Restroom	R	330	37.87	0.00	0.00	0.00	37.87	25.41	0.00	0.00	0.00	25.41	32.90%
20798	Meeting Rooms	M	169	29.34	0.00	0.00	0.00	29.34	19.39	0.00	0.00	0.00	19.39	33.91%
21885	Storage	S	17	0.20	0.00	0.00	0.00	0.20	0.20	0.00	0.00	0.00	0.20	0.00%
21659	Restroom	R	330	50.56	0.00	0.00	0.00	50.56	24.43	0.00	0.00	0.00	24.43	51.68%
22395	Meeting Rooms	M	142	24.76	0.00	0.00	0.00	24.76	18.68	0.00	0.00	0.00	18.68	24.56%
21780	Storage	S	17	13.62	0.00	0.00	0.00	13.62	9.34	0.00	0.00	0.00	9.34	31.42%
21281	Restroom	R	330	66.74	0.00	0.00	0.00	66.74	35.10	0.00	0.00	0.00	35.10	47.41%
22063	Meeting Rooms	M	188	42.76	0.00	0.00	0.00	42.76	26.63	0.00	0.00	0.00	26.63	37.72%
22665	Storage	S	19	32.75	0.00	0.00	0.00	32.75	14.42	0.00	0.00	0.00	14.42	55.97%
21626	Restroom	R	330	50.83	0.00	0.00	0.00	50.83	30.12	0.00	0.00	0.00	30.12	40.74%
22977	Janitor Closet	J	80	40.55	0.00	0.00	0.00	40.55	13.30	0.00	0.00	0.00	13.30	67.20%
22589	Meeting Rooms	M	142	47.67	0.00	0.00	0.00	47.67	25.83	0.00	0.00	0.00	25.83	45.81%
21620	Storage	S	19	29.81	0.00	0.00	0.00	29.81	7.58	0.00	0.00	0.00	7.58	74.57%
21289	Meeting Rooms	M	169	51.38	0.00	0.00	0.00	51.38	23.81	0.00	0.00	0.00	23.81	53.66%
20851	Storage	S	17	29.18	0.00	0.00	0.00	29.18	12.88	0.00	0.00	0.00	12.88	55.86%
22365	Restroom	R	330	36.29	0.00	0.00	0.00	36.29	25.93	0.00	0.00	0.00	25.93	28.55%
22431	Janitor Closet	J	19	88.19	0.00	0.00	0.00	88.19	35.47	0.00	0.00	0.00	35.47	59.78%
20745	Meeting Rooms	M	76	0.35	0.00	0.00	0.00	0.35	0.33	0.00	0.00	0.00	0.33	5.71%
20856	Storage	S	17	19.05	0.00	0.00	0.00	19.05	9.15	0.00	0.00	0.00	9.15	51.97%
22200	Restroom	R	57	0.92	0.00	0.00	0.00	0.92	0.92	0.00	0.00	0.00	0.92	0.00%
21000	Janitor Closet	J	19	44.83	0.00	0.00	0.00	44.83	28.33	0.00	0.00	0.00	28.33	36.81%
22374	Janitor Closet	J	80	15.17	0.00	0.00	0.00	15.17	3.79	0.00	0.00	0.00	3.79	75.02%
22301	Meeting Rooms	M	95	40.84	0.00	0.00	0.00	40.84	15.79	0.00	0.00	0.00	15.79	61.34%
22258	Restroom	R	17	30.06	0.00	0.00	0.00	30.06	12.88	0.00	0.00	0.00	12.88	57.15%
22141	Meeting Rooms	M	100	40.67	0.00	0.00	0.00	40.67	16.85	0.00	0.00	0.00	16.85	58.57%
21369	Storage	S	60	38.48	0.00	0.00	0.00	38.48	16.80	0.00	0.00	0.00	16.80	56.34%
20550	MultiPurpose	MP	150	42.22	0.00	0.00	0.00	42.22	20.65	0.00	0.00	0.00	20.65	51.09%
21629	Meeting Rooms	M	95	4.35	0.00	0.00	0.00	4.35	3.36	0.00	0.00	0.00	3.36	22.76%
21003	Restroom	R	165	10.90	0.00	0.00	0.00	10.90	10.72	0.00	0.00	0.00	10.72	1.65%
22697	MultiPurpose	MP	150	36.09	0.00	0.00	0.00	36.09	21.04	0.00	0.00	0.00	21.04	41.70%
22302	Kitchen	K	227	139.11	0.00	0.00	0.00	139.11	101.53	0.00	0.00	0.00	101.53	27.01%
20737	Hallway	H	307	168.00	0.00	0.00	0.00	168.00	104.85	0.00	0.00	0.00	104.85	37.59%
21728	Private Office	PO	80	152.73	0.00	0.00	0.00	152.73	80.88	0.00	0.00	0.00	80.88	47.04%
22750	Private Office	PO	100	73.55	0.00	0.00	0.00	73.55	54.04	0.00	0.00	0.00	54.04	26.53%
21171	Office	O	80	106.87	0.00	0.00	0.00	106.87	91.30	0.00	0.00	0.00	91.30	14.57%
22292	MultiPurpose	MP	890	168.00	0.00	0.00	0.00	168.00	127.23	0.00	0.00	0.00	127.23	24.27%
21176	MultiPurpose	MP	890	168.00	0.00	0.00	0.00	168.00	127.05	0.00	0.00	0.00	127.05	24.38%

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	2	180	20	0	0	0	20	12	0	0	0	12
Meeting Rooms	M	10	1300	42	0	0	0	42	23	0	0	0	23
Restroom	R	8	1888	67	0	0	0	67	39	0	0	0	39
Storage	S	8	184	4	0	0	0	4	2	0	0	0	2
Hallway	H	1	307	52	0	0	0	52	32	0	0	0	32
Janitor Closet	J	4	200	9	0	0	0	9	4	0	0	0	4
Kitchen	K	1	227	32	0	0	0	32	23	0	0	0	23
Office	O	1	80	9	0	0	0	9	7	0	0	0	7
MultiPurpose Rm	MP	4	2080	215	0	0	0	215	154	0	0	0	154
Building Totals			6446	450			0	450	296			0	296