


Area Type Averages

Building type:Industrial Manufacturing. Building size:500K to less than 1,000K. Shifts:2

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Factory	FA	19	718	29.90	81.43	0.00	0.00	111.33	27.65	55.62	0.00	0.00	83.27	25.20%
Building Average			13642	29.90	81.43	0.00		111.33	27.65	55.62	0.00		83.27	25.20%



Hours per Week for each Area Type

Data Logger Detail Building type:Industrial Manufacturing. Building size:500K to less than 1,000K. Shifts:2

All Loggers Listed			Hours Installed						Lights On						Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
20494	Factory	FA	362.48	66.70	295.78	0.00	0.00	10/31/05 11:13	11/15/05 1:41 PM	66.68	227.03	0.00	0.00	293.72	59.18	157.12	0.00	0.00	216.30
22266	Factory	FA	362.47	66.70	295.77	0.00	0.00	10/31/05 11:14	11/15/05 1:41 PM	66.68	215.90	0.00	0.00	282.58	66.62	205.63	0.00	0.00	272.25
22019	Factory	FA	362.47	66.72	295.75	0.00	0.00	10/31/05 11:15	11/15/05 1:42 PM	66.70	216.02	0.00	0.00	282.72	66.13	185.95	0.00	0.00	252.08
20584	Factory	FA	362.33	66.62	295.72	0.00	0.00	10/31/05 11:17	11/15/05 1:36 PM	65.30	112.85	0.00	0.00	178.15	64.10	90.02	0.00	0.00	154.12
20597	Factory	FA	362.35	66.65	295.70	0.00	0.00	10/31/05 11:18	11/15/05 1:38 PM	66.17	167.53	0.00	0.00	233.70	66.17	146.90	0.00	0.00	213.07
21905	Factory	FA	361.08	66.00	295.08	0.00	0.00	10/31/05 11:33	11/15/05 12:37	66.00	289.63	0.00	0.00	355.63	65.30	131.67	0.00	0.00	196.97
20528	Factory	FA	361.27	66.00	295.27	0.00	0.00	10/31/05 11:36	11/15/05 12:51	66.00	236.12	0.00	0.00	302.12	55.87	154.95	0.00	0.00	210.82
21938	Factory	FA	361.33	66.00	295.33	0.00	0.00	10/31/05 11:39	11/15/05 12:58	65.87	228.15	0.00	0.00	294.02	62.10	140.88	0.00	0.00	202.98
22792	Factory	FA	361.17	66.00	295.17	0.00	0.00	10/31/05 11:35	11/15/05 12:44	66.00	295.15	0.00	0.00	361.15	65.97	182.88	0.00	0.00	248.85
21365	Factory	FA	361.40	66.07	295.33	0.00	0.00	10/31/05 11:40	11/15/05 1:03 PM	65.07	144.80	0.00	0.00	209.87	64.47	122.27	0.00	0.00	186.73
20901	Factory	FA	360.85	66.00	294.85	0.00	0.00	10/31/05 11:31	11/15/05 12:21	66.00	84.13	0.00	0.00	150.13	60.50	64.23	0.00	0.00	124.73
21864	Factory	FA	360.90	66.00	294.90	0.00	0.00	10/31/05 11:29	11/15/05 12:22	66.00	84.32	0.00	0.00	150.32	63.43	70.95	0.00	0.00	134.38
21049	Factory	FA	360.87	66.00	294.87	0.00	0.00	10/31/05 11:29	11/15/05 12:20	66.00	84.13	0.00	0.00	150.13	63.55	70.92	0.00	0.00	134.47
22720	Factory	FA	362.58	66.73	295.85	0.00	0.00	10/31/05 11:09	11/15/05 1:43 PM	66.72	112.12	0.00	0.00	178.83	66.28	105.08	0.00	0.00	171.37
22711	Factory	FA	362.58	66.75	295.83	0.00	0.00	10/31/05 11:10	11/15/05 1:44 PM	66.73	112.17	0.00	0.00	178.90	65.73	105.27	0.00	0.00	171.00
20602	Factory	FA	362.58	66.77	295.82	0.00	0.00	10/31/05 11:11	11/15/05 1:45 PM	65.75	108.42	0.00	0.00	174.17	26.57	50.67	0.00	0.00	77.23
22010	Factory	FA	362.07	66.48	295.58	0.00	0.00	10/31/05 11:25	11/15/05 1:28 PM	66.47	204.87	0.00	0.00	271.33	65.12	105.08	0.00	0.00	170.20
22276	Factory	FA	362.17	66.52	295.65	0.00	0.00	10/31/05 11:21	11/15/05 1:30 PM	66.50	184.22	0.00	0.00	250.72	50.67	72.30	0.00	0.00	122.97
20506	Factory	FA	362.05	66.48	295.57	0.00	0.00	10/31/05 11:26	11/15/05 1:28 PM	66.47	204.90	0.00	0.00	271.37	64.37	100.13	0.00	0.00	164.50

Normalized Data Logger Detail Building type:Industrial Manufacturing. Building size:500K to less than 1,000K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
20494	Factory	FA	1080	29.99	105.92	0.00	0.00	135.92	26.62	73.30	0.00	0.00	99.92	26.49%
22266	Factory	FA	1080	29.99	100.74	0.00	0.00	130.73	29.96	95.95	0.00	0.00	125.91	3.69%
22019	Factory	FA	1080	29.99	100.80	0.00	0.00	130.79	29.74	86.77	0.00	0.00	116.50	10.93%
20584	Factory	FA	1080	29.41	52.66	0.00	0.00	82.07	28.87	42.01	0.00	0.00	70.87	13.65%
20597	Factory	FA	1080	29.78	78.19	0.00	0.00	107.97	29.78	68.56	0.00	0.00	98.34	8.92%
21905	Factory	FA	455	30.00	135.45	0.00	0.00	165.45	29.68	61.58	0.00	0.00	91.26	44.84%
20528	Factory	FA	455	30.00	110.35	0.00	0.00	140.35	25.39	72.42	0.00	0.00	97.81	30.31%
21938	Factory	FA	455	29.94	106.61	0.00	0.00	136.55	28.23	65.83	0.00	0.00	94.06	31.12%
22792	Factory	FA	455	30.00	137.99	0.00	0.00	167.99	29.98	85.50	0.00	0.00	115.49	31.25%
21365	Factory	FA	455	29.55	67.66	0.00	0.00	97.21	29.27	57.13	0.00	0.00	86.40	11.12%
20901	Factory	FA	455	30.00	39.38	0.00	0.00	69.38	27.50	30.06	0.00	0.00	57.56	17.04%
21864	Factory	FA	455	30.00	39.46	0.00	0.00	69.46	28.83	33.20	0.00	0.00	62.03	10.70%
21049	Factory	FA	455	30.00	39.38	0.00	0.00	69.38	28.89	33.19	0.00	0.00	62.08	10.52%
22720	Factory	FA	1080	29.99	52.30	0.00	0.00	82.29	29.80	49.02	0.00	0.00	78.81	4.23%
22711	Factory	FA	1080	29.99	52.32	0.00	0.00	82.32	29.54	49.10	0.00	0.00	78.65	4.46%
20602	Factory	FA	1080	29.54	50.58	0.00	0.00	80.12	11.94	23.64	0.00	0.00	35.57	55.60%
22010	Factory	FA	455	29.99	95.65	0.00	0.00	125.64	29.38	49.06	0.00	0.00	78.44	37.57%
22276	Factory	FA	455	29.99	85.99	0.00	0.00	115.98	22.85	33.75	0.00	0.00	56.60	51.20%
20506	Factory	FA	455	29.99	95.67	0.00	0.00	125.66	29.04	46.75	0.00	0.00	75.80	39.68%

Building Summary Totals Building type:Industrial Manufacturing. Building size:500K to less than 1,000K. Shifts:2

Building Summary Totals			Lights On KWHR						Occupied KWHR				
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Factory	FA	19	13642	408	1111	0	0	1519	377	759	0	0	1136
Building Totals			13642	408	1111		0	1519	377	759		0	1136