


# Area Type Averages

Building type:Light/High Tech Manufg. Building size:25K to less than 50K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Restroom	R	4	221	74.36	0.00	0.00	74.36	37.05	0.00	0.00	0.00	37.05	50.17%	
Hallway	H	2	472	38.40	0.00	0.00	38.40	26.28	0.00	0.00	0.00	26.28	31.56%	
Classroom	CR	3	375	5.44	0.00	0.00	5.44	3.70	0.00	0.00	0.00	3.70	31.99%	
Kitchen	K	1	590	0.75	0.00	0.00	0.75	0.75	0.00	0.00	0.00	0.75	0.00%	
Cafeteria	CF	1	826	9.96	0.00	0.00	9.96	8.41	0.00	0.00	0.00	8.41	15.56%	
Waiting Room	WF	1	295	0.58	0.00	0.00	0.58	0.57	0.00	0.00	0.00	0.57	1.72%	
Office	O	7	211	8.41	0.00	0.00	8.41	7.71	0.00	0.00	0.00	7.71	8.32%	
Lobby	LB	1	472	0.65	0.00	0.00	0.65	0.65	0.00	0.00	0.00	0.65	0.00%	
Utility	UT	1	66	0.05	0.00	0.00	0.05	0.05	0.00	0.00	0.00	0.05	0.00%	
Building Average			6679	19.42			19.42	12.12			0.00	12.12	37.59%	



**Hours per Week for each Area Type**

Data Logger Detail Building type:Light/High Tech Manufg. Building size:25K to less than 50K. Shifts:1 Page 1 of 1

All Loggers Listed			Hours Installed							Lights On					Occupied					
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
23733	Lobby	LB	744.02	744.02	0.00	0.00	0.00	10/18/05 12:00	11/18/05 12:00	2.90	0.00	0.00	0.00	2.90	2.90	0.00	0.00	0.00	0.00	2.90
23985	Hallway	H	744.02	744.02	0.00	0.00	0.00	10/18/05 12:00	11/18/05 12:00	334.55	0.00	0.00	0.00	334.55	228.43	0.00	0.00	0.00	0.00	228.43
24169	Office	O	744.02	744.02	0.00	0.00	0.00	10/18/05 12:00	11/18/05 12:00	2.33	0.00	0.00	0.00	2.33	2.33	0.00	0.00	0.00	0.00	2.33
24302	Office	O	744.02	744.02	0.00	0.00	0.00	10/18/05 12:00	11/18/05 12:00	3.43	0.00	0.00	0.00	3.43	2.77	0.00	0.00	0.00	0.00	2.77
24179	Restroom	R	744.02	744.02	0.00	0.00	0.00	10/18/05 12:00	11/18/05 12:00	331.07	0.00	0.00	0.00	331.07	198.63	0.00	0.00	0.00	0.00	198.63
23759	Hallway	H	744.02	744.02	0.00	0.00	0.00	10/18/05 12:00	11/18/05 12:00	5.57	0.00	0.00	0.00	5.57	4.30	0.00	0.00	0.00	0.00	4.30
24590	Office	O	744.02	744.02	0.00	0.00	0.00	10/18/05 12:00	11/18/05 12:00	197.17	0.00	0.00	0.00	197.17	178.23	0.00	0.00	0.00	0.00	178.23
23393	Restroom	R	744.02	744.02	0.00	0.00	0.00	10/18/05 12:00	11/18/05 12:00	744.02	0.00	0.00	0.00	744.02	347.25	0.00	0.00	0.00	0.00	347.25
23921	Classroom	CR	545.27	545.27	0.00	0.00	0.00	10/26/05 6:45 AM	11/18/05 12:00	51.47	0.00	0.00	0.00	51.47	34.57	0.00	0.00	0.00	0.00	34.57
20523	Classroom	CR	521.33	521.33	0.00	0.00	0.00	10/27/05 6:41 AM	11/18/05 12:00	0.77	0.00	0.00	0.00	0.77	0.77	0.00	0.00	0.00	0.00	0.77
23545	Kitchen	K	545.22	545.22	0.00	0.00	0.00	10/26/05 6:48 AM	11/18/05 12:00	2.43	0.00	0.00	0.00	2.43	2.43	0.00	0.00	0.00	0.00	2.43
24207	Utility	UT	521.35	521.35	0.00	0.00	0.00	10/27/05 6:40 AM	11/18/05 12:00	0.17	0.00	0.00	0.00	0.17	0.17	0.00	0.00	0.00	0.00	0.17
23550	Cafeteria	CF	541.13	541.13	0.00	0.00	0.00	10/26/05 10:53	11/18/05 12:00	32.07	0.00	0.00	0.00	32.07	27.10	0.00	0.00	0.00	0.00	27.10
23487	Restroom	R	559.13	559.13	0.00	0.00	0.00	10/25/05 4:53 PM	11/18/05 12:00	181.37	0.00	0.00	0.00	181.37	82.33	0.00	0.00	0.00	0.00	82.33
23749	Waiting Room	WF	558.33	558.33	0.00	0.00	0.00	10/25/05 5:41 PM	11/18/05 12:00	1.93	0.00	0.00	0.00	1.93	1.90	0.00	0.00	0.00	0.00	1.90
24324	Office	O	542.80	542.80	0.00	0.00	0.00	10/26/05 9:13 AM	11/18/05 12:00	2.57	0.00	0.00	0.00	2.57	2.57	0.00	0.00	0.00	0.00	2.57
23806	Office	O	544.40	544.40	0.00	0.00	0.00	10/26/05 7:37 AM	11/18/05 12:00	1.33	0.00	0.00	0.00	1.33	1.33	0.00	0.00	0.00	0.00	1.33
23076	Office	O	559.68	559.68	0.00	0.00	0.00	10/25/05 4:20 PM	11/18/05 12:00	38.57	0.00	0.00	0.00	38.57	37.03	0.00	0.00	0.00	0.00	37.03
21477	Office	O	421.53	421.53	0.00	0.00	0.00	10/31/05 10:29	11/18/05 12:00	0.60	0.00	0.00	0.00	0.60	0.57	0.00	0.00	0.00	0.00	0.57
23331	Classroom	CR	544.30	544.30	0.00	0.00	0.00	10/26/05 7:43 AM	11/18/05 12:00	0.70	0.00	0.00	0.00	0.70	0.67	0.00	0.00	0.00	0.00	0.67
23732	Restroom	R	545.18	545.18	0.00	0.00	0.00	10/26/05 6:50 AM	11/18/05 12:00	0.63	0.00	0.00	0.00	0.63	0.63	0.00	0.00	0.00	0.00	0.63

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23733	Lobby	LB	472	0.65	0.00	0.00	0.00	0.65	0.65	0.00	0.00	0.00	0.65	0.00%
23985	Hallway	H	413	75.54	0.00	0.00	0.00	75.54	51.58	0.00	0.00	0.00	51.58	31.72%
24169	Office	O	118	0.53	0.00	0.00	0.00	0.53	0.53	0.00	0.00	0.00	0.53	0.00%
24302	Office	O	118	0.78	0.00	0.00	0.00	0.78	0.62	0.00	0.00	0.00	0.62	20.51%
24179	Restroom	R	295	74.76	0.00	0.00	0.00	74.76	44.85	0.00	0.00	0.00	44.85	40.01%
23759	Hallway	H	531	1.26	0.00	0.00	0.00	1.26	0.97	0.00	0.00	0.00	0.97	23.02%
24590	Office	O	236	44.52	0.00	0.00	0.00	44.52	40.25	0.00	0.00	0.00	40.25	9.59%
23393	Restroom	R	236	168.00	0.00	0.00	0.00	168.00	78.41	0.00	0.00	0.00	78.41	53.33%
23921	Classroom	CR	295	15.86	0.00	0.00	0.00	15.86	10.65	0.00	0.00	0.00	10.65	32.85%
20523	Classroom	CR	239	0.25	0.00	0.00	0.00	0.25	0.25	0.00	0.00	0.00	0.25	0.00%
23545	Kitchen	K	590	0.75	0.00	0.00	0.00	0.75	0.75	0.00	0.00	0.00	0.75	0.00%
24207	Utility	UT	66	0.05	0.00	0.00	0.00	0.05	0.05	0.00	0.00	0.00	0.05	0.00%
23550	Cafeteria	CF	826	9.96	0.00	0.00	0.00	9.96	8.41	0.00	0.00	0.00	8.41	15.56%
23487	Restroom	R	177	54.49	0.00	0.00	0.00	54.49	24.74	0.00	0.00	0.00	24.74	54.60%
23749	Waiting Room	WF	295	0.58	0.00	0.00	0.00	0.58	0.57	0.00	0.00	0.00	0.57	1.72%
24324	Office	O	118	0.79	0.00	0.00	0.00	0.79	0.79	0.00	0.00	0.00	0.79	0.00%
23806	Office	O	295	0.41	0.00	0.00	0.00	0.41	0.41	0.00	0.00	0.00	0.41	0.00%
23076	Office	O	118	11.58	0.00	0.00	0.00	11.58	11.12	0.00	0.00	0.00	11.12	3.97%
21477	Office	O	472	0.24	0.00	0.00	0.00	0.24	0.23	0.00	0.00	0.00	0.23	4.17%
23331	Classroom	CR	590	0.22	0.00	0.00	0.00	0.22	0.21	0.00	0.00	0.00	0.21	4.55%
23732	Restroom	R	177	0.20	0.00	0.00	0.00	0.20	0.20	0.00	0.00	0.00	0.20	0.00%

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	4	884	66	0	0	0	66	33	0	0	0	33
Hallway	H	2	944	36	0	0	0	36	25	0	0	0	25
Classroom	CR	3	1125	6	0	0	0	6	4	0	0	0	4
Kitchen	K	1	590	0	0	0	0	0	0	0	0	0	0
Cafeteria	CF	1	826	8	0	0	0	8	7	0	0	0	7
Waiting Room	WF	1	295	0	0	0	0	0	0	0	0	0	0
Office	O	7	1477	12	0	0	0	12	11	0	0	0	11
Lobby	LB	1	472	0	0	0	0	0	0	0	0	0	0
Utility	UT	1	66	0	0	0	0	0	0	0	0	0	0
Building Totals			6679	130			0	130	81			0	81