


# Area Type Averages

Building type:Office. Building size:more than 1,000K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	6	275	64.67	0.00	0.00	64.67	37.48	0.00	0.00	0.00	37.48	42.04%	
Meeting Rooms	M	8	779	50.73	0.00	0.00	50.73	12.67	0.00	0.00	0.00	12.67	75.02%	
Open Space	OS	13	1363	92.61	0.00	0.00	92.61	62.36	0.00	0.00	0.00	62.36	32.66%	
Restroom	R	8	249	130.54	0.00	0.00	130.54	46.34	0.00	0.00	0.00	46.34	64.50%	
Storage	S	3	1089	75.85	0.00	0.00	75.85	21.17	0.00	0.00	0.00	21.17	72.09%	
Kitchen	K	2	249	98.43	0.00	0.00	98.43	36.20	0.00	0.00	0.00	36.20	63.22%	
Copy Rm	C	3	680	110.25	0.00	0.00	110.25	42.80	0.00	0.00	0.00	42.80	61.18%	
Building Average			33398	85.20			85.20	45.29			0.00	45.29	46.84%	



**Hours per Week for each Area Type**

# Data Logger Detail Building type:Office. Building size:more than 1,000K. Shifts:1 Page 1 of 1

All Loggers Listed			Hours Installed						Lights On						Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
49369	Copy Rm	C	701.73	701.73	0.00	0.00	0.00	7/10/02 9:34 AM	8/08/02 3:17 PM	351.35	0.00	0.00	0.00	351.35	118.08	0.00	0.00	0.00	118.08
49569	Meeting Rooms	M	700.62	700.62	0.00	0.00	0.00	7/10/02 10:41 AM	8/08/02 3:17 PM	66.82	0.00	0.00	0.00	66.82	20.93	0.00	0.00	0.00	20.93
49389	Storage	S	700.98	700.98	0.00	0.00	0.00	7/10/02 9:26 AM	8/08/02 2:24 PM	318.92	0.00	0.00	0.00	318.92	107.48	0.00	0.00	0.00	107.48
49363	Storage	S	701.87	701.87	0.00	0.00	0.00	7/10/02 9:26 AM	8/08/02 3:17 PM	319.02	0.00	0.00	0.00	319.02	115.03	0.00	0.00	0.00	115.03
49390	Private Office	PO	700.98	700.98	0.00	0.00	0.00	7/10/02 9:26 AM	8/08/02 2:24 PM	225.72	0.00	0.00	0.00	225.72	135.40	0.00	0.00	0.00	135.40
49385	Meeting Rooms	M	700.83	700.83	0.00	0.00	0.00	7/10/02 9:35 AM	8/08/02 2:24 PM	176.05	0.00	0.00	0.00	176.05	45.27	0.00	0.00	0.00	45.27
49364	Private Office	PO	701.62	701.62	0.00	0.00	0.00	7/10/02 9:41 AM	8/08/02 3:17 PM	256.17	0.00	0.00	0.00	256.17	157.82	0.00	0.00	0.00	157.82
49365	Private Office	PO	701.45	701.45	0.00	0.00	0.00	7/10/02 9:51 AM	8/08/02 3:17 PM	265.42	0.00	0.00	0.00	265.42	145.20	0.00	0.00	0.00	145.20
49486	Meeting Rooms	M	702.68	702.68	0.00	0.00	0.00	7/10/02 7:44 AM	8/08/02 2:24 PM	285.73	0.00	0.00	0.00	285.73	46.02	0.00	0.00	0.00	46.02
49554	Private Office	PO	698.53	698.53	0.00	0.00	0.00	7/10/02 11:56 AM	8/08/02 2:27 PM	268.97	0.00	0.00	0.00	268.97	201.02	0.00	0.00	0.00	201.02
49384	Open Space	OS	699.12	699.12	0.00	0.00	0.00	7/10/02 11:18 AM	8/08/02 2:24 PM	341.48	0.00	0.00	0.00	341.48	276.53	0.00	0.00	0.00	276.53
49443	Open Space	OS	699.00	699.00	0.00	0.00	0.00	7/10/02 11:25 AM	8/08/02 2:24 PM	338.45	0.00	0.00	0.00	338.45	279.28	0.00	0.00	0.00	279.28
49446	Open Space	OS	699.93	699.93	0.00	0.00	0.00	7/10/02 11:22 AM	8/08/02 3:17 PM	42.65	0.00	0.00	0.00	42.65	32.58	0.00	0.00	0.00	32.58
49440	Open Space	OS	700.20	700.20	0.00	0.00	0.00	7/10/02 11:06 AM	8/08/02 3:17 PM	698.95	0.00	0.00	0.00	698.95	300.80	0.00	0.00	0.00	300.80
49423	Open Space	OS	699.10	699.10	0.00	0.00	0.00	7/10/02 11:19 AM	8/08/02 2:24 PM	338.45	0.00	0.00	0.00	338.45	301.75	0.00	0.00	0.00	301.75
49498	Storage	S	701.52	701.52	0.00	0.00	0.00	7/10/02 9:47 AM	8/08/02 3:17 PM	312.17	0.00	0.00	0.00	312.17	42.67	0.00	0.00	0.00	42.67
49492	Kitchen	K	700.52	700.52	0.00	0.00	0.00	7/10/02 9:54 AM	8/08/02 2:24 PM	120.38	0.00	0.00	0.00	120.38	20.08	0.00	0.00	0.00	20.08
49481	Restroom	R	698.70	698.70	0.00	0.00	0.00	7/10/02 12:12 PM	8/08/02 2:53 PM	634.52	0.00	0.00	0.00	634.52	62.98	0.00	0.00	0.00	62.98
49438	Restroom	R	698.27	698.27	0.00	0.00	0.00	7/10/02 12:09 PM	8/08/02 2:24 PM	416.73	0.00	0.00	0.00	416.73	256.87	0.00	0.00	0.00	256.87
49362	Restroom	R	698.15	698.15	0.00	0.00	0.00	7/10/02 12:16 PM	8/08/02 2:24 PM	400.23	0.00	0.00	0.00	400.23	218.27	0.00	0.00	0.00	218.27
49437	Copy Rm	C	698.98	698.98	0.00	0.00	0.00	7/10/02 11:26 AM	8/08/02 2:24 PM	698.98	0.00	0.00	0.00	698.98	271.93	0.00	0.00	0.00	271.93
49474	Open Space	OS	698.92	698.92	0.00	0.00	0.00	7/10/02 11:30 AM	8/08/02 2:24 PM	501.65	0.00	0.00	0.00	501.65	273.10	0.00	0.00	0.00	273.10
49360	Restroom	R	700.93	700.93	0.00	0.00	0.00	7/10/02 10:22 AM	8/08/02 3:17 PM	550.45	0.00	0.00	0.00	550.45	217.27	0.00	0.00	0.00	217.27
49421	Restroom	R	700.07	700.07	0.00	0.00	0.00	7/10/02 10:21 AM	8/08/02 2:24 PM	546.52	0.00	0.00	0.00	546.52	214.37	0.00	0.00	0.00	214.37
49563	Copy Rm	C	698.37	698.37	0.00	0.00	0.00	7/10/02 12:03 PM	8/08/02 2:24 PM	326.92	0.00	0.00	0.00	326.92	144.50	0.00	0.00	0.00	144.50
49475	Private Office	PO	699.37	699.37	0.00	0.00	0.00	7/10/02 11:03 AM	8/08/02 2:24 PM	364.20	0.00	0.00	0.00	364.20	152.90	0.00	0.00	0.00	152.90
49579	Meeting Rooms	M	699.30	699.30	0.00	0.00	0.00	7/10/02 12:00 PM	8/08/02 3:17 PM	281.30	0.00	0.00	0.00	281.30	64.30	0.00	0.00	0.00	64.30
49436	Meeting Rooms	M	699.27	699.27	0.00	0.00	0.00	7/10/02 12:02 PM	8/08/02 3:17 PM	283.78	0.00	0.00	0.00	283.78	83.55	0.00	0.00	0.00	83.55
49495	Meeting Rooms	M	699.25	699.25	0.00	0.00	0.00	7/10/02 12:03 PM	8/08/02 3:17 PM	180.75	0.00	0.00	0.00	180.75	33.35	0.00	0.00	0.00	33.35
49376	Meeting Rooms	M	700.20	700.20	0.00	0.00	0.00	7/10/02 11:06 AM	8/08/02 3:17 PM	243.80	0.00	0.00	0.00	243.80	78.65	0.00	0.00	0.00	78.65
49445	Private Office	PO	699.25	699.25	0.00	0.00	0.00	7/10/02 11:10 AM	8/08/02 2:24 PM	236.52	0.00	0.00	0.00	236.52	144.75	0.00	0.00	0.00	144.75
49391	Open Space	OS	701.95	701.95	0.00	0.00	0.00	7/10/02 9:21 AM	8/08/02 3:17 PM	324.82	0.00	0.00	0.00	324.82	177.63	0.00	0.00	0.00	177.63
49560	Open Space	OS	698.98	698.98	0.00	0.00	0.00	7/10/02 11:48 AM	8/08/02 2:46 PM	347.32	0.00	0.00	0.00	347.32	270.65	0.00	0.00	0.00	270.65
49496	Open Space	OS	698.92	698.92	0.00	0.00	0.00	7/10/02 11:50 AM	8/08/02 2:44 PM	338.72	0.00	0.00	0.00	338.72	238.27	0.00	0.00	0.00	238.27
49578	Kitchen	K	698.67	698.67	0.00	0.00	0.00	7/10/02 11:45 AM	8/08/02 2:24 PM	698.57	0.00	0.00	0.00	698.57	281.02	0.00	0.00	0.00	281.02
49568	Meeting Rooms	M	698.87	698.87	0.00	0.00	0.00	7/10/02 11:33 AM	8/08/02 2:24 PM	173.02	0.00	0.00	0.00	173.02	50.22	0.00	0.00	0.00	50.22
49573	Open Space	OS	698.70	698.70	0.00	0.00	0.00	7/10/02 11:43 AM	8/08/02 2:24 PM	346.97	0.00	0.00	0.00	346.97	306.35	0.00	0.00	0.00	306.35
49564	Open Space	OS	698.80	698.80	0.00	0.00	0.00	7/10/02 11:37 AM	8/08/02 2:24 PM	698.50	0.00	0.00	0.00	698.50	306.43	0.00	0.00	0.00	306.43
49559	Open Space	OS	699.73	699.73	0.00	0.00	0.00	7/10/02 11:34 AM	8/08/02 3:17 PM	346.80	0.00	0.00	0.00	346.80	295.98	0.00	0.00	0.00	295.98
49482	Open Space	OS	698.75	698.75	0.00	0.00	0.00	7/10/02 11:40 AM	8/08/02 2:24 PM	347.22	0.00	0.00	0.00	347.22	315.05	0.00	0.00	0.00	315.05
49430	Restroom	R	697.88	697.88	0.00	0.00	0.00	7/10/02 12:09 PM	8/08/02 2:01 PM	636.28	0.00	0.00	0.00	636.28	206.07	0.00	0.00	0.00	206.07
49491	Restroom	R	699.07	699.07	0.00	0.00	0.00	7/10/02 12:14 PM	8/08/02 3:17 PM	594.87	0.00	0.00	0.00	594.87	136.95	0.00	0.00	0.00	136.95
49387	Restroom	R	698.15	698.15	0.00	0.00	0.00	7/10/02 12:16 PM	8/08/02 2:24 PM	565.10	0.00	0.00	0.00	565.10	229.40	0.00	0.00	0.00	229.40

Normalized Data Logger Detail Building type:Office. Building size:more than 1,000K. Shifts:1 Page 1 of 1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
49369	Copy Rm	C	480	84.12	0.00	0.00	0.00	84.12	28.27	0.00	0.00	0.00	28.27	66.39%
49569	Meeting Rooms	M	89	16.02	0.00	0.00	0.00	16.02	5.02	0.00	0.00	0.00	5.02	68.66%
49389	Storage	S	1950	76.43	0.00	0.00	0.00	76.43	25.76	0.00	0.00	0.00	25.76	66.30%
49363	Storage	S	356	76.36	0.00	0.00	0.00	76.36	27.53	0.00	0.00	0.00	27.53	63.95%
49390	Private Office	PO	320	54.10	0.00	0.00	0.00	54.10	32.45	0.00	0.00	0.00	32.45	40.02%
49385	Meeting Rooms	M	640	42.20	0.00	0.00	0.00	42.20	10.85	0.00	0.00	0.00	10.85	74.29%
49364	Private Office	PO	160	61.34	0.00	0.00	0.00	61.34	37.79	0.00	0.00	0.00	37.79	38.39%
49365	Private Office	PO	390	63.57	0.00	0.00	0.00	63.57	34.78	0.00	0.00	0.00	34.78	45.29%
49486	Meeting Rooms	M	2900	68.31	0.00	0.00	0.00	68.31	11.00	0.00	0.00	0.00	11.00	83.90%
49554	Private Office	PO	260	64.69	0.00	0.00	0.00	64.69	48.35	0.00	0.00	0.00	48.35	25.26%
49384	Open Space	OS	712	82.06	0.00	0.00	0.00	82.06	66.45	0.00	0.00	0.00	66.45	19.02%
49443	Open Space	OS	5200	81.34	0.00	0.00	0.00	81.34	67.12	0.00	0.00	0.00	67.12	17.48%
49446	Open Space	OS	712	10.24	0.00	0.00	0.00	10.24	7.82	0.00	0.00	0.00	7.82	23.63%
49440	Open Space	OS	712	167.70	0.00	0.00	0.00	167.70	72.17	0.00	0.00	0.00	72.17	56.96%
49423	Open Space	OS	712	81.33	0.00	0.00	0.00	81.33	72.51	0.00	0.00	0.00	72.51	10.84%
49498	Storage	S	960	74.76	0.00	0.00	0.00	74.76	10.22	0.00	0.00	0.00	10.22	86.33%
49492	Kitchen	K	320	28.87	0.00	0.00	0.00	28.87	4.82	0.00	0.00	0.00	4.82	83.30%
49481	Restroom	R	320	152.57	0.00	0.00	0.00	152.57	15.14	0.00	0.00	0.00	15.14	90.08%
49438	Restroom	R	320	100.26	0.00	0.00	0.00	100.26	61.80	0.00	0.00	0.00	61.80	38.36%
49362	Restroom	R	34	96.31	0.00	0.00	0.00	96.31	52.52	0.00	0.00	0.00	52.52	45.47%
49437	Copy Rm	C	1300	168.00	0.00	0.00	0.00	168.00	65.36	0.00	0.00	0.00	65.36	61.10%
49474	Open Space	OS	178	120.58	0.00	0.00	0.00	120.58	65.65	0.00	0.00	0.00	65.65	45.55%
49360	Restroom	R	320	131.93	0.00	0.00	0.00	131.93	52.07	0.00	0.00	0.00	52.07	60.53%
49421	Restroom	R	320	131.15	0.00	0.00	0.00	131.15	51.44	0.00	0.00	0.00	51.44	60.78%
49563	Copy Rm	C	260	78.64	0.00	0.00	0.00	78.64	34.76	0.00	0.00	0.00	34.76	55.80%
49475	Private Office	PO	260	87.49	0.00	0.00	0.00	87.49	36.73	0.00	0.00	0.00	36.73	58.02%
49579	Meeting Rooms	M	260	67.58	0.00	0.00	0.00	67.58	15.45	0.00	0.00	0.00	15.45	77.14%
49436	Meeting Rooms	M	260	68.18	0.00	0.00	0.00	68.18	20.07	0.00	0.00	0.00	20.07	70.56%
49495	Meeting Rooms	M	260	43.43	0.00	0.00	0.00	43.43	8.01	0.00	0.00	0.00	8.01	81.56%
49376	Meeting Rooms	M	780	58.50	0.00	0.00	0.00	58.50	18.87	0.00	0.00	0.00	18.87	67.74%
49445	Private Office	PO	260	56.82	0.00	0.00	0.00	56.82	34.78	0.00	0.00	0.00	34.78	38.79%
49391	Open Space	OS	267	77.74	0.00	0.00	0.00	77.74	42.51	0.00	0.00	0.00	42.51	45.32%
49560	Open Space	OS	89	83.48	0.00	0.00	0.00	83.48	65.05	0.00	0.00	0.00	65.05	22.08%
49496	Open Space	OS	89	81.42	0.00	0.00	0.00	81.42	57.27	0.00	0.00	0.00	57.27	29.66%
49578	Kitchen	K	178	167.98	0.00	0.00	0.00	167.98	67.57	0.00	0.00	0.00	67.57	59.77%
49568	Meeting Rooms	M	1040	41.59	0.00	0.00	0.00	41.59	12.07	0.00	0.00	0.00	12.07	70.98%
49573	Open Space	OS	3900	83.43	0.00	0.00	0.00	83.43	73.66	0.00	0.00	0.00	73.66	11.71%
49564	Open Space	OS	623	167.93	0.00	0.00	0.00	167.93	73.67	0.00	0.00	0.00	73.67	56.13%
49559	Open Space	OS	623	83.26	0.00	0.00	0.00	83.26	71.06	0.00	0.00	0.00	71.06	14.65%
49482	Open Space	OS	3900	83.48	0.00	0.00	0.00	83.48	75.75	0.00	0.00	0.00	75.75	9.26%
49430	Restroom	R	320	153.17	0.00	0.00	0.00	153.17	49.61	0.00	0.00	0.00	49.61	67.61%
49491	Restroom	R	320	142.96	0.00	0.00	0.00	142.96	32.91	0.00	0.00	0.00	32.91	76.98%
49387	Restroom	R	34	135.98	0.00	0.00	0.00	135.98	55.20	0.00	0.00	0.00	55.20	59.41%

Building Summary Totals Building type:Office. Building size:more than 1,000K. Shifts:1 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	6	1650	107	0	0	0	107	62	0	0	0	62
Meeting Rooms	M	8	6232	316	0	0	0	316	79	0	0	0	79
Open Space	OS	13	17719	1641	0	0	0	1641	1105	0	0	0	1105
Restroom	R	8	1992	260	0	0	0	260	92	0	0	0	92
Storage	S	3	3267	248	0	0	0	248	69	0	0	0	69
Kitchen	K	2	498	49	0	0	0	49	18	0	0	0	18
Copy Rm	C	3	2040	225	0	0	0	225	87	0	0	0	87
Building Totals			33398	2846			0	2846	1513			0	1513