


Area Type Averages

Building type:Office. Building size:more than 1,000K. Shifts:1

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	9	357	28.19	0.00	0.00	0.00	28.19	21.97	0.00	0.00	0.00	21.97	22.06%
Meeting Rooms	M	7	725	25.11	0.00	0.00	0.00	25.11	8.58	0.00	0.00	0.00	8.58	65.83%
Restroom	R	14	335	126.24	0.00	0.00	0.00	126.24	31.13	0.00	0.00	0.00	31.13	75.34%
Storage	S	7	263	108.68	0.00	0.00	0.00	108.68	12.42	0.00	0.00	0.00	12.42	88.57%
Hallway	H	12	647	130.16	0.00	0.00	0.00	130.16	55.87	0.00	0.00	0.00	55.87	57.08%
Janitor Closet	J	6	143	56.95	0.00	0.00	0.00	56.95	9.23	0.00	0.00	0.00	9.23	83.79%
Kitchen	K	3	507	38.48	0.00	0.00	0.00	38.48	24.23	0.00	0.00	0.00	24.23	37.03%
Copy Rm	C	5	859	80.23	0.00	0.00	0.00	80.23	55.81	0.00	0.00	0.00	55.81	30.44%
Cafeteria	CF	5	376	59.22	0.00	0.00	0.00	59.22	36.06	0.00	0.00	0.00	36.06	39.11%
Open Office	OO	6	969	39.67	0.00	0.00	0.00	39.67	27.94	0.00	0.00	0.00	27.94	29.57%
Stairwell	ST	6	2298	168.00	0.00	0.00	0.00	168.00	8.86	0.00	0.00	0.00	8.86	94.73%
Main Lobby	ML	8	670	68.77	0.00	0.00	0.00	68.77	33.64	0.00	0.00	0.00	33.64	51.08%
Building Average			56099	98.03			0.00	98.03	27.34			0.00	27.34	72.11%



Data Logger Detail Building type:Office. Building size:more than 1,000K. Shifts:1 Page 1 of 2

All Loggers Listed			Hours Installed						Lights On						Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
21447	Kitchen	K	635.48	635.48	0.00	0.00	0.00	10/25/05 11:32	11/20/05 11:00	185.27	0.00	0.00	0.00	185.27	128.33	0.00	0.00	0.00	128.33
22771	Private Office	PO	635.45	635.45	0.00	0.00	0.00	10/25/05 11:34	11/20/05 11:00	127.07	0.00	0.00	0.00	127.07	113.27	0.00	0.00	0.00	113.27
23416	Private Office	PO	635.45	635.45	0.00	0.00	0.00	10/25/05 11:34	11/20/05 11:00	180.90	0.00	0.00	0.00	180.90	147.10	0.00	0.00	0.00	147.10
24634	Meeting Rooms	M	635.27	635.27	0.00	0.00	0.00	10/25/05 11:45	11/20/05 11:00	75.07	0.00	0.00	0.00	75.07	37.03	0.00	0.00	0.00	37.03
22108	Janitor Closet	J	635.13	635.13	0.00	0.00	0.00	10/25/05 11:53	11/20/05 11:00	635.13	0.00	0.00	0.00	635.13	2.70	0.00	0.00	0.00	2.70
20784	Hallway	H	633.80	633.80	0.00	0.00	0.00	10/25/05 1:13 PM	11/20/05 11:00	462.82	0.00	0.00	0.00	462.82	249.93	0.00	0.00	0.00	249.93
22955	Storage	S	633.57	633.57	0.00	0.00	0.00	10/25/05 1:27 PM	11/20/05 11:00	495.23	0.00	0.00	0.00	495.23	222.15	0.00	0.00	0.00	222.15
23156	Storage	S	633.45	633.45	0.00	0.00	0.00	10/25/05 1:34 PM	11/20/05 11:00	104.63	0.00	0.00	0.00	104.63	8.77	0.00	0.00	0.00	8.77
22504	Cafeteria	CF	633.18	633.18	0.00	0.00	0.00	10/25/05 1:50 PM	11/20/05 11:00	354.72	0.00	0.00	0.00	354.72	221.82	0.00	0.00	0.00	221.82
23008	Cafeteria	CF	633.82	633.82	0.00	0.00	0.00	10/25/05 1:12 PM	11/20/05 11:00	1.67	0.00	0.00	0.00	1.67	1.20	0.00	0.00	0.00	1.20
22460	Restroom	R	633.23	633.23	0.00	0.00	0.00	10/25/05 1:47 PM	11/20/05 11:00	226.82	0.00	0.00	0.00	226.82	136.35	0.00	0.00	0.00	136.35
21558	Restroom	R	633.22	633.22	0.00	0.00	0.00	10/25/05 1:48 PM	11/20/05 11:00	227.33	0.00	0.00	0.00	227.33	172.77	0.00	0.00	0.00	172.77
20542	Storage	S	23.28	23.28	0.00	0.00	0.00	10/25/05 11:55	10/26/05 11:11	23.27	0.00	0.00	0.00	23.27	0.03	0.00	0.00	0.00	0.03
22002	Restroom	R	635.57	635.57	0.00	0.00	0.00	10/25/05 11:27	11/20/05 11:00	635.57	0.00	0.00	0.00	635.57	108.78	0.00	0.00	0.00	108.78
22942	Restroom	R	635.55	635.55	0.00	0.00	0.00	10/25/05 11:28	11/20/05 11:00	290.12	0.00	0.00	0.00	290.12	154.00	0.00	0.00	0.00	154.00
22692	Meeting Rooms	M	589.98	589.98	0.00	0.00	0.00	10/25/05 7:57 AM	11/18/05 9:55 PM	64.93	0.00	0.00	0.00	64.93	13.37	0.00	0.00	0.00	13.37
20512	Copy Rm	C	639.02	639.02	0.00	0.00	0.00	10/25/05 8:00 AM	11/20/05 11:00	220.00	0.00	0.00	0.00	220.00	140.97	0.00	0.00	0.00	140.97
22544	Open Office	OO	639.12	639.12	0.00	0.00	0.00	10/25/05 7:54 AM	11/20/05 11:00	227.33	0.00	0.00	0.00	227.33	200.07	0.00	0.00	0.00	200.07
23420	Private Office	PO	630.53	630.53	0.00	0.00	0.00	10/25/05 8:30 AM	11/20/05 3:01 PM	119.97	0.00	0.00	0.00	119.97	102.30	0.00	0.00	0.00	102.30
22317	Private Office	PO	638.15	638.15	0.00	0.00	0.00	10/25/05 8:52 AM	11/20/05 11:00	50.72	0.00	0.00	0.00	50.72	45.22	0.00	0.00	0.00	45.22
20783	Meeting Rooms	M	638.12	638.12	0.00	0.00	0.00	10/25/05 8:54 AM	11/20/05 11:00	154.43	0.00	0.00	0.00	154.43	76.63	0.00	0.00	0.00	76.63
22153	Main Lobby	ML	638.00	638.00	0.00	0.00	0.00	10/25/05 9:01 AM	11/20/05 11:00	638.00	0.00	0.00	0.00	638.00	141.50	0.00	0.00	0.00	141.50
24629	Hallway	H	638.47	638.47	0.00	0.00	0.00	10/25/05 8:33 AM	11/20/05 11:00	638.47	0.00	0.00	0.00	638.47	193.33	0.00	0.00	0.00	193.33
21685	Cafeteria	CF	658.03	658.03	0.00	0.00	0.00	10/24/05 12:59	11/20/05 11:00	254.90	0.00	0.00	0.00	254.90	181.40	0.00	0.00	0.00	181.40
21177	Hallway	H	659.60	659.60	0.00	0.00	0.00	10/24/05 11:25	11/20/05 11:00	659.60	0.00	0.00	0.00	659.60	252.97	0.00	0.00	0.00	252.97
24639	Main Lobby	ML	728.07	728.07	0.00	0.00	0.00	10/21/05 2:57 PM	11/20/05 11:00	239.90	0.00	0.00	0.00	239.90	160.60	0.00	0.00	0.00	160.60
22557	Copy Rm	C	728.30	728.30	0.00	0.00	0.00	10/21/05 2:43 PM	11/20/05 11:00	365.48	0.00	0.00	0.00	365.48	179.93	0.00	0.00	0.00	179.93
21649	Copy Rm	C	1.98	1.98	0.00	0.00	0.00	10/21/05 2:44 PM	10/21/05 4:42 PM	1.97	0.00	0.00	0.00	1.97	1.70	0.00	0.00	0.00	1.70
23373	Meeting Rooms	M	732.08	732.08	0.00	0.00	0.00	10/21/05 10:56	11/20/05 11:00	240.97	0.00	0.00	0.00	240.97	23.83	0.00	0.00	0.00	23.83
21272	Restroom	R	730.00	730.00	0.00	0.00	0.00	10/21/05 1:01 PM	11/20/05 11:00	730.00	0.00	0.00	0.00	730.00	157.73	0.00	0.00	0.00	157.73
23125	Hallway	H	729.85	729.85	0.00	0.00	0.00	10/21/05 1:10 PM	11/20/05 11:00	729.85	0.00	0.00	0.00	729.85	284.80	0.00	0.00	0.00	284.80
22681	Janitor Closet	J	729.92	729.92	0.00	0.00	0.00	10/21/05 1:06 PM	11/20/05 11:00	4.93	0.00	0.00	0.00	4.93	0.73	0.00	0.00	0.00	0.73
20770	Stock Room	ST	732.32	732.32	0.00	0.00	0.00	10/21/05 10:42	11/20/05 11:00	732.32	0.00	0.00	0.00	732.32	116.60	0.00	0.00	0.00	116.60
22734	Janitor Closet	J	734.18	734.18	0.00	0.00	0.00	10/21/05 8:50 AM	11/20/05 11:00	140.73	0.00	0.00	0.00	140.73	41.40	0.00	0.00	0.00	41.40
24333	Hallway	H	734.12	734.12	0.00	0.00	0.00	10/21/05 8:54 AM	11/20/05 11:00	208.73	0.00	0.00	0.00	208.73	119.87	0.00	0.00	0.00	119.87
22855	Janitor Closet	J	734.05	734.05	0.00	0.00	0.00	10/21/05 8:58 AM	11/20/05 11:00	330.60	0.00	0.00	0.00	330.60	152.23	0.00	0.00	0.00	152.23
21025	Cafeteria	CF	734.07	734.07	0.00	0.00	0.00	10/21/05 8:57 AM	11/20/05 11:00	458.53	0.00	0.00	0.00	458.53	212.00	0.00	0.00	0.00	212.00
23051	Storage	S	726.72	726.72	0.00	0.00	0.00	10/21/05 4:18 PM	11/20/05 11:00	137.97	0.00	0.00	0.00	137.97	32.33	0.00	0.00	0.00	32.33
24349	Open Office	OO	777.10	777.10	0.00	0.00	0.00	10/19/05 1:55 PM	11/20/05 11:00	315.05	0.00	0.00	0.00	315.05	215.40	0.00	0.00	0.00	215.40
23690	Open Office	OO	777.03	777.03	0.00	0.00	0.00	10/19/05 1:59 PM	11/20/05 11:00	144.63	0.00	0.00	0.00	144.63	103.23	0.00	0.00	0.00	103.23
22291	Hallway	H	776.82	776.82	0.00	0.00	0.00	10/19/05 2:12 PM	11/20/05 11:00	265.07	0.00	0.00	0.00	265.07	101.73	0.00	0.00	0.00	101.73
22795	Private Office	PO	719.90	719.90	0.00	0.00	0.00	10/19/05 1:13 PM	11/18/05 1:06 PM	159.20	0.00	0.00	0.00	159.20	124.80	0.00	0.00	0.00	124.80
20525	Open Office	OO	777.83	777.83	0.00	0.00	0.00	10/19/05 1:11 PM	11/20/05 11:00	175.35	0.00	0.00	0.00	175.35	165.78	0.00	0.00	0.00	165.78
24173	Private Office	PO	776.77	776.77	0.00	0.00	0.00	10/19/05 2:15 PM	11/20/05 11:00	13.07	0.00	0.00	0.00	13.07	4.13	0.00	0.00	0.00	4.13
23345	Open Office	OO	777.73	777.73	0.00	0.00	0.00	10/19/05 1:17 PM	11/20/05 11:00	27.47	0.00	0.00	0.00	27.47	16.57	0.00	0.00	0.00	16.57
23444	Kitchen	K	683.23	683.23	0.00	0.00	0.00	10/19/05 1:35 PM	11/17/05 12:48	33.57	0.00	0.00	0.00	33.57	20.17	0.00	0.00	0.00	20.17
23919	Restroom	R	777.95	777.95	0.00	0.00	0.00	10/19/05 1:04 PM	11/20/05 11:00	553.67	0.00	0.00	0.00	553.67	51.63	0.00	0.00	0.00	51.63
24051	Restroom	R	777.97	777.97	0.00	0.00	0.00	10/19/05 1:03 PM	11/20/05 11:00	473.70	0.00	0.00	0.00	473.70	68.53	0.00	0.00	0.00	68.53
23819	Main Lobby	ML	779.78	779.78	0.00	0.00	0.00	10/19/05 11:14	11/20/05 11:00	214.47	0.00	0.00	0.00	214.47	136.30	0.00	0.00	0.00	136.30
23321	Meeting Rooms	M	780.65	780.65	0.00	0.00	0.00	10/19/05 10:22	11/20/05 11:00	66.83	0.00	0.00	0.00	66.83	20.33	0.00	0.00	0.00	20.33
23583	Main Lobby	ML	780.60	780.60	0.00	0.00	0.00	10/19/05 10:25	11/20/05 11:00	127.60	0.00	0.00	0.00	127.60	74.63	0.00	0.00	0.00	74.63
24174	Hallway	H	780.97	780.97	0.00	0.00	0.00	10/19/05 10:03	11/20/05 11:00	368.00	0.00	0.00	0.00	368.00	288.67	0.00	0.00	0.00	288.67
23059	Hallway	H	780.97	780.97	0.00	0.00	0.00	10/19/05 10:03	11/20/05 11:00	368.02	0.00	0.00	0.00	368.02	243.30	0.00	0.00	0.00	243.30
21835	Restroom	R	781.02	781.02	0.00	0.00	0.00	10/19/05 10:00	11/20/05 11:00	781.02	0.00	0.00	0.00	781.02	209.77	0.00	0.00	0.00	209.77
23798	Restroom	R	781.00	781.00	0.00	0.00	0.00	10/19/05 10:01	11/20/05 11:00	781.00	0.00	0.00	0.00	781.00	165.43	0.00	0.00	0.00	165.43
24025	Main Lobby	ML	781.32	781.32	0.00	0.00	0.00	10/19/05 9:42 AM	11/20/05 11:00	365.97	0.00	0.00	0.00	365.97	239.43	0.00	0.00	0.00	239.43
23510	Main Lobby	ML	782.08	782.08	0.00	0.00	0.00	10/19/05 8:56 AM	11/20/05 11:00	399.92	0.00	0.00	0.00	399.92	131.53	0.00	0.00	0.00	131.53
24129	Storage	S	782.03	782.03															

Data Logger Detail Building type:Office. Building size:more than 1,000K. Shifts:1 Page 2 of 2

22746	Restroom	R	632.97	632.97	0.00	0.00	0.00	10/25/05 2:03 PM	11/20/05 11:00	632.97	0.00	0.00	0.00	632.97	111.83	0.00	0.00	0.00	111.83
20795	Stock Room	ST	632.23	632.23	0.00	0.00	0.00	10/25/05 2:47 PM	11/20/05 11:00	632.23	0.00	0.00	0.00	632.23	10.17	0.00	0.00	0.00	10.17
21097	Janitor Closet	J	632.32	632.32	0.00	0.00	0.00	10/25/05 2:42 PM	11/20/05 11:00	46.33	0.00	0.00	0.00	46.33	35.67	0.00	0.00	0.00	35.67
23161	Restroom	R	632.97	632.97	0.00	0.00	0.00	10/25/05 2:03 PM	11/20/05 11:00	632.97	0.00	0.00	0.00	632.97	142.05	0.00	0.00	0.00	142.05
22464	Stock Room	ST	729.52	729.52	0.00	0.00	0.00	10/21/05 1:30 PM	11/20/05 11:00	729.52	0.00	0.00	0.00	729.52	19.17	0.00	0.00	0.00	19.17
24144	Stock Room	ST	777.28	777.28	0.00	0.00	0.00	10/19/05 1:44 PM	11/20/05 11:00	777.28	0.00	0.00	0.00	777.28	13.07	0.00	0.00	0.00	13.07
24119	Stock Room	ST	782.25	782.25	0.00	0.00	0.00	10/19/05 8:46 AM	11/20/05 11:00	782.25	0.00	0.00	0.00	782.25	17.30	0.00	0.00	0.00	17.30
21320	Stock Room	ST	732.40	732.40	0.00	0.00	0.00	10/21/05 10:37	11/20/05 11:00	732.40	0.00	0.00	0.00	732.40	55.60	0.00	0.00	0.00	55.60

Normalized Data Logger Detail Building type:Office. Building size:more than 1,000K. Shifts:1 Page 1 of 2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
21447	Kitchen	K	480	48.98	0.00	0.00	0.00	48.98	33.93	0.00	0.00	0.00	33.93	30.73%
22771	Private Office	PO	640	33.59	0.00	0.00	0.00	33.59	29.95	0.00	0.00	0.00	29.95	10.84%
23416	Private Office	PO	320	47.83	0.00	0.00	0.00	47.83	38.89	0.00	0.00	0.00	38.89	18.69%
24634	Meeting Rooms	M	780	19.85	0.00	0.00	0.00	19.85	9.79	0.00	0.00	0.00	9.79	50.68%
22108	Janitor Closet	J	60	168.00	0.00	0.00	0.00	168.00	0.71	0.00	0.00	0.00	0.71	99.58%
20784	Hallway	H	420	122.68	0.00	0.00	0.00	122.68	66.25	0.00	0.00	0.00	66.25	46.00%
22955	Storage	S	300	131.32	0.00	0.00	0.00	131.32	58.91	0.00	0.00	0.00	58.91	55.14%
23156	Storage	S	356	27.75	0.00	0.00	0.00	27.75	2.33	0.00	0.00	0.00	2.33	91.60%
22504	Cafeteria	CF	890	94.12	0.00	0.00	0.00	94.12	58.85	0.00	0.00	0.00	58.85	37.47%
23008	Cafeteria	CF	89	0.44	0.00	0.00	0.00	0.44	0.32	0.00	0.00	0.00	0.32	27.27%
22460	Restroom	R	870	60.18	0.00	0.00	0.00	60.18	36.17	0.00	0.00	0.00	36.17	39.90%
21558	Restroom	R	870	60.31	0.00	0.00	0.00	60.31	45.84	0.00	0.00	0.00	45.84	23.99%
20542	Storage	S	200	167.88	0.00	0.00	0.00	167.88	0.24	0.00	0.00	0.00	0.24	99.86%
22002	Restroom	R	300	168.00	0.00	0.00	0.00	168.00	28.75	0.00	0.00	0.00	28.75	82.89%
22942	Restroom	R	240	76.69	0.00	0.00	0.00	76.69	40.71	0.00	0.00	0.00	40.71	46.92%
22692	Meeting Rooms	M	800	18.49	0.00	0.00	0.00	18.49	3.81	0.00	0.00	0.00	3.81	79.39%
20512	Copy Rm	C	520	57.84	0.00	0.00	0.00	57.84	37.06	0.00	0.00	0.00	37.06	35.93%
22544	Open Office	OO	1300	59.76	0.00	0.00	0.00	59.76	52.59	0.00	0.00	0.00	52.59	12.00%
23420	Private Office	PO	260	31.96	0.00	0.00	0.00	31.96	27.26	0.00	0.00	0.00	27.26	14.71%
22317	Private Office	PO	260	13.35	0.00	0.00	0.00	13.35	11.90	0.00	0.00	0.00	11.90	10.86%
20783	Meeting Rooms	M	910	40.66	0.00	0.00	0.00	40.66	20.18	0.00	0.00	0.00	20.18	50.37%
22153	Main Lobby	ML	480	168.00	0.00	0.00	0.00	168.00	37.26	0.00	0.00	0.00	37.26	77.82%
24629	Hallway	H	480	168.00	0.00	0.00	0.00	168.00	50.87	0.00	0.00	0.00	50.87	69.72%
21685	Cafeteria	CF	80	65.08	0.00	0.00	0.00	65.08	46.31	0.00	0.00	0.00	46.31	28.84%
21177	Hallway	H	1920	168.00	0.00	0.00	0.00	168.00	64.43	0.00	0.00	0.00	64.43	61.65%
24639	Main Lobby	ML	1050	55.36	0.00	0.00	0.00	55.36	37.06	0.00	0.00	0.00	37.06	33.06%
22557	Copy Rm	C	1040	84.31	0.00	0.00	0.00	84.31	41.51	0.00	0.00	0.00	41.51	50.77%
21649	Copy Rm	C	650	166.59	0.00	0.00	0.00	166.59	144.00	0.00	0.00	0.00	144.00	13.56%
23373	Meeting Rooms	M	800	55.30	0.00	0.00	0.00	55.30	5.47	0.00	0.00	0.00	5.47	90.11%
21272	Restroom	R	225	168.00	0.00	0.00	0.00	168.00	36.30	0.00	0.00	0.00	36.30	78.39%
23125	Hallway	H	600	168.00	0.00	0.00	0.00	168.00	65.56	0.00	0.00	0.00	65.56	60.98%
22681	Janitor Closet	J	75	1.14	0.00	0.00	0.00	1.14	0.17	0.00	0.00	0.00	0.17	85.09%
20770	Stock Room	ST	1150	168.00	0.00	0.00	0.00	168.00	26.75	0.00	0.00	0.00	26.75	84.08%
22734	Janitor Closet	J	240	32.20	0.00	0.00	0.00	32.20	9.47	0.00	0.00	0.00	9.47	70.59%
24333	Hallway	H	456	47.77	0.00	0.00	0.00	47.77	27.43	0.00	0.00	0.00	27.43	42.58%
22855	Janitor Closet	J	320	75.66	0.00	0.00	0.00	75.66	34.84	0.00	0.00	0.00	34.84	53.95%
21025	Cafeteria	CF	342	104.94	0.00	0.00	0.00	104.94	48.52	0.00	0.00	0.00	48.52	53.76%
23051	Storage	S	120	31.89	0.00	0.00	0.00	31.89	7.47	0.00	0.00	0.00	7.47	76.58%
24349	Open Office	OO	1170	68.11	0.00	0.00	0.00	68.11	46.57	0.00	0.00	0.00	46.57	31.63%
23690	Open Office	OO	1068	31.27	0.00	0.00	0.00	31.27	22.32	0.00	0.00	0.00	22.32	28.62%
22291	Hallway	H	1040	57.33	0.00	0.00	0.00	57.33	22.00	0.00	0.00	0.00	22.00	61.63%
22795	Private Office	PO	480	37.15	0.00	0.00	0.00	37.15	29.12	0.00	0.00	0.00	29.12	21.62%
20525	Open Office	OO	800	37.87	0.00	0.00	0.00	37.87	35.81	0.00	0.00	0.00	35.81	5.44%
24173	Private Office	PO	178	2.83	0.00	0.00	0.00	2.83	0.89	0.00	0.00	0.00	0.89	68.55%
23345	Open Office	OO	356	5.93	0.00	0.00	0.00	5.93	3.58	0.00	0.00	0.00	3.58	39.63%
23444	Kitchen	K	260	8.25	0.00	0.00	0.00	8.25	4.96	0.00	0.00	0.00	4.96	39.88%
23919	Restroom	R	120	119.57	0.00	0.00	0.00	119.57	11.15	0.00	0.00	0.00	11.15	90.67%
24051	Restroom	R	120	102.29	0.00	0.00	0.00	102.29	14.80	0.00	0.00	0.00	14.80	85.53%
23819	Main Lobby	ML	540	46.21	0.00	0.00	0.00	46.21	29.37	0.00	0.00	0.00	29.37	36.44%
23321	Meeting Rooms	M	520	14.38	0.00	0.00	0.00	14.38	4.38	0.00	0.00	0.00	4.38	69.54%

Normalized Data Logger Detail Building type:Office. Building size:more than 1,000K. Shifts:1 Page 2 of 2

23583	Main Lobby	ML	650	27.46	0.00	0.00	0.00	27.46	16.06	0.00	0.00	0.00	16.06	41.51%
24174	Hallway	H	180	79.16	0.00	0.00	0.00	79.16	62.10	0.00	0.00	0.00	62.10	21.55%
23059	Hallway	H	540	79.17	0.00	0.00	0.00	79.17	52.34	0.00	0.00	0.00	52.34	33.89%
21835	Restroom	R	120	168.00	0.00	0.00	0.00	168.00	45.12	0.00	0.00	0.00	45.12	73.14%
23798	Restroom	R	180	168.00	0.00	0.00	0.00	168.00	35.59	0.00	0.00	0.00	35.59	78.82%
24025	Main Lobby	ML	570	78.69	0.00	0.00	0.00	78.69	51.48	0.00	0.00	0.00	51.48	34.58%
23510	Main Lobby	ML	228	85.91	0.00	0.00	0.00	85.91	28.25	0.00	0.00	0.00	28.25	67.12%
24129	Storage	S	228	65.94	0.00	0.00	0.00	65.94	2.35	0.00	0.00	0.00	2.35	96.44%
21824	Hallway	H	267	168.00	0.00	0.00	0.00	168.00	51.79	0.00	0.00	0.00	51.79	69.17%
21576	Meeting Rooms	M	485	8.81	0.00	0.00	0.00	8.81	7.25	0.00	0.00	0.00	7.25	17.71%
24685	Copy Rm	C	390	31.21	0.00	0.00	0.00	31.21	9.01	0.00	0.00	0.00	9.01	71.13%
22393	Main Lobby	ML	1040	47.47	0.00	0.00	0.00	47.47	43.12	0.00	0.00	0.00	43.12	9.16%
21711	Private Office	PO	260	28.84	0.00	0.00	0.00	28.84	20.08	0.00	0.00	0.00	20.08	30.37%
24337	Kitchen	K	780	58.21	0.00	0.00	0.00	58.21	33.81	0.00	0.00	0.00	33.81	41.92%
22887	Janitor Closet	J	60	52.39	0.00	0.00	0.00	52.39	0.68	0.00	0.00	0.00	0.68	98.70%
23761	Restroom	R	160	4.29	0.00	0.00	0.00	4.29	2.68	0.00	0.00	0.00	2.68	37.53%
22844	Meeting Rooms	M	780	18.26	0.00	0.00	0.00	18.26	9.17	0.00	0.00	0.00	9.17	49.78%
24338	Copy Rm	C	1694	61.22	0.00	0.00	0.00	61.22	47.45	0.00	0.00	0.00	47.45	22.49%
24306	Private Office	PO	640	42.49	0.00	0.00	0.00	42.49	27.79	0.00	0.00	0.00	27.79	34.60%
21383	Cafeteria	CF	480	31.52	0.00	0.00	0.00	31.52	26.32	0.00	0.00	0.00	26.32	16.50%
24304	Open Office	OO	1120	35.09	0.00	0.00	0.00	35.09	6.76	0.00	0.00	0.00	6.76	80.74%
23730	Hallway	H	240	168.00	0.00	0.00	0.00	168.00	70.89	0.00	0.00	0.00	70.89	57.80%
24321	Hallway	H	420	167.75	0.00	0.00	0.00	167.75	71.66	0.00	0.00	0.00	71.66	57.28%
23002	Restroom	R	180	168.00	0.00	0.00	0.00	168.00	37.69	0.00	0.00	0.00	37.69	77.57%
22084	Restroom	R	180	168.00	0.00	0.00	0.00	168.00	33.67	0.00	0.00	0.00	33.67	79.96%
23441	Storage	S	100	167.99	0.00	0.00	0.00	167.99	0.09	0.00	0.00	0.00	0.09	99.95%
22246	Storage	S	534	168.00	0.00	0.00	0.00	168.00	15.56	0.00	0.00	0.00	15.56	90.74%
22889	Main Lobby	ML	801	41.04	0.00	0.00	0.00	41.04	26.52	0.00	0.00	0.00	26.52	35.38%
23305	Private Office	PO	178	15.70	0.00	0.00	0.00	15.70	11.87	0.00	0.00	0.00	11.87	24.39%
23153	Hallway	H	1200	168.00	0.00	0.00	0.00	168.00	65.09	0.00	0.00	0.00	65.09	61.26%
22746	Restroom	R	480	168.00	0.00	0.00	0.00	168.00	29.68	0.00	0.00	0.00	29.68	82.33%
20795	Stock Room	ST	1150	168.00	0.00	0.00	0.00	168.00	2.70	0.00	0.00	0.00	2.70	98.39%
21097	Janitor Closet	J	100	12.31	0.00	0.00	0.00	12.31	9.48	0.00	0.00	0.00	9.48	22.99%
23161	Restroom	R	640	168.00	0.00	0.00	0.00	168.00	37.70	0.00	0.00	0.00	37.70	77.56%
22464	Stock Room	ST	2300	168.00	0.00	0.00	0.00	168.00	4.41	0.00	0.00	0.00	4.41	97.38%
24144	Stock Room	ST	4200	168.00	0.00	0.00	0.00	168.00	2.82	0.00	0.00	0.00	2.82	98.32%
24119	Stock Room	ST	2688	168.00	0.00	0.00	0.00	168.00	3.72	0.00	0.00	0.00	3.72	97.79%
21320	Stock Room	ST	2300	168.00	0.00	0.00	0.00	168.00	12.75	0.00	0.00	0.00	12.75	92.41%

Building Summary Totals Building type:Office. Building size:more than 1,000K. Shifts:1 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	9	3213	91	0	0	0	91	71	0	0	0	71
Meeting Rooms	M	7	5075	127	0	0	0	127	44	0	0	0	44
Restroom	R	14	4690	592	0	0	0	592	146	0	0	0	146
Storage	S	7	1841	200	0	0	0	200	23	0	0	0	23
Hallway	H	12	7764	1011	0	0	0	1011	434	0	0	0	434
Janitor Closet	J	6	858	49	0	0	0	49	8	0	0	0	8
Kitchen	K	3	1521	59	0	0	0	59	37	0	0	0	37
Copy Rm	C	5	4295	345	0	0	0	345	240	0	0	0	240
Cafeteria	CF	5	1880	111	0	0	0	111	68	0	0	0	68
Open Office	OO	6	5814	231	0	0	0	231	162	0	0	0	162
Stairwell	ST	6	13788	2316	0	0	0	2316	122	0	0	0	122
Main Lobby	ML	8	5360	369	0	0	0	369	180	0	0	0	180
Building Totals			56099	5500			0	5500	1534			0	1534