


Area Type Averages

Building type:Office. Building size:100K to less than 250K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav		
Open Office	00	4	7680	84.80	0.00	0.00	0.00	84.80	56.23	0.00	0.00	0.00	56.23	33.69%	
Building Average		30720	84.80				0.00	84.80	56.23				0.00	56.23	33.69%



Hours per Week for each Area Type

Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23451	Open Office	00	445.07	445.07	0.00	0.00	0.00	11/02/05 10:57	11/21/05 12:00	224.60	0.00	0.00	0.00	224.60	153.57	0.00	0.00	0.00	153.57
23082	Open Office	00	445.05	445.05	0.00	0.00	0.00	11/02/05 10:58	11/21/05 12:00	224.70	0.00	0.00	0.00	224.70	163.77	0.00	0.00	0.00	163.77
23048	Open Office	00	445.03	445.03	0.00	0.00	0.00	11/02/05 10:59	11/21/05 12:00	224.82	0.00	0.00	0.00	224.82	125.73	0.00	0.00	0.00	125.73
22070	Open Office	00	445.05	445.05	0.00	0.00	0.00	11/02/05 10:58	11/21/05 12:00	224.43	0.00	0.00	0.00	224.43	152.73	0.00	0.00	0.00	152.73

Normalized Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23451	Open Office	00	7680	84.78	0.00	0.00	0.00	84.78	57.97	0.00	0.00	0.00	57.97	31.62%
23082	Open Office	00	7680	84.82	0.00	0.00	0.00	84.82	61.82	0.00	0.00	0.00	61.82	27.12%
23048	Open Office	00	7680	84.87	0.00	0.00	0.00	84.87	47.46	0.00	0.00	0.00	47.46	44.08%
22070	Open Office	00	7680	84.72	0.00	0.00	0.00	84.72	57.65	0.00	0.00	0.00	57.65	31.95%

Building Summary Totals Building type:Office. Building size:100K to less than 250K. Shifts:1

Building Summary Totals				Lights On KWHR					Occupied KWHR					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	
Open Office		00	4	30720	2605	0	0	0	2605	1727	0	0	0	1727
Building Totals				30720	2605			0	2605	1727			0	1727