


# Area Type Averages

Building type:Office. Building size:100K to less than 250K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Restroom	R	5	184	134.06	0.00	0.00	134.06	46.71	0.00	0.00	0.00	46.71	65.16%	
Storage	S	1	952	124.67	0.00	0.00	124.67	7.80	0.00	0.00	0.00	7.80	93.74%	
Hallway	H	2	544	167.99	0.00	0.00	167.99	73.63	0.00	0.00	0.00	73.63	56.17%	
Copy Rm	C	3	317	77.02	0.00	0.00	77.02	29.27	0.00	0.00	0.00	29.27	62.00%	
Office	O	5	605	70.71	0.00	0.00	70.71	45.54	0.00	0.00	0.00	45.54	35.60%	
Open Office	OO	5	1210	79.02	0.00	0.00	79.02	30.14	0.00	0.00	0.00	30.14	61.86%	
Building Average			12986	91.64			0.00	91.64	36.84			0.00	36.84	59.80%



Hours per Week for each Area Type

Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:1 Page 1 of 1

All Loggers Listed			Hours Installed							Lights On					Occupied				
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
22481	Office	O	335.60	335.60	0.00	0.00	0.00	9/14/05 9:51 AM	9/28/05 9:26 AM	156.12	0.00	0.00	0.00	156.12	89.75	0.00	0.00	0.00	89.75
22170	Office	O	335.62	335.62	0.00	0.00	0.00	9/14/05 9:45 AM	9/28/05 9:21 AM	212.97	0.00	0.00	0.00	212.97	125.97	0.00	0.00	0.00	125.97
22104	Restroom	R	335.62	335.62	0.00	0.00	0.00	9/14/05 9:47 AM	9/28/05 9:23 AM	332.40	0.00	0.00	0.00	332.40	155.57	0.00	0.00	0.00	155.57
21819	Open Office	OO	335.25	335.25	0.00	0.00	0.00	9/14/05 10:40 AM	9/28/05 9:54 AM	173.70	0.00	0.00	0.00	173.70	103.93	0.00	0.00	0.00	103.93
22700	Copy Rm	C	335.30	335.30	0.00	0.00	0.00	9/14/05 10:48 AM	9/28/05 10:05 AM	172.60	0.00	0.00	0.00	172.60	27.23	0.00	0.00	0.00	27.23
20976	Copy Rm	C	335.32	335.32	0.00	0.00	0.00	9/14/05 10:50 AM	9/28/05 10:08 AM	171.83	0.00	0.00	0.00	171.83	33.73	0.00	0.00	0.00	33.73
22754	Storage	S	335.28	335.28	0.00	0.00	0.00	9/14/05 10:57 AM	9/28/05 10:13 AM	248.80	0.00	0.00	0.00	248.80	15.57	0.00	0.00	0.00	15.57
22419	Hallway	H	335.55	335.55	0.00	0.00	0.00	9/14/05 10:07 AM	9/28/05 9:39 AM	335.53	0.00	0.00	0.00	335.53	146.10	0.00	0.00	0.00	146.10
22664	Hallway	H	335.52	335.52	0.00	0.00	0.00	9/14/05 10:12 AM	9/28/05 9:42 AM	335.50	0.00	0.00	0.00	335.50	148.02	0.00	0.00	0.00	148.02
21110	Restroom	R	335.53	335.53	0.00	0.00	0.00	9/14/05 10:03 AM	9/28/05 9:34 AM	245.23	0.00	0.00	0.00	245.23	19.67	0.00	0.00	0.00	19.67
22971	Copy Rm	C	335.58	335.58	0.00	0.00	0.00	9/14/05 9:55 AM	9/28/05 9:29 AM	116.83	0.00	0.00	0.00	116.83	114.40	0.00	0.00	0.00	114.40
24706	Restroom	R	335.45	335.45	0.00	0.00	0.00	9/14/05 10:23 AM	9/28/05 9:49 AM	216.40	0.00	0.00	0.00	216.40	129.47	0.00	0.00	0.00	129.47
24682	Restroom	R	335.33	335.33	0.00	0.00	0.00	9/14/05 10:48 AM	9/28/05 10:07 AM	335.30	0.00	0.00	0.00	335.30	75.10	0.00	0.00	0.00	75.10
21186	Open Office	OO	335.27	335.27	0.00	0.00	0.00	9/14/05 10:42 AM	9/28/05 9:57 AM	173.72	0.00	0.00	0.00	173.72	68.42	0.00	0.00	0.00	68.42
21732	Open Office	OO	335.30	335.30	0.00	0.00	0.00	9/14/05 10:43 AM	9/28/05 10:00 AM	173.75	0.00	0.00	0.00	173.75	20.10	0.00	0.00	0.00	20.10
21622	Open Office	OO	358.27	358.27	0.00	0.00	0.00	9/14/05 10:45 AM	9/29/05 9:00 AM	75.33	0.00	0.00	0.00	75.33	4.87	0.00	0.00	0.00	4.87
21906	Open Office	OO	335.55	335.55	0.00	0.00	0.00	9/14/05 9:59 AM	9/28/05 9:31 AM	196.98	0.00	0.00	0.00	196.98	103.83	0.00	0.00	0.00	103.83
21384	Office	O	335.53	335.53	0.00	0.00	0.00	9/14/05 9:58 AM	9/28/05 9:29 AM	205.88	0.00	0.00	0.00	205.88	174.78	0.00	0.00	0.00	174.78
21224	Office	O	335.58	335.58	0.00	0.00	0.00	9/14/05 9:52 AM	9/28/05 9:26 AM	91.53	0.00	0.00	0.00	91.53	37.80	0.00	0.00	0.00	37.80
21184	Office	O	335.33	335.33	0.00	0.00	0.00	9/14/05 10:49 AM	9/28/05 10:08 AM	39.77	0.00	0.00	0.00	39.77	26.53	0.00	0.00	0.00	26.53
21037	Restroom	R	335.42	335.42	0.00	0.00	0.00	9/14/05 10:26 AM	9/28/05 9:50 AM	209.20	0.00	0.00	0.00	209.20	86.60	0.00	0.00	0.00	86.60

Normalized Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:1 Page 1 of 1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
22481	Office	O	1224	78.15	0.00	0.00	0.00	78.15	44.93	0.00	0.00	0.00	44.93	42.51%
22170	Office	O	544	106.60	0.00	0.00	0.00	106.60	63.06	0.00	0.00	0.00	63.06	40.84%
22104	Restroom	R	204	166.39	0.00	0.00	0.00	166.39	77.87	0.00	0.00	0.00	77.87	53.20%
21819	Open Office	OO	1360	87.04	0.00	0.00	0.00	87.04	52.08	0.00	0.00	0.00	52.08	40.17%
22700	Copy Rm	C	204	86.48	0.00	0.00	0.00	86.48	13.65	0.00	0.00	0.00	13.65	84.22%
20976	Copy Rm	C	204	86.09	0.00	0.00	0.00	86.09	16.90	0.00	0.00	0.00	16.90	80.37%
22754	Storage	S	952	124.67	0.00	0.00	0.00	124.67	7.80	0.00	0.00	0.00	7.80	93.74%
22419	Hallway	H	544	167.99	0.00	0.00	0.00	167.99	73.15	0.00	0.00	0.00	73.15	56.46%
22664	Hallway	H	544	167.99	0.00	0.00	0.00	167.99	74.11	0.00	0.00	0.00	74.11	55.88%
21110	Restroom	R	204	122.79	0.00	0.00	0.00	122.79	9.85	0.00	0.00	0.00	9.85	91.98%
22971	Copy Rm	C	544	58.49	0.00	0.00	0.00	58.49	57.27	0.00	0.00	0.00	57.27	2.09%
24706	Restroom	R	138	108.38	0.00	0.00	0.00	108.38	64.84	0.00	0.00	0.00	64.84	40.17%
24682	Restroom	R	204	167.98	0.00	0.00	0.00	167.98	37.62	0.00	0.00	0.00	37.62	77.60%
21186	Open Office	OO	1360	87.05	0.00	0.00	0.00	87.05	34.28	0.00	0.00	0.00	34.28	60.62%
21732	Open Office	OO	1360	87.06	0.00	0.00	0.00	87.06	10.07	0.00	0.00	0.00	10.07	88.43%
21622	Open Office	OO	1360	35.33	0.00	0.00	0.00	35.33	2.28	0.00	0.00	0.00	2.28	93.55%
21906	Open Office	OO	612	98.62	0.00	0.00	0.00	98.62	51.99	0.00	0.00	0.00	51.99	47.28%
21384	Office	O	612	103.08	0.00	0.00	0.00	103.08	87.51	0.00	0.00	0.00	87.51	15.10%
21224	Office	O	442	45.82	0.00	0.00	0.00	45.82	18.92	0.00	0.00	0.00	18.92	58.71%
21184	Office	O	204	19.92	0.00	0.00	0.00	19.92	13.29	0.00	0.00	0.00	13.29	33.28%
21037	Restroom	R	172	104.78	0.00	0.00	0.00	104.78	43.38	0.00	0.00	0.00	43.38	58.60%

Building Summary Totals Building type:Office. Building size:100K to less than 250K. Shifts:1 Page 1 of 1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	5	920	123	0	0	0	123	43	0	0	0	43
Storage	S	1	952	119	0	0	0	119	7	0	0	0	7
Hallway	H	2	1088	183	0	0	0	183	80	0	0	0	80
Copy Rm	C	3	951	73	0	0	0	73	28	0	0	0	28
Office	O	5	3025	214	0	0	0	214	138	0	0	0	138
Open Office	OO	5	6050	478	0	0	0	478	182	0	0	0	182
Building Totals			12986	1190			0	1190	478			0	478