


Area Type Averages

Building type:Office. Building size:100K to less than 250K. Shifts:2

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Meeting Rooms	M	1	130	167.95	0.00	0.00	0.00	167.95	55.89	0.00	0.00	0.00	55.89	66.72%
Restroom	R	4	316	88.33	0.00	0.00	0.00	88.33	36.94	0.00	0.00	0.00	36.94	58.18%
Mechanical Room /	MR	1	260	75.07	0.00	0.00	0.00	75.07	0.92	0.00	0.00	0.00	0.92	98.77%
Gym	G	1	1326	73.78	0.00	0.00	0.00	73.78	46.19	0.00	0.00	0.00	46.19	37.39%
Exam Room	EX	1	110	131.35	0.00	0.00	0.00	131.35	0.39	0.00	0.00	0.00	0.39	99.70%
Office	O	1	130	155.90	0.00	0.00	0.00	155.90	35.11	0.00	0.00	0.00	35.11	77.48%
Lobby	LB	5	119	108.71	0.00	0.00	0.00	108.71	30.69	0.00	0.00	0.00	30.69	71.77%
Building Average			3815	91.80			0.00	91.80	36.25			0.00	36.25	60.51%



Hours per Week for each Area Type

Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:2

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23630	Restroom	R	108.82	108.82	0.00	0.00	0.00	10/01/05 9:54 PM	10/06/05 10:42	94.00	0.00	0.00	0.00	94.00	20.10	0.00	0.00	0.00	20.10
23699	Lobby	LB	336.28	336.28	0.00	0.00	0.00	9/22/05 10:26 AM	10/06/05 10:42	147.03	0.00	0.00	0.00	147.03	86.80	0.00	0.00	0.00	86.80
23659	Restroom	R	336.37	336.37	0.00	0.00	0.00	9/22/05 10:21 AM	10/06/05 10:42	183.93	0.00	0.00	0.00	183.93	64.03	0.00	0.00	0.00	64.03
23667	Lobby	LB	336.23	336.23	0.00	0.00	0.00	9/22/05 10:28 AM	10/06/05 10:41	114.90	0.00	0.00	0.00	114.90	26.33	0.00	0.00	0.00	26.33
24595	Restroom	R	336.18	336.18	0.00	0.00	0.00	9/22/05 10:32 AM	10/06/05 10:42	112.63	0.00	0.00	0.00	112.63	76.33	0.00	0.00	0.00	76.33
23515	Restroom	R	336.15	336.15	0.00	0.00	0.00	9/22/05 10:33 AM	10/06/05 10:41	120.10	0.00	0.00	0.00	120.10	93.20	0.00	0.00	0.00	93.20
23629	Exam Room	EX	334.47	334.47	0.00	0.00	0.00	9/22/05 12:15 PM	10/06/05 10:42	261.50	0.00	0.00	0.00	261.50	0.77	0.00	0.00	0.00	0.77
23694	Lobby	LB	334.43	334.43	0.00	0.00	0.00	9/22/05 12:16 PM	10/06/05 10:41	153.10	0.00	0.00	0.00	153.10	93.23	0.00	0.00	0.00	93.23
23713	Lobby	LB	334.40	334.40	0.00	0.00	0.00	9/22/05 12:12 PM	10/06/05 10:35	334.38	0.00	0.00	0.00	334.38	59.53	0.00	0.00	0.00	59.53
23645	Lobby	LB	334.53	334.53	0.00	0.00	0.00	9/22/05 12:10 PM	10/06/05 10:41	334.13	0.00	0.00	0.00	334.13	40.20	0.00	0.00	0.00	40.20
23614	Mechanical Room / Storage	MR	336.58	336.58	0.00	0.00	0.00	9/22/05 10:07 AM	10/06/05 10:41	150.40	0.00	0.00	0.00	150.40	1.83	0.00	0.00	0.00	1.83
23641	Gym	G	336.55	336.55	0.00	0.00	0.00	9/22/05 10:10 AM	10/06/05 10:42	147.80	0.00	0.00	0.00	147.80	92.53	0.00	0.00	0.00	92.53
24164	Office	O	359.63	359.63	0.00	0.00	0.00	9/21/05 11:07 AM	10/06/05 10:44	333.73	0.00	0.00	0.00	333.73	75.17	0.00	0.00	0.00	75.17
23644	Meeting Rooms	M	336.67	336.67	0.00	0.00	0.00	9/22/05 10:02 AM	10/06/05 10:41	336.57	0.00	0.00	0.00	336.57	112.00	0.00	0.00	0.00	112.00

Normalized Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:2

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23630	Restroom	R	314	145.12	0.00	0.00	0.00	145.12	31.03	0.00	0.00	0.00	31.03	78.62%
23699	Lobby	LB	110	73.45	0.00	0.00	0.00	73.45	43.36	0.00	0.00	0.00	43.36	40.97%
23659	Restroom	R	288	91.87	0.00	0.00	0.00	91.87	31.98	0.00	0.00	0.00	31.98	65.19%
23667	Lobby	LB	110	57.41	0.00	0.00	0.00	57.41	13.16	0.00	0.00	0.00	13.16	77.08%
24595	Restroom	R	330	56.29	0.00	0.00	0.00	56.29	38.15	0.00	0.00	0.00	38.15	32.23%
23515	Restroom	R	330	60.02	0.00	0.00	0.00	60.02	46.58	0.00	0.00	0.00	46.58	22.39%
23629	Exam Room	EX	110	131.35	0.00	0.00	0.00	131.35	0.39	0.00	0.00	0.00	0.39	99.70%
23694	Lobby	LB	68	76.91	0.00	0.00	0.00	76.91	46.84	0.00	0.00	0.00	46.84	39.10%
23713	Lobby	LB	110	167.99	0.00	0.00	0.00	167.99	29.91	0.00	0.00	0.00	29.91	82.20%
23645	Lobby	LB	198	167.80	0.00	0.00	0.00	167.80	20.19	0.00	0.00	0.00	20.19	87.97%
23614	Mechanical	MR	260	75.07	0.00	0.00	0.00	75.07	0.92	0.00	0.00	0.00	0.92	98.77%
23641	Gym	G	1326	73.78	0.00	0.00	0.00	73.78	46.19	0.00	0.00	0.00	46.19	37.39%
24164	Office	O	130	155.90	0.00	0.00	0.00	155.90	35.11	0.00	0.00	0.00	35.11	77.48%
23644	Meeting Rooms	M	130	167.95	0.00	0.00	0.00	167.95	55.89	0.00	0.00	0.00	55.89	66.72%

Building Summary Totals Building type:Office. Building size:100K to less than 250K. Shifts:2

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Meeting Rooms	M	1	130	22	0	0	0	22	7	0	0	0	7
Restroom	R	4	1264	112	0	0	0	112	47	0	0	0	47
Mechanical Room /	MR	1	260	20	0	0	0	20	0	0	0	0	0
Gym	G	1	1326	98	0	0	0	98	61	0	0	0	61
Exam Room	EX	1	110	14	0	0	0	14	0	0	0	0	0
Office	O	1	130	20	0	0	0	20	5	0	0	0	5
Lobby	LB	5	595	65	0	0	0	65	18	0	0	0	18
Building Totals			3815	350			0	350	138				138