


Area Type Averages

Building type:Office. Building size:100K to less than 250K. Shifts:3

| Area Type Averages | | | | Normalized Weekly Lights On | | | | | Normalized Weekly Occupied | | | | | |
|--------------------|-----|-------|-------|-----------------------------|---------|---------|--------|--------|----------------------------|---------|---------|--------|--------|--|
| Area Type | Qty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | % sav | |
| Restroom | R | 3 | 173 | 42.18 | 0.00 | 0.00 | 42.18 | 40.24 | 0.00 | 0.00 | 0.00 | 40.24 | 4.60% | |
| Storage | S | 1 | 320 | 67.08 | 0.00 | 0.00 | 67.08 | 33.53 | 0.00 | 0.00 | 0.00 | 33.53 | 50.01% | |
| Hallway | H | 3 | 311 | 143.87 | 0.00 | 0.00 | 143.87 | 101.31 | 0.00 | 0.00 | 0.00 | 101.31 | 29.58% | |
| Copy Rm | C | 2 | 160 | 49.68 | 0.00 | 0.00 | 49.68 | 30.96 | 0.00 | 0.00 | 0.00 | 30.96 | 37.68% | |
| Office | O | 28 | 460 | 73.96 | 0.00 | 0.00 | 73.96 | 49.20 | 0.00 | 0.00 | 0.00 | 49.20 | 33.48% | |
| Computer Room | CP | 2 | 960 | 37.33 | 0.00 | 0.00 | 37.33 | 35.78 | 0.00 | 0.00 | 0.00 | 35.78 | 4.15% | |
| MultiPurpose Rm | MP | 2 | 100 | 96.42 | 0.00 | 0.00 | 96.42 | 36.34 | 0.00 | 0.00 | 0.00 | 36.34 | 62.31% | |
| Building Average | | | 17092 | 72.38 | | | 72.38 | 49.48 | | | 0.00 | 49.48 | 31.64% | |



Hours per Week for each Area Type

Data Logger Detail Building type:Office. Building size:100K to less than 250K. Shifts:3 Page 1 of 1

| All Loggers Listed | | | Hours Installed | | | | | Lights On | | | | | Occupied | | | | | | |
|--------------------|-----------------|----|-----------------|--------|------|---------|---------|------------------|-----------------|--------|------|---------|----------|--------|--------|------|---------|---------|--------|
| Logger | Area Type | Ty | Total | Peak | Off | Shldr 1 | Shldr 2 | Installed | Removed | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total |
| 21955 | Hallway | H | 485.82 | 485.82 | 0.00 | 0.00 | 0.00 | 9/08/05 3:12 PM | 9/28/05 9:00 PM | 415.65 | 0.00 | 0.00 | 0.00 | 415.65 | 289.47 | 0.00 | 0.00 | 0.00 | 289.47 |
| 21961 | Hallway | H | 485.80 | 485.80 | 0.00 | 0.00 | 0.00 | 9/08/05 3:13 PM | 9/28/05 9:00 PM | 416.17 | 0.00 | 0.00 | 0.00 | 416.17 | 294.13 | 0.00 | 0.00 | 0.00 | 294.13 |
| 22695 | Office | O | 468.30 | 468.30 | 0.00 | 0.00 | 0.00 | 9/09/05 8:43 AM | 9/28/05 9:00 PM | 454.97 | 0.00 | 0.00 | 0.00 | 454.97 | 397.50 | 0.00 | 0.00 | 0.00 | 397.50 |
| 21499 | Office | O | 468.33 | 468.33 | 0.00 | 0.00 | 0.00 | 9/09/05 8:41 AM | 9/28/05 9:00 PM | 393.13 | 0.00 | 0.00 | 0.00 | 393.13 | 345.53 | 0.00 | 0.00 | 0.00 | 345.53 |
| 23992 | Office | O | 468.32 | 468.32 | 0.00 | 0.00 | 0.00 | 9/09/05 8:42 AM | 9/28/05 9:00 PM | 375.57 | 0.00 | 0.00 | 0.00 | 375.57 | 258.78 | 0.00 | 0.00 | 0.00 | 258.78 |
| 21506 | Office | O | 468.03 | 468.03 | 0.00 | 0.00 | 0.00 | 9/09/05 8:59 AM | 9/28/05 9:00 PM | 169.32 | 0.00 | 0.00 | 0.00 | 169.32 | 157.97 | 0.00 | 0.00 | 0.00 | 157.97 |
| 21604 | MultiPurpose Rm | MP | 489.85 | 489.85 | 0.00 | 0.00 | 0.00 | 9/08/05 11:10 AM | 9/28/05 9:00 PM | 489.85 | 0.00 | 0.00 | 0.00 | 489.85 | 159.07 | 0.00 | 0.00 | 0.00 | 159.07 |
| 21741 | Office | O | 468.25 | 468.25 | 0.00 | 0.00 | 0.00 | 9/09/05 8:46 AM | 9/28/05 9:00 PM | 56.87 | 0.00 | 0.00 | 0.00 | 56.87 | 51.70 | 0.00 | 0.00 | 0.00 | 51.70 |
| 22892 | Office | O | 486.43 | 486.43 | 0.00 | 0.00 | 0.00 | 9/08/05 2:35 PM | 9/28/05 9:00 PM | 486.43 | 0.00 | 0.00 | 0.00 | 486.43 | 110.73 | 0.00 | 0.00 | 0.00 | 110.73 |
| 22131 | Office | O | 486.45 | 486.45 | 0.00 | 0.00 | 0.00 | 9/08/05 2:34 PM | 9/28/05 9:00 PM | 156.98 | 0.00 | 0.00 | 0.00 | 156.98 | 91.78 | 0.00 | 0.00 | 0.00 | 91.78 |
| 22706 | Office | O | 468.03 | 468.03 | 0.00 | 0.00 | 0.00 | 9/09/05 8:59 AM | 9/28/05 9:00 PM | 99.00 | 0.00 | 0.00 | 0.00 | 99.00 | 87.83 | 0.00 | 0.00 | 0.00 | 87.83 |
| 23311 | Office | O | 485.70 | 485.70 | 0.00 | 0.00 | 0.00 | 9/08/05 3:19 PM | 9/28/05 9:00 PM | 91.30 | 0.00 | 0.00 | 0.00 | 91.30 | 74.57 | 0.00 | 0.00 | 0.00 | 74.57 |
| 21441 | Office | O | 485.68 | 485.68 | 0.00 | 0.00 | 0.00 | 9/08/05 3:20 PM | 9/28/05 9:00 PM | 90.60 | 0.00 | 0.00 | 0.00 | 90.60 | 72.83 | 0.00 | 0.00 | 0.00 | 72.83 |
| 22059 | Computer Room | CP | 486.65 | 486.65 | 0.00 | 0.00 | 0.00 | 9/08/05 2:22 PM | 9/28/05 9:00 PM | 115.30 | 0.00 | 0.00 | 0.00 | 115.30 | 114.03 | 0.00 | 0.00 | 0.00 | 114.03 |
| 22355 | Copy Rm | C | 468.00 | 468.00 | 0.00 | 0.00 | 0.00 | 9/09/05 9:01 AM | 9/28/05 9:00 PM | 138.35 | 0.00 | 0.00 | 0.00 | 138.35 | 125.72 | 0.00 | 0.00 | 0.00 | 125.72 |
| 23894 | Office | O | 486.72 | 486.72 | 0.00 | 0.00 | 0.00 | 9/08/05 2:18 PM | 9/28/05 9:00 PM | 166.47 | 0.00 | 0.00 | 0.00 | 166.47 | 133.23 | 0.00 | 0.00 | 0.00 | 133.23 |
| 22522 | Office | O | 468.17 | 468.17 | 0.00 | 0.00 | 0.00 | 9/09/05 8:51 AM | 9/28/05 9:00 PM | 126.67 | 0.00 | 0.00 | 0.00 | 126.67 | 87.97 | 0.00 | 0.00 | 0.00 | 87.97 |
| 23684 | Office | O | 486.12 | 486.12 | 0.00 | 0.00 | 0.00 | 9/08/05 2:54 PM | 9/28/05 9:00 PM | 225.35 | 0.00 | 0.00 | 0.00 | 225.35 | 96.10 | 0.00 | 0.00 | 0.00 | 96.10 |
| 21966 | Office | O | 486.50 | 486.50 | 0.00 | 0.00 | 0.00 | 9/08/05 2:31 PM | 9/28/05 9:00 PM | 153.50 | 0.00 | 0.00 | 0.00 | 153.50 | 125.83 | 0.00 | 0.00 | 0.00 | 125.83 |
| 23662 | Office | O | 486.62 | 486.62 | 0.00 | 0.00 | 0.00 | 9/08/05 2:24 PM | 9/28/05 9:00 PM | 185.42 | 0.00 | 0.00 | 0.00 | 185.42 | 150.80 | 0.00 | 0.00 | 0.00 | 150.80 |
| 21644 | Office | O | 486.60 | 486.60 | 0.00 | 0.00 | 0.00 | 9/08/05 2:25 PM | 9/28/05 9:00 PM | 185.37 | 0.00 | 0.00 | 0.00 | 185.37 | 145.28 | 0.00 | 0.00 | 0.00 | 145.28 |
| 22029 | Hallway | H | 485.92 | 485.92 | 0.00 | 0.00 | 0.00 | 9/08/05 3:06 PM | 9/28/05 9:00 PM | 416.35 | 0.00 | 0.00 | 0.00 | 416.35 | 295.32 | 0.00 | 0.00 | 0.00 | 295.32 |
| 22000 | Office | O | 486.08 | 486.08 | 0.00 | 0.00 | 0.00 | 9/08/05 2:56 PM | 9/28/05 9:00 PM | 220.53 | 0.00 | 0.00 | 0.00 | 220.53 | 185.93 | 0.00 | 0.00 | 0.00 | 185.93 |
| 23540 | Office | O | 486.53 | 486.53 | 0.00 | 0.00 | 0.00 | 9/08/05 2:29 PM | 9/28/05 9:00 PM | 164.77 | 0.00 | 0.00 | 0.00 | 164.77 | 102.73 | 0.00 | 0.00 | 0.00 | 102.73 |
| 21362 | Office | O | 486.15 | 486.15 | 0.00 | 0.00 | 0.00 | 9/08/05 2:52 PM | 9/28/05 9:00 PM | 187.20 | 0.00 | 0.00 | 0.00 | 187.20 | 54.73 | 0.00 | 0.00 | 0.00 | 54.73 |
| 22027 | Office | O | 486.28 | 486.28 | 0.00 | 0.00 | 0.00 | 9/08/05 2:44 PM | 9/28/05 9:00 PM | 209.88 | 0.00 | 0.00 | 0.00 | 209.88 | 183.58 | 0.00 | 0.00 | 0.00 | 183.58 |
| 22194 | Storage | S | 486.23 | 486.23 | 0.00 | 0.00 | 0.00 | 9/08/05 2:47 PM | 9/28/05 9:00 PM | 194.13 | 0.00 | 0.00 | 0.00 | 194.13 | 97.03 | 0.00 | 0.00 | 0.00 | 97.03 |
| 21406 | MultiPurpose Rm | MP | 486.80 | 486.80 | 0.00 | 0.00 | 0.00 | 9/08/05 2:13 PM | 9/28/05 9:00 PM | 71.95 | 0.00 | 0.00 | 0.00 | 71.95 | 52.50 | 0.00 | 0.00 | 0.00 | 52.50 |
| 21240 | Restroom | R | 486.88 | 486.88 | 0.00 | 0.00 | 0.00 | 9/08/05 2:08 PM | 9/28/05 9:00 PM | 111.67 | 0.00 | 0.00 | 0.00 | 111.67 | 111.63 | 0.00 | 0.00 | 0.00 | 111.63 |
| 22120 | Office | O | 486.37 | 486.37 | 0.00 | 0.00 | 0.00 | 9/08/05 2:39 PM | 9/28/05 9:00 PM | 154.45 | 0.00 | 0.00 | 0.00 | 154.45 | 121.28 | 0.00 | 0.00 | 0.00 | 121.28 |
| 24157 | Office | O | 485.87 | 485.87 | 0.00 | 0.00 | 0.00 | 9/08/05 3:09 PM | 9/28/05 9:00 PM | 416.30 | 0.00 | 0.00 | 0.00 | 416.30 | 169.80 | 0.00 | 0.00 | 0.00 | 169.80 |
| 21674 | Copy Rm | C | 467.97 | 467.97 | 0.00 | 0.00 | 0.00 | 9/09/05 9:03 AM | 9/28/05 9:00 PM | 138.40 | 0.00 | 0.00 | 0.00 | 138.40 | 46.73 | 0.00 | 0.00 | 0.00 | 46.73 |
| 21982 | Office | O | 485.67 | 485.67 | 0.00 | 0.00 | 0.00 | 9/08/05 3:21 PM | 9/28/05 9:00 PM | 154.03 | 0.00 | 0.00 | 0.00 | 154.03 | 131.93 | 0.00 | 0.00 | 0.00 | 131.93 |
| 22123 | Office | O | 486.02 | 486.02 | 0.00 | 0.00 | 0.00 | 9/08/05 3:00 PM | 9/28/05 9:00 PM | 216.88 | 0.00 | 0.00 | 0.00 | 216.88 | 121.12 | 0.00 | 0.00 | 0.00 | 121.12 |
| 22028 | Office | O | 486.02 | 486.02 | 0.00 | 0.00 | 0.00 | 9/08/05 3:00 PM | 9/28/05 9:00 PM | 195.22 | 0.00 | 0.00 | 0.00 | 195.22 | 114.83 | 0.00 | 0.00 | 0.00 | 114.83 |
| 21704 | Office | O | 468.08 | 468.08 | 0.00 | 0.00 | 0.00 | 9/09/05 8:56 AM | 9/28/05 9:00 PM | 169.20 | 0.00 | 0.00 | 0.00 | 169.20 | 118.17 | 0.00 | 0.00 | 0.00 | 118.17 |
| 21409 | Office | O | 486.33 | 486.33 | 0.00 | 0.00 | 0.00 | 9/08/05 2:41 PM | 9/28/05 9:00 PM | 208.75 | 0.00 | 0.00 | 0.00 | 208.75 | 89.87 | 0.00 | 0.00 | 0.00 | 89.87 |
| 22257 | Computer Room | CP | 486.53 | 486.53 | 0.00 | 0.00 | 0.00 | 9/08/05 2:29 PM | 9/28/05 9:00 PM | 100.97 | 0.00 | 0.00 | 0.00 | 100.97 | 93.23 | 0.00 | 0.00 | 0.00 | 93.23 |
| 21528 | Office | O | 486.40 | 486.40 | 0.00 | 0.00 | 0.00 | 9/08/05 2:37 PM | 9/28/05 9:00 PM | 208.77 | 0.00 | 0.00 | 0.00 | 208.77 | 146.80 | 0.00 | 0.00 | 0.00 | 146.80 |
| 22015 | Restroom | R | 486.75 | 486.75 | 0.00 | 0.00 | 0.00 | 9/08/05 2:16 PM | 9/28/05 9:00 PM | 127.33 | 0.00 | 0.00 | 0.00 | 127.33 | 119.33 | 0.00 | 0.00 | 0.00 | 119.33 |
| 21999 | Restroom | R | 486.78 | 486.78 | 0.00 | 0.00 | 0.00 | 9/08/05 2:14 PM | 9/28/05 9:00 PM | 127.70 | 0.00 | 0.00 | 0.00 | 127.70 | 118.83 | 0.00 | 0.00 | 0.00 | 118.83 |

| All Loggers Listed | | | Load | Normalized Weekly Hours of Use | | | | | Normalized Weekly Hours of Occupancy | | | | | |
|--------------------|--------------|----|-------|--------------------------------|------|---------|---------|--------|--------------------------------------|------|---------|---------|--------|--------|
| Logger | Area Type | Ty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total | % sav |
| 21955 | Hallway | H | 240 | 143.74 | 0.00 | 0.00 | 0.00 | 143.74 | 100.10 | 0.00 | 0.00 | 0.00 | 100.10 | 30.36% |
| 21961 | Hallway | H | 240 | 143.92 | 0.00 | 0.00 | 0.00 | 143.92 | 101.72 | 0.00 | 0.00 | 0.00 | 101.72 | 29.32% |
| 22695 | Office | O | 640 | 163.22 | 0.00 | 0.00 | 0.00 | 163.22 | 142.60 | 0.00 | 0.00 | 0.00 | 142.60 | 12.63% |
| 21499 | Office | O | 640 | 141.02 | 0.00 | 0.00 | 0.00 | 141.02 | 123.95 | 0.00 | 0.00 | 0.00 | 123.95 | 12.10% |
| 23992 | Office | O | 640 | 134.73 | 0.00 | 0.00 | 0.00 | 134.73 | 92.83 | 0.00 | 0.00 | 0.00 | 92.83 | 31.10% |
| 21506 | Office | O | 454 | 60.78 | 0.00 | 0.00 | 0.00 | 60.78 | 56.70 | 0.00 | 0.00 | 0.00 | 56.70 | 6.71% |
| 21604 | MultiPurpose | MP | 100 | 168.00 | 0.00 | 0.00 | 0.00 | 168.00 | 54.55 | 0.00 | 0.00 | 0.00 | 54.55 | 67.53% |
| 21741 | Office | O | 640 | 20.40 | 0.00 | 0.00 | 0.00 | 20.40 | 18.55 | 0.00 | 0.00 | 0.00 | 18.55 | 9.07% |
| 22892 | Office | O | 640 | 168.00 | 0.00 | 0.00 | 0.00 | 168.00 | 38.24 | 0.00 | 0.00 | 0.00 | 38.24 | 77.24% |
| 22131 | Office | O | 640 | 54.22 | 0.00 | 0.00 | 0.00 | 54.22 | 31.70 | 0.00 | 0.00 | 0.00 | 31.70 | 41.53% |
| 22706 | Office | O | 454 | 35.54 | 0.00 | 0.00 | 0.00 | 35.54 | 31.53 | 0.00 | 0.00 | 0.00 | 31.53 | 11.28% |
| 23311 | Office | O | 160 | 31.58 | 0.00 | 0.00 | 0.00 | 31.58 | 25.79 | 0.00 | 0.00 | 0.00 | 25.79 | 18.33% |
| 21441 | Office | O | 320 | 31.34 | 0.00 | 0.00 | 0.00 | 31.34 | 25.19 | 0.00 | 0.00 | 0.00 | 25.19 | 19.62% |
| 22059 | Computer | CP | 960 | 39.80 | 0.00 | 0.00 | 0.00 | 39.80 | 39.37 | 0.00 | 0.00 | 0.00 | 39.37 | 1.08% |
| 22355 | Copy Rm | C | 160 | 49.66 | 0.00 | 0.00 | 0.00 | 49.66 | 45.13 | 0.00 | 0.00 | 0.00 | 45.13 | 9.12% |
| 23894 | Office | O | 320 | 57.46 | 0.00 | 0.00 | 0.00 | 57.46 | 45.99 | 0.00 | 0.00 | 0.00 | 45.99 | 19.96% |
| 22522 | Office | O | 320 | 45.45 | 0.00 | 0.00 | 0.00 | 45.45 | 31.57 | 0.00 | 0.00 | 0.00 | 31.57 | 30.54% |
| 23684 | Office | O | 320 | 77.88 | 0.00 | 0.00 | 0.00 | 77.88 | 33.21 | 0.00 | 0.00 | 0.00 | 33.21 | 57.36% |
| 21966 | Office | O | 480 | 53.01 | 0.00 | 0.00 | 0.00 | 53.01 | 43.45 | 0.00 | 0.00 | 0.00 | 43.45 | 18.03% |
| 23662 | Office | O | 480 | 64.01 | 0.00 | 0.00 | 0.00 | 64.01 | 52.06 | 0.00 | 0.00 | 0.00 | 52.06 | 18.67% |
| 21644 | Office | O | 480 | 64.00 | 0.00 | 0.00 | 0.00 | 64.00 | 50.16 | 0.00 | 0.00 | 0.00 | 50.16 | 21.63% |
| 22029 | Hallway | H | 454 | 143.95 | 0.00 | 0.00 | 0.00 | 143.95 | 102.10 | 0.00 | 0.00 | 0.00 | 102.10 | 29.07% |
| 22000 | Office | O | 790 | 76.22 | 0.00 | 0.00 | 0.00 | 76.22 | 64.26 | 0.00 | 0.00 | 0.00 | 64.26 | 15.69% |
| 23540 | Office | O | 480 | 56.89 | 0.00 | 0.00 | 0.00 | 56.89 | 35.47 | 0.00 | 0.00 | 0.00 | 35.47 | 37.65% |
| 21362 | Office | O | 454 | 64.69 | 0.00 | 0.00 | 0.00 | 64.69 | 18.91 | 0.00 | 0.00 | 0.00 | 18.91 | 70.77% |
| 22027 | Office | O | 320 | 72.51 | 0.00 | 0.00 | 0.00 | 72.51 | 63.42 | 0.00 | 0.00 | 0.00 | 63.42 | 12.54% |
| 22194 | Storage | S | 320 | 67.08 | 0.00 | 0.00 | 0.00 | 67.08 | 33.53 | 0.00 | 0.00 | 0.00 | 33.53 | 50.01% |
| 21406 | MultiPurpose | MP | 100 | 24.83 | 0.00 | 0.00 | 0.00 | 24.83 | 18.12 | 0.00 | 0.00 | 0.00 | 18.12 | 27.02% |
| 21240 | Restroom | R | 80 | 38.53 | 0.00 | 0.00 | 0.00 | 38.53 | 38.52 | 0.00 | 0.00 | 0.00 | 38.52 | 0.03% |
| 22120 | Office | O | 640 | 53.35 | 0.00 | 0.00 | 0.00 | 53.35 | 41.89 | 0.00 | 0.00 | 0.00 | 41.89 | 21.48% |
| 24157 | Office | O | 227 | 143.95 | 0.00 | 0.00 | 0.00 | 143.95 | 58.71 | 0.00 | 0.00 | 0.00 | 58.71 | 59.22% |
| 21674 | Copy Rm | C | 160 | 49.69 | 0.00 | 0.00 | 0.00 | 49.69 | 16.78 | 0.00 | 0.00 | 0.00 | 16.78 | 66.23% |
| 21982 | Office | O | 160 | 53.28 | 0.00 | 0.00 | 0.00 | 53.28 | 45.64 | 0.00 | 0.00 | 0.00 | 45.64 | 14.34% |
| 22123 | Office | O | 454 | 74.97 | 0.00 | 0.00 | 0.00 | 74.97 | 41.87 | 0.00 | 0.00 | 0.00 | 41.87 | 44.15% |
| 22028 | Office | O | 160 | 67.48 | 0.00 | 0.00 | 0.00 | 67.48 | 39.69 | 0.00 | 0.00 | 0.00 | 39.69 | 41.18% |
| 21704 | Office | O | 454 | 60.73 | 0.00 | 0.00 | 0.00 | 60.73 | 42.41 | 0.00 | 0.00 | 0.00 | 42.41 | 30.17% |
| 21409 | Office | O | 480 | 72.11 | 0.00 | 0.00 | 0.00 | 72.11 | 31.04 | 0.00 | 0.00 | 0.00 | 31.04 | 56.95% |
| 22257 | Computer | CP | 960 | 34.86 | 0.00 | 0.00 | 0.00 | 34.86 | 32.19 | 0.00 | 0.00 | 0.00 | 32.19 | 7.66% |
| 21528 | Office | O | 640 | 72.11 | 0.00 | 0.00 | 0.00 | 72.11 | 50.70 | 0.00 | 0.00 | 0.00 | 50.70 | 29.69% |
| 22015 | Restroom | R | 220 | 43.95 | 0.00 | 0.00 | 0.00 | 43.95 | 41.19 | 0.00 | 0.00 | 0.00 | 41.19 | 6.28% |
| 21999 | Restroom | R | 220 | 44.07 | 0.00 | 0.00 | 0.00 | 44.07 | 41.01 | 0.00 | 0.00 | 0.00 | 41.01 | 6.94% |

Building Summary Totals Building type:Office. Building size:100K to less than 250K. Shifts:3 Page 1 of 1

| Building Summary Totals | | | | Lights On KWHR | | | | | Occupied KWHR | | | | |
|-------------------------|----|-----|-------|----------------|-----|---------|---------|-------|---------------|-----|---------|---------|-------|
| Area Type | | Qty | Watts | Peak | Off | Shldr 1 | Shldr 2 | Total | Peak | Off | Shldr 1 | Shldr 2 | Total |
| Restroom | R | 3 | 519 | 22 | 0 | 0 | 0 | 22 | 21 | 0 | 0 | 0 | 21 |
| Storage | S | 1 | 320 | 21 | 0 | 0 | 0 | 21 | 11 | 0 | 0 | 0 | 11 |
| Hallway | H | 3 | 933 | 134 | 0 | 0 | 0 | 134 | 95 | 0 | 0 | 0 | 95 |
| Copy Rm | C | 2 | 320 | 16 | 0 | 0 | 0 | 16 | 10 | 0 | 0 | 0 | 10 |
| Office | O | 28 | 12880 | 953 | 0 | 0 | 0 | 953 | 634 | 0 | 0 | 0 | 634 |
| Computer Room | CP | 2 | 1920 | 72 | 0 | 0 | 0 | 72 | 69 | 0 | 0 | 0 | 69 |
| MultiPurpose Rm | MP | 2 | 200 | 19 | 0 | 0 | 0 | 19 | 7 | 0 | 0 | 0 | 7 |
| Building Totals | | | 17092 | 1237 | | | 0 | 1237 | 846 | | | 0 | 846 |