


Area Type Averages

Building type:Office. Building size:500K to less than 1,000K. Shifts:1

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Restroom	R	2	640	63.14	0.00	0.00	63.14	31.77	0.00	0.00	0.00	31.77	49.68%	
Storage	S	4	160	30.17	0.00	0.00	30.17	9.84	0.00	0.00	0.00	9.84	67.38%	
Office	O	11	151	30.28	0.00	0.00	30.28	22.12	0.00	0.00	0.00	22.12	26.95%	
Conference	CN	2	192	11.32	0.00	0.00	11.32	4.59	0.00	0.00	0.00	4.59	59.45%	
Building Average			3965	39.03			39.03	21.56			0.00	21.56	44.76%	



Hours per Week for each Area Type

Data Logger Detail Building type:Office. Building size:500K to less than 1,000K. Shifts:1

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
23257	Office	O	324.47	324.47	0.00	0.00	0.00	9/08/05 11:33 AM	9/22/05 12:00 AM	72.40	0.00	0.00	0.00	72.40	67.20	0.00	0.00	0.00	67.20
21013	Office	O	324.45	324.45	0.00	0.00	0.00	9/08/05 11:34 AM	9/22/05 12:00 AM	67.77	0.00	0.00	0.00	67.77	48.83	0.00	0.00	0.00	48.83
21512	Office	O	324.43	324.43	0.00	0.00	0.00	9/08/05 11:35 AM	9/22/05 12:00 AM	44.50	0.00	0.00	0.00	44.50	40.10	0.00	0.00	0.00	40.10
22175	Conference	CN	324.65	324.65	0.00	0.00	0.00	9/08/05 11:22 AM	9/22/05 12:00 AM	17.97	0.00	0.00	0.00	17.97	5.30	0.00	0.00	0.00	5.30
21939	Storage	S	324.07	324.07	0.00	0.00	0.00	9/08/05 11:57 AM	9/22/05 12:00 AM	11.40	0.00	0.00	0.00	11.40	8.70	0.00	0.00	0.00	8.70
23071	Storage	S	324.08	324.08	0.00	0.00	0.00	9/08/05 11:56 AM	9/22/05 12:00 AM	0.03	0.00	0.00	0.00	0.03	0.00	0.00	0.00	0.00	0.00
23116	Office	O	324.38	324.38	0.00	0.00	0.00	9/08/05 11:38 AM	9/22/05 12:00 AM	32.07	0.00	0.00	0.00	32.07	20.60	0.00	0.00	0.00	20.60
22121	Office	O	324.37	324.37	0.00	0.00	0.00	9/08/05 11:39 AM	9/22/05 12:00 AM	39.73	0.00	0.00	0.00	39.73	36.50	0.00	0.00	0.00	36.50
22405	Office	O	324.33	324.33	0.00	0.00	0.00	9/08/05 11:41 AM	9/22/05 12:00 AM	53.33	0.00	0.00	0.00	53.33	42.50	0.00	0.00	0.00	42.50
22179	Office	O	324.33	324.33	0.00	0.00	0.00	9/08/05 11:41 AM	9/22/05 12:00 AM	67.50	0.00	0.00	0.00	67.50	54.53	0.00	0.00	0.00	54.53
23223	Office	O	324.30	324.30	0.00	0.00	0.00	9/08/05 11:43 AM	9/22/05 12:00 AM	5.93	0.00	0.00	0.00	5.93	1.87	0.00	0.00	0.00	1.87
21566	Office	O	324.22	324.22	0.00	0.00	0.00	9/08/05 11:48 AM	9/22/05 12:00 AM	58.47	0.00	0.00	0.00	58.47	38.63	0.00	0.00	0.00	38.63
23199	Storage	S	324.12	324.12	0.00	0.00	0.00	9/08/05 11:54 AM	9/22/05 12:00 AM	85.27	0.00	0.00	0.00	85.27	47.37	0.00	0.00	0.00	47.37
20534	Conference	CN	324.13	324.13	0.00	0.00	0.00	9/08/05 11:53 AM	9/22/05 12:00 AM	25.73	0.00	0.00	0.00	25.73	12.43	0.00	0.00	0.00	12.43
24645	Office	O	324.57	324.57	0.00	0.00	0.00	9/08/05 11:27 AM	9/22/05 12:00 AM	65.30	0.00	0.00	0.00	65.30	53.43	0.00	0.00	0.00	53.43
22408	Restroom	R	324.23	324.23	0.00	0.00	0.00	9/08/05 11:47 AM	9/22/05 12:00 AM	138.23	0.00	0.00	0.00	138.23	69.80	0.00	0.00	0.00	69.80
23212	Restroom	R	324.27	324.27	0.00	0.00	0.00	9/08/05 11:45 AM	9/22/05 12:00 AM	105.50	0.00	0.00	0.00	105.50	52.80	0.00	0.00	0.00	52.80
21624	Office	O	324.55	324.55	0.00	0.00	0.00	9/08/05 11:28 AM	9/22/05 12:00 AM	136.23	0.00	0.00	0.00	136.23	65.73	0.00	0.00	0.00	65.73
22484	Storage	S	324.60	324.60	0.00	0.00	0.00	9/08/05 11:25 AM	9/22/05 12:00 AM	136.30	0.00	0.00	0.00	136.30	19.93	0.00	0.00	0.00	19.93

Normalized Data Logger Detail Building type:Office. Building size:500K to less than 1,000K. Shifts:1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
23257	Office	O	128	37.49	0.00	0.00	0.00	37.49	34.79	0.00	0.00	0.00	34.79	7.20%
21013	Office	O	128	35.09	0.00	0.00	0.00	35.09	25.29	0.00	0.00	0.00	25.29	27.93%
21512	Office	O	192	23.04	0.00	0.00	0.00	23.04	20.76	0.00	0.00	0.00	20.76	9.90%
22175	Conference	CN	128	9.30	0.00	0.00	0.00	9.30	2.74	0.00	0.00	0.00	2.74	70.54%
21939	Storage	S	192	5.91	0.00	0.00	0.00	5.91	4.51	0.00	0.00	0.00	4.51	23.69%
23071	Storage	S	64	0.02	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.00	0.00	00.00%
23116	Office	O	192	16.61	0.00	0.00	0.00	16.61	10.67	0.00	0.00	0.00	10.67	35.76%
22121	Office	O	192	20.58	0.00	0.00	0.00	20.58	18.90	0.00	0.00	0.00	18.90	8.16%
22405	Office	O	192	27.63	0.00	0.00	0.00	27.63	22.01	0.00	0.00	0.00	22.01	20.34%
22179	Office	O	128	34.96	0.00	0.00	0.00	34.96	28.25	0.00	0.00	0.00	28.25	19.19%
23223	Office	O	128	3.07	0.00	0.00	0.00	3.07	0.97	0.00	0.00	0.00	0.97	68.40%
21566	Office	O	128	30.30	0.00	0.00	0.00	30.30	20.02	0.00	0.00	0.00	20.02	33.93%
23199	Storage	S	64	44.20	0.00	0.00	0.00	44.20	24.55	0.00	0.00	0.00	24.55	44.46%
20534	Conference	CN	256	13.34	0.00	0.00	0.00	13.34	6.44	0.00	0.00	0.00	6.44	51.72%
24645	Office	O	128	33.80	0.00	0.00	0.00	33.80	27.66	0.00	0.00	0.00	27.66	18.17%
22408	Restroom	R	640	71.62	0.00	0.00	0.00	71.62	36.17	0.00	0.00	0.00	36.17	49.50%
23212	Restroom	R	640	54.66	0.00	0.00	0.00	54.66	27.36	0.00	0.00	0.00	27.36	49.95%
21624	Office	O	128	70.52	0.00	0.00	0.00	70.52	34.03	0.00	0.00	0.00	34.03	51.74%
22484	Storage	S	320	70.54	0.00	0.00	0.00	70.54	10.32	0.00	0.00	0.00	10.32	85.37%

Building Summary Totals Building type:Office. Building size:500K to less than 1,000K. Shifts:1

Building Summary Totals				Lights On KWHR					Occupied KWHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	2	1280	81	0	0	0	81	41	0	0	0	41
Storage	S	4	640	19	0	0	0	19	6	0	0	0	6
Office	O	11	1661	50	0	0	0	50	37	0	0	0	37
Conference	CN	2	384	4	0	0	0	4	2	0	0	0	2
Building Totals			3965	155			0	155	85			0	85