


# Area Type Averages

Building type:Restaurant. Building size:50K to less than 100K. Shifts:3

Area Type Averages				Normalized Weekly Lights On					Normalized Weekly Occupied					
Area Type	Qty	Watts		Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
Restroom	R	2	64	167.99	0.00	0.00	0.00	167.99	105.68	0.00	0.00	0.00	105.68	37.09%
Storage	S	2	64	131.63	0.00	0.00	0.00	131.63	47.42	0.00	0.00	0.00	47.42	63.97%
Kitchen	K	3	64	83.60	0.00	0.00	0.00	83.60	64.67	0.00	0.00	0.00	64.67	22.64%
Locker Room	LR	1	64	148.41	0.00	0.00	0.00	148.41	73.18	0.00	0.00	0.00	73.18	50.69%
Cafeteria	CF	6	64	136.30	0.00	0.00	0.00	136.30	126.39	0.00	0.00	0.00	126.39	7.27%
Office	O	1	64	108.60	0.00	0.00	0.00	108.60	95.57	0.00	0.00	0.00	95.57	12.00%
Building Average			960	128.32			0.00	128.32	95.15			0.00	95.15	25.85%



Hours per Week for each Area Type

## Data Logger Detail Building type:Restaurant. Building size:50K to less than 100K. Shifts:3

All Loggers Listed			Hours Installed					Lights On					Occupied						
Logger	Area Type	Ty	Total	Peak	Off	Shldr 1	Shldr 2	Installed	Removed	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
22711	Cafeteria	CF	363.65	363.65	0.00	0.00	0.00	9/19/05 10:45 AM	10/04/05 2:23 PM	230.87	0.00	0.00	0.00	230.87	221.03	0.00	0.00	0.00	221.03
21938	Cafeteria	CF	372.28	372.28	0.00	0.00	0.00	9/19/05 10:44 AM	10/04/05 11:00	241.12	0.00	0.00	0.00	241.12	218.62	0.00	0.00	0.00	218.62
20597	Cafeteria	CF	182.72	182.72	0.00	0.00	0.00	9/19/05 10:44 AM	9/27/05 1:26 AM	116.97	0.00	0.00	0.00	116.97	114.37	0.00	0.00	0.00	114.37
22266	Restroom	R	363.70	363.70	0.00	0.00	0.00	9/19/05 10:50 AM	10/04/05 2:31 PM	363.68	0.00	0.00	0.00	363.68	281.25	0.00	0.00	0.00	281.25
22010	Restroom	R	363.68	363.68	0.00	0.00	0.00	9/19/05 10:54 AM	10/04/05 2:34 PM	363.67	0.00	0.00	0.00	363.67	176.30	0.00	0.00	0.00	176.30
22792	Cafeteria	CF	363.20	363.20	0.00	0.00	0.00	9/19/05 11:03 AM	10/04/05 2:14 PM	353.22	0.00	0.00	0.00	353.22	321.35	0.00	0.00	0.00	321.35
20494	Cafeteria	CF	363.13	363.13	0.00	0.00	0.00	9/19/05 11:06 AM	10/04/05 2:13 PM	363.12	0.00	0.00	0.00	363.12	332.65	0.00	0.00	0.00	332.65
20506	Cafeteria	CF	371.98	371.98	0.00	0.00	0.00	9/19/05 11:02 AM	10/04/05 11:00	361.85	0.00	0.00	0.00	361.85	331.88	0.00	0.00	0.00	331.88
20563	Storage	S	363.05	363.05	0.00	0.00	0.00	9/19/05 11:14 AM	10/04/05 2:16 PM	333.27	0.00	0.00	0.00	333.27	95.93	0.00	0.00	0.00	95.93
22720	Storage	S	362.97	362.97	0.00	0.00	0.00	9/19/05 11:19 AM	10/04/05 2:16 PM	235.58	0.00	0.00	0.00	235.58	109.00	0.00	0.00	0.00	109.00
20602	Kitchen	K	363.17	363.17	0.00	0.00	0.00	9/19/05 11:08 AM	10/04/05 2:17 PM	128.90	0.00	0.00	0.00	128.90	44.93	0.00	0.00	0.00	44.93
22276	Kitchen	K	371.87	371.87	0.00	0.00	0.00	9/19/05 11:09 AM	10/04/05 11:00	208.73	0.00	0.00	0.00	208.73	191.67	0.00	0.00	0.00	191.67
20901	Locker Room	LR	362.93	362.93	0.00	0.00	0.00	9/19/05 11:20 AM	10/04/05 2:15 PM	320.62	0.00	0.00	0.00	320.62	158.10	0.00	0.00	0.00	158.10
20841	Office	O	363.07	363.07	0.00	0.00	0.00	9/19/05 11:15 AM	10/04/05 2:18 PM	234.70	0.00	0.00	0.00	234.70	206.53	0.00	0.00	0.00	206.53
21365	Kitchen	K	362.95	362.95	0.00	0.00	0.00	9/19/05 11:19 AM	10/04/05 2:15 PM	209.27	0.00	0.00	0.00	209.27	187.15	0.00	0.00	0.00	187.15

## Normalized Data Logger Detail Building type:Restaurant. Building size:50K to less than 100K. Shifts:3

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Area Type	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
22711	Cafeteria	CF	64	106.66	0.00	0.00	0.00	106.66	102.11	0.00	0.00	0.00	102.11	4.27%
21938	Cafeteria	CF	64	108.81	0.00	0.00	0.00	108.81	98.65	0.00	0.00	0.00	98.65	9.34%
20597	Cafeteria	CF	64	107.55	0.00	0.00	0.00	107.55	105.16	0.00	0.00	0.00	105.16	2.22%
22266	Restroom	R	64	167.99	0.00	0.00	0.00	167.99	129.91	0.00	0.00	0.00	129.91	22.67%
22010	Restroom	R	64	167.99	0.00	0.00	0.00	167.99	81.44	0.00	0.00	0.00	81.44	51.52%
22792	Cafeteria	CF	64	163.38	0.00	0.00	0.00	163.38	148.64	0.00	0.00	0.00	148.64	9.02%
20494	Cafeteria	CF	64	167.99	0.00	0.00	0.00	167.99	153.90	0.00	0.00	0.00	153.90	8.39%
20506	Cafeteria	CF	64	163.42	0.00	0.00	0.00	163.42	149.89	0.00	0.00	0.00	149.89	8.28%
20563	Storage	S	64	154.22	0.00	0.00	0.00	154.22	44.39	0.00	0.00	0.00	44.39	71.22%
22720	Storage	S	64	109.04	0.00	0.00	0.00	109.04	50.45	0.00	0.00	0.00	50.45	53.73%
20602	Kitchen	K	64	59.63	0.00	0.00	0.00	59.63	20.79	0.00	0.00	0.00	20.79	65.14%
22276	Kitchen	K	64	94.30	0.00	0.00	0.00	94.30	86.59	0.00	0.00	0.00	86.59	8.18%
20901	Locker Room	LR	64	148.41	0.00	0.00	0.00	148.41	73.18	0.00	0.00	0.00	73.18	50.69%
20841	Office	O	64	108.60	0.00	0.00	0.00	108.60	95.57	0.00	0.00	0.00	95.57	12.00%
21365	Kitchen	K	64	96.86	0.00	0.00	0.00	96.86	86.63	0.00	0.00	0.00	86.63	10.56%

## Building Summary Totals Building type:Restaurant. Building size:50K to less than 100K. Shifts:3

Building Summary Totals				Lights On KwHR					Occupied KwHR				
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Restroom	R	2	128	22	0	0	0	22	14	0	0	0	14
Storage	S	2	128	17	0	0	0	17	6	0	0	0	6
Kitchen	K	3	192	16	0	0	0	16	12	0	0	0	12
Locker Room	LR	1	64	9	0	0	0	9	5	0	0	0	5
Cafeteria	CF	6	384	52	0	0	0	52	49	0	0	0	49
Office	O	1	64	7	0	0	0	7	6	0	0	0	6
Building Totals			960	123			0	123	91				91